

Attachment B

MARKED-UP TECHNICAL SPECIFICATION 6.8.4

Insert Page 6-15a

8512020283 851125
PDR ADCK 05000275
P PDR



PROCEDURES AND PROGRAMS (Continued)c. Secondary Water Chemistry

A program for monitoring of secondary water chemistry to inhibit steam generator tube degradation. This program shall include:

- 1) Identification of a sampling schedule for the critical variables and control points for these variables,
- 2) Identification of the procedures used to measure the values of the critical variables,
- 3) Identification of process sampling points, including monitoring the discharge of the condensate pumps for evidence of condenser in-leakage,
- 4) Procedures for the recording and management of data,
- 5) Procedures defining corrective actions for all off-control point chemistry conditions, and
- 6) A procedure identifying: (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action.

d. Backup Method for Determining Subcooling Margin

A program which will ensure the capability to accurately monitor the Reactor Coolant System subcooling margin. This program shall include the following:

- 1) Training of personnel, and
- 2) Procedures for monitoring.

e. Postaccident Sampling

A program which will ensure the capability to obtain and analyze reactor coolant, radioactive iodines and particulates in plant gaseous effluents, and containment atmosphere samples under accident conditions. The program shall include the following:

- 1) Training of personnel,
- 2) Procedures for sampling and analysis, and
- 3) Provisions for maintenance of sampling and analysis equipment.



PROCEDURES AND PROGRAMS (Continued)

f. Containment Polar and Turbine Building Cranes

A program which will ensure that: 1) the position of the containment polar cranes precludes jet impingement from a postulated pipe rupture; and 2) the operation of the turbine building cranes is consistent with the restrictions associated with the current Hosgri seismic analysis of the turbine building. This program shall include the following:

- 1) Training of personnel, and
- 2) Procedures for the containment polar and turbine building cranes operation.

