

RECEIVED
NRC

PACIFIC GAS AND ELECTRIC COMPANY

PG&E



77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

1986 JUL 22 PM 12:50

JAMES D. SHIFFER
VICE PRESIDENT
NUCLEAR POWER GENERATION

July 18, 1986

REGION V IRE

PGandE Letter No.: DCL-86-208

Mr. John B. Martin, Regional Administrator
U. S. Nuclear Regulatory Commission, Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596-5368

Re: Docket No. 50-275, OL-DPR-80
Diablo Canyon Unit 1
Sampling Plan for Safety-Related Snubbers

Dear Mr. Martin:

As required by DCPD Technical Specification 4.7.7.1e, PGandE is hereby notifying the NRC Regional Administrator of the sampling plan to be used in verifying the operability of safety-related snubbers. During the Unit 1 first refueling outage PGandE will implement the sampling plan outlined in Technical Specification 4.7.7.1e.3).

As required in the Technical Specification 4.7.7.1e.3) sample plan, an initial representative sample of 55 snubbers will be functionally tested. For each type of snubber that does not meet the functional test acceptance criteria, another sample at least half the size of the initial sample will be tested, until the total number tested is equal to the initial sample size multiplied by the factor $1 + C/2$, where "C" is the number of snubbers found that do not meet the functional test acceptance criteria. This testing will continue until the results from this sample fall on or below an "accept" line defined by the equation for the cumulative number of snubbers of a type tested $[N = 55 (1 + C/2)]$, or until all of the snubbers of that type have been tested.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Sincerely,

[Signature]
for J. D. Shiffer

Enclosure

REGION V IRE

cc: L. J. Chandler
M. M. Mendonca
B. Norton
H. E. Schierling
S. A. Varga
CPUC
Diablo Distribution

0946S/0046K/DJH/623

IEDI
11

8608010268 860718
PDR ADDCK 05000275
P PDR

