

ENCLOSURE 2

ERRATA CONTAINING REPLACEMENT PAGES FOR
FOURTH QUARTER 1998
NPDES DISCHARGE MONITORING REPORTS FOR
DIABLO CANYON POWER PLANT

Please locate the reports listed in the Errata below and replace the incorrect pages with the corrected form provided in the enclosure.

ERRATA: Fourth Quarter 1998 NPDES Discharge Monitoring Report, PG&E Letter DCL-9-500, dated January 20, 1999. The replacement pages for the following errata are attached:

Page (A)1 data for influent and effluent metals were incorrectly reported. Spike values were incorrectly reported as the method reporting limit.

Page (M)7 data for Effluent 001N Suspended Solids, the monthly average and high were incorrectly calculated. DCCP remained in compliance with the monthly average limit of 60 mg/l.

9903080188 990226
PDR ADOCK 05000275
R PDR




FACILITY I.D. 3 402003001	BEGINNING YEAR / MO / DAY 98 / 10 / 01	ENDING YEAR / MO / DAY 98 / 10 / 31	STATE CODE 06	NPDES PERMIT # CA0003751				
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001 TITANIUM ug/l GRAB OCTOBER	INFLUENT ARSENIC ug/l GRAB OCTOBER	EFFLUENT ARSENIC ug/l GRAB OCTOBER	INFLUENT CADMIUM ug/l GRAB OCTOBER	EFFLUENT 001 CADMIUM ug/l GRAB OCTOBER	INFLUENT LEAD ug/l GRAB OCTOBER	EFFLUENT 001 LEAD ug/l GRAB OCTOBER	INFLUENT ZINC ug/l GRAB OCTOBER
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14	ND (5)	1.7	1.5	0.06	0.04	0.11	0.02	ND (10)
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG	ND (5)	1.7	1.5	0.06	0.04	0.11	0.02	ND (10)
MONTHLY HIGH	ND (5)	1.7	1.5	0.06	0.04	0.11	0.02	ND (10)
MONTHLY LOW	ND (5)	1.7	1.5	0.06	0.04	0.11	0.02	ND (10)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	6M - MEAN 30 = 0	NO LIMIT	6M-MEAN 10 = 0	NO LIMIT	6M-MEAN 10 = 0	NO LIMIT
TIMES EXCEEDED			D MAX 150 = 0		D MAX 20 = 0		D MAX 40 = 0	
TIMES EXCEEDED			I MAX 400 = 0		I MAX 50 = 0		I MAX 100 = 0	

REMARKS: *NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
GREGORY M. RUEGER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Drew Squim...</i>	26-Feb-99



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
81 HIGUERA
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 55
AVILA BEACH, CALIF 93424

PAGE: (M) 7

FACILITY I.D.	YEAR / MO / DAY			YEAR / MO / DAY			STATE CODE	NPDES PERMIT #
3402003001	BEGINNING	98 / 10 / 01	ENDING	98 / 10 / 31			06	CA0003751
STATION ANALYSIS UNITS SAMPL TYPE FREQ.	EFFLUENT 001M SUSPENDED SOLIDS			EFFLUENT 001N SUSPENDED SLDS mg/l COMPOSITE WEEKLY	EFFLUENT 001P SUSPENDED SOLIDS			
	mg/l 1st FLTR	mg/l 2nd FLTR GRAB MONTHLY	mg/l NET		mg/l 1st FLTR	mg/l 2nd FLTR GRAB MONTHLY	mg/l NET	
1								
2				ND (10)				
3								
4								
5					5	1		ND (5)
6								
7								
8				12				
9								
10								
11								
12								
13								
14								
15				12				
16								
17								
18								
19								
20								
21				15				
22								
23								
24								
25								
26				ND (10)				
27			2	ND (10)				
28			2	11				
29			2	16				
30			2	14				
31								
MONTHLY AVG	NO DISCHARGE			9	ND (5)			
MONTHLY HIGH				21	ND (5)			
MONTHLY LOW				ND (10)	ND (5)			
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0	MO AVG 60 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0	
TIMES EXCEEDED			D MAX 100 = 0				D MAX 100 = 0	
TIMES EXCEEDED								

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
GREGORY M. RUEGER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Drew Squyres</i>	26-7-99

