

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

CCESSION NBR: 7909110533 DDC DATE: 79/09/05 NOTARIZED: NO DOCKET # 05000275
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000323
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga
 AUTH. NAME CRANE, P. A. AUTHOR AFFILIATION Pacific Gas & Electric Co.
 RECIP. NAME STOLZ, J. F. RECIPIENT AFFILIATION Light Water Reactors Branch 1

SUBJECT: Supplements 790226 submittal on primary overcurrent fault protective sys. Matl pertains to ability of protective systems to prevent heat rises as related to containment structure.

DISTRIBUTION CODE: B001B COPIES RECEIVED: LTR 1 ENCL 40 SIZE: 26
 TITLE: PSAR/FSAR Amdts. & Related Correspondence

NOTES: J. HANCHETT W/ICM ALL MATL.

TION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
BC	05 PM B BUCKLEY	1	1	AD LWR	1	0
	LWR #1	1	0	LA LWR #1	1	0
TERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	06 I & E	2	2	08 OPERA LIC BR	1	1
	09 GEOSCIEN BR	4	4	10 GAB	1	1
	11 MECH ENG BR	1	1	12 STRUC ENG BR	1	1
	13 MATL ENG BR	2	2	15 REAC SYS BR	1	1
	16 ANALYSIS BR	1	1	17 CORE PERF BR	1	1
	18 AUX SYS BR	1	1	19 CONTAIN SYS	1	1
	20 I & C SYS BR	1	1	21 POWER SYS BR	1	1
	22 AD SITE TECH	1	0	26 ACCDNT ANLYS	1	1
	27 EFFL TRT SYS	1	1	28 RAD ASMT BR	1	1
	29 KIRKWOOD	1	1	AD FOR ENG	1	0
	AD PLANT SYS	1	0	AD REAC SAFETY	1	0
	AD SITE ANALYSIS	1	0	DIRECTOR NRR	1	0
	HYDRO-METEOR .BR	2	2	MPA	1	0
	OELD	1	0			
	TERNAL:	03 LPDR	1	1	04 NSIC	1
30 ACRS		10	10			

LTR
 MOORE
 EPB #1 BC
 S. KIRSLIS
 EPB #1 LA

SEP 12 1979

COB

MA
4

TOTAL NUMBER OF COPIES REQUIRED: LTTR 56 ENCL 41

PACIFIC GAS AND ELECTRIC COMPANY

PG&E + 77 BEALE STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

JOHN C. MORRISSEY
VICE PRESIDENT AND GENERAL COUNSEL

MALCOLM H. FURBUSH
ASSOCIATE GENERAL COUNSEL

CHARLES T. VAN DEUSEN
PHILIP A. CRANE, JR.
HENRY J. LaPLANTE
JOHN B. GIBSON

ARTHUR L. HILLMAN, JR.

ROBERT OHLBACH
CHARLES W. THISSELL

DANIEL E. GIBSON
ASSISTANT GENERAL COUNSEL

September 5, 1979

DILBERT L. HARRICK
GLENN WEST, JR.
JOSEPH I. KELLY
HOWARD V. GOLUB
JAMES C. LOSBOON
ROBERT L. BORRICH
PETER W. HANSCHEN
THEODORE L. LINDBERG, JR.
DOUGLAS A. DOLESBY

SENIOR COUNSEL

EDWARD J. McGANNEY
DAN GRAYSON LUBBOCK
JACK F. FALLIN, JR.
BERNARD J. DELLABANTA
JOSHUA BAR-LEV
JOSEPH S. ENGLEST, JR.
ROBERT L. HARRIS
RICHARD F. LODGE
DAVID L. LUDVIGSON

J. PETER BAUMGARTNER
STEVEN P. BURKE
PAMELA CHAPPELLE
AUDREY DAINES
MICHAEL Q. DESMARAIS
DARY P. ENDINAS
JOHN R. FRYE
PATRICK Q. GOLDEN
KERNIT R. KUBITZ
MEEK E. LIPSON
JOHN R. LOW
RICHARD L. MEISS
ROGER J. PETERS
ROBERT R. RICKETT
SHIRLEY A. SANDERSON
JO ANN SHAFFER
LOUIS E. VINCENT
SHIRLEY A. WOOD

DIANA BERGHAUSEN
LEIGH B. CARRIOY
HEATHER S. GIBSON
BRIAN S. DENTON
WILLIAM H. EDWARDS
DONALD D. ERICKSON
DAVID C. GILBERT
JUAN M. JAYO
F. RONALD LAUPHEIMER
HARRY W. LONG, JR.
ROBERT S. MCLENNAN
RICHARD H. MOSS
J. MICHAEL REIDENBACH
IVOR E. SANBORN
SUE ANN LEVIN SCHIFF
JACK W. SHUCK
DAVID J. WILLIAMSON
BRUCE R. WORTHINGTON

ATTORNEYS

REGULATORY DOCKET FILE COPY

Mr. John F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Docket No. 50-275-OL
Docket No. 50-323-OL
Diablo Canyon Units 1 and 2

Dear Mr. Stolz:

In response to questions from the Staff, the attached material expands our February 26, 1979 submittal on Primary Overcurrent Fault Protective Systems for Containment Penetrations to include a discussion of the ability of the protective systems to prevent heat rises in the containment electrical penetrations from compromising the integrity of the containment structure.

Five copies of this submittal have been sent directly to Mr. Bart Buckley.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it to me in the enclosed addressed envelope.

Very truly yours,

Philip A. Crane

Attachments

BOOK 1/40

7909110533

A



15

[illegible]

Figure 1

Figure 1. The effect of the number of trials on the number of correct responses. The number of correct responses was significantly higher than the number of incorrect responses in all cases. The number of correct responses was significantly higher than the number of incorrect responses in all cases. The number of correct responses was significantly higher than the number of incorrect responses in all cases.

[illegible][illegible]

100

[illegible]

PRIMARY OVERCURRENT FAULT PROTECTIVE SYSTEMS
FOR
CONTAINMENT PENETRATIONS
Additional Information

The attached Primary Protection Curves, have been revised from the February 26, 1979 submittal to include penetration conductor time-current curves for an initial conductor temperature T_1 of at least 132°C (270°F) and a final conductor temperature T_2 of 171°C (340°F). The initial temperature T_1 is assumed to be at least equal to the LOCA peak containment temperature shown in Figure 6.2-6 of the FSAR. Where required, because of continuous operation of equipment, the initial penetration conductor temperature T_1 was increased to give a conservative allowance for normal current heat rise in the penetration conductors. The final temperature T_2 is the penetration qualification test temperature of 171°C (340°F) (See Reference 1).

One curve, Figure 6, has been redrawn to reflect the new settings of the primary protective circuit breaker.

The equation (See Reference 2) to calculate the conductor time-current curve is

$$t = \frac{0.0279 A^2}{I^2} \log \frac{T_2 + 234}{T_1 + 234}$$

where

t = Time-seconds

I = Current-amperes

A = Conductor area - circular mils

T_1 = Assumed initial conductor temperature (See above for details)

T_2 = Maximum allowable conductor temperature (171°C)

The calculations are based upon the assumption that all heat generated by the current flowing through the conductor remains in the conductor. This approach is conservative since conductors outside the containment will act as a heat sink and will cool the penetration conductors. The assumption that the penetration conductors reach the peak LOCA temperature as an initial condition is also conservative since the containment liner and concrete temperatures remain well below the peak and are therefore, unable to cause the conductors to reach the assumed T_1 .



11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61

11-11-61


An evaluation of the Primary Protection Curves shows that all electrical penetrations at Diablo Canyon are adequately protected since overcurrents and short circuit currents will not cause undue heat rises in the penetration conductors during the worst postulated ambient conditions and therefore will not compromise the integrity of the containment structure.

- Reference 1. General Electric 100 Series Electrical Penetrations Qualification Test Report dated January 18, 1974.
- Reference 2. Short Circuit Characteristics of Insulated Cable, Publication P-32-382, Revised March 1969, Reprinted 1973, Insulated Power Cable Engineers Association (IPCEA)

1. The first part of the document is a list of names and addresses of the members of the committee. The names are listed in alphabetical order, and the addresses are given in full, including the street, city, and state.

2. The second part of the document is a list of the names and addresses of the members of the committee who have been elected to the office of the chairman. The names are listed in alphabetical order, and the addresses are given in full, including the street, city, and state.

PENETRATIONS 40E, 41E, 43E, 44E



REACTOR COOLANT P.P.'S TIME-CURRENT CHARACTERISTIC CURVES Primary Protection

For..... Fuse Links. In.....

BASIS FOR DATA Standards..... Dated.....

1. Tests made at.....Volts a-c at..... p-f, Starting at 25C with no initial load.....

2. Curves are plotted to.....Test points so variations should be.....

No.....


Date.....DEC.....1.....1978.....

K&E TIME-CURRENT CHARACTERISTIC 48 5257 MADE IN U.S.A. KEUFFEL & ESSER CO.

Schematic - 437586-10 (W)


FIG. 1 REV. 8/17/79 JET/le

PENETRATIONS
1E, 34E, 37E




<u>PRESSURIZER HEATERS</u> TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION	
For _____	Fuse Links. In _____
BASIS FOR DATA Standards _____ Dated _____	
1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load.	
2. Curves are plotted to _____ Test points so variations should be _____	
No. _____	Date <u>12-14-78</u>

PENETRATIONS
3E, 9E, 15E, 29E, 32E



CONT. FAN COOLERS		TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION	
For _____ Fuse Links. In _____			
BASIS FOR DATA Standards _____ Dated _____			
1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____		No. _____	
2. Curves are plotted to _____ Test points so variations should be _____		Date 12-1-78	



EMER. LTG. TLE 16 TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION

For _____ Fuse Links. In _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____

2. Curves are plotted to _____ Test points so variations should be _____

No. _____

Date JAN. 15, 1979

5E, 17E



FPE FRS2-25-600

450A, 3 POLE, 500A TAP

52-7807, 52-1343

CIRCUIT

5004P00, 5004P90

SHORT TIME
PICK UP (EX500)

SHORT TIME BANDS

MAX. BUS DUTY
12 CYCLES


MAX. FAULT DUTY
5400A

DIABLO CANYON UNIT 1, MCC 13 BUS J&I TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links. In _____
BASIS FOR DATA Standards _____ Dated _____
1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load
2. Curves are plotted to _____ Test points so variations should be _____


No. _____
Date AUG. 7, 1979 *J. E. [signature]*

FIG. 6
REDRAIN 8/7/79



For FRES PWR REL VV TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION
FUSE LINKS. In _____
BASIS FOR DATA Standards _____ Dated _____
1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____
2. Curves are plotted to _____ Test points so variations should be _____
No. _____
Date JAN. 17, 1979


PENETRATION
19E, 12E



RHK SUCT. VALVE TIME-CURRENT CHARACTERISTIC CURVES Primary Protection
 For _____ Fuse Links. In _____
 BASIS FOR DATA Standards _____ Dated _____
 1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____
 2. Curves are plotted to _____ Test points so variations should be _____
 No. _____
 Date JAN 17 1979

Fig 8
REV: 8/17/77

PENETRATION
19E



8703 RHE RECIR. VV

TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION

For _____ Fuse Links. In _____

BASIS FOR DATA Standards _____ Date _____


1. Tests made at _____ Volts a-c at _____ p.f., starting at 25C with no initial load.

2. Curves are plotted to _____ Test points so variations should be _____

No. _____

Date JAN. 18, 1970

PENETRATION
12E



RCP REAR. OIL VV, FCV 749 TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION

For _____ Fuse Links. In _____


BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load.

2. Curves are plotted to _____ Test points so variations should be _____


No. _____

Date JAN. 18, 1979



8112 RCP SEAL WTR RTN TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECT IN
150 UV
For _____ Fuse Links. In _____
BASIS FOR DATA Standards _____ Dated _____
1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____
2. Curves are plotted to _____ Test points so variations should be _____
No. _____
Date JAN. 18 1979

12E, 19E, 26E



For ACCUM INJECT TO TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION
COLD LOAD VV Fuse Links. In _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____


2. Curves are plotted to _____ Test points so variations should be _____

No. _____

Date JAN. 12, 1959

FIG. 12
RE: 8/17/74 ≤ 25


PENETRATION
236, 11E



For CONT. sump pps TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION
Basis for Data Standards _____ Fuse Links. In _____ Dated _____
1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____
2. Curves are plotted to _____ Test points so variations should be _____


No. _____
Date Jan 19, 1977

PENETRATION
37E, 5E, 1E, 34E




CRD BLO FN 11,12,13, TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION
For 314 Fuse Links. In
BASIS FOR DATA Standards Dated
1. Tests made at Volts a-c at p-f., starting at 25C with no initial load
2. Curves are plotted to Test points so variations should be
No. Date JAN, 31, 1979

PENETRATION
11E, 23E




RCP TBRG LPP 11, 12, 13, TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION	
For <u>§14</u>	Fuse Links. In _____
BASIS FOR DATA Standards _____ Dated _____	
1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load.	
2. Curves are plotted to _____ Test points so variations should be _____	
No. _____	Date <u>JAN 31, 1979</u>

PENETRATION
11E, 23E




For RC DRN TK PD 1-1, 1-2 TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION
5 FODINE REM E-15 Fuse Links. In _____
BASIS FOR DATA Standards _____ Dated _____
1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____
2. Curves are plotted to _____ Test points so variations should be _____
No. _____
Date JAN, 31, 1979



IODINE REM E16 TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION

- For _____ Fuse Links. In _____
- BASIS FOR DATA Standards _____ Dated _____
1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____
2. Curves are plotted to _____ Test points so variations should be _____

No. _____
Date JAN 31 1973



CONT. AC FAULT SIB TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION

For _____ Fuse Links. In _____

BASIS FOR DATA Standards _____ Dated _____


1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. _____

Date JAN 31, 1977

PROTECTION
11E, 23E



For REAC. CAI. SURG. PP'S TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECTION


Basis for Data Standards Fuse Links. In _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. _____
Date JAN 19, 1979

PENETRATION
1 34E, 37E




Nu. 202 HSE BACKS TIME-CURRENT CHARACTERISTIC CURVES PRIMARY SYSTEM
 For _____ Fuse Links. In _____
 BASIS FOR DATA Standards _____ Dated _____
 1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load
 2. Curves are plotted to _____ Test points so variations should be _____
 No. _____
 Date JAN. 31 1979

FIG. 20
REV 9-7-68

12E, 26E



For _____ Fuse Links. In _____
BASIS FOR DATA Standards _____ Dated _____
1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____
2. Curves are plotted to _____ Test points so variations should be _____



(DC) EMEG, LTG, PNL PLED 161 TIME-CURRENT CHARACTERISTIC CURVES PRIMARY PROTECT

For _____ Fuse Links. In _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____

2. Curves are plotted to _____ Test points so variations should be _____

No. _____

Date JAN 31, 1979

