

ATTACHMENT B

MARKED-UP TECHNICAL SPECIFICATIONS

Remove Page

3/4 4-8

Insert Page

3/4 4-8

6893S

9507070149 950629
PDR ADDCK 05000275
P PDR

REACTOR COOLANT SYSTEM

OPERATING

LIMITING CONDITION FOR OPERATION

3.4.2.2 All pressurizer Code safety valves shall be OPERABLE with a lift setting of 2485 psig \pm 1%.*

APPLICABILITY: MODES 2, 3 and 4.#

ACTION:

- 1,
- a. With one pressurizer Code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 15 minutes or be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN with all RCS cold leg temperatures less than or equal to 323°F within the following 6 hours.
- 270
- b. The provisions of Specification 3.0.4 may be suspended for up to 18 hours per valve for entry into and during operations in MODE 3 and 4# for the purpose of setting the pressurizer Code safety valves under ambient (hot) conditions provided a preliminary cold setting was made prior to heatup.

SURVEILLANCE REQUIREMENTS

4.4.2.2 No additional requirements other than those required by Specification 4.0.5.

*The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

#When all RCS cold leg temperatures are greater than 323°F.

270

ATTACHMENT C

PROPOSED TECHNICAL SPECIFICATION PAGE

REACTOR COOLANT SYSTEM

OPERATING

LIMITING CONDITION FOR OPERATION

3.4.2.2 All pressurizer Code safety valves shall be OPERABLE with a lift setting of 2485 psig \pm 1%.*

APPLICABILITY: MODES 1, 2, 3 and 4.#

ACTION:

- a. With one pressurizer Code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 15 minutes or be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN with all RCS cold leg temperatures less than or equal to 270°F within the following 6 hours.
- b. The provisions of Specification 3.0.4 may be suspended for up to 18 hours per valve for entry into and during operations in MODE 3 and 4# for the purpose of setting the pressurizer Code safety valves under ambient (hot) conditions provided a preliminary cold setting was made prior to heatup.

SURVEILLANCE REQUIREMENTS

4.4.2.2 No additional requirements other than those required by Specification 4.0.5.

*The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

#When all RCS cold leg temperatures are greater than 270°F.

