

PRIORITY 2

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9508020033 DOC. DATE: 95/07/27 NOTARIZED: NO DOCKET #
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000275
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga 05000323
 AUTH. NAME AUTHOR AFFILIATION
 DYER, J.E. Region 4 (Post 820201)
 RECIP. NAME RECIPIENT AFFILIATION
 RUEGER, G.M. Pacific Gas & Electric Co.

SUBJECT: Forwards insp repts 50-275/95-11 & 50-323/95-11 on
 950514-0624. Non-cited violations which involved failure to
 comply w/maint procedure for maintaining & monitoring freeze
 seal, noted.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5+26
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD4-2 PD	1 1	MILLER, M	1 1
INTERNAL: ACRS	2 2	AEOD/DEIB	1 1
AEOD/SPD/RAB	1 1	AEOD/TTC	1 1
DEDRO	1 1	<u>FILE CENTER</u>	1 1
NRR/DISP/PIPB	1 1	NRR/DORS/OEAB	1 1
NRR/DRCH/HHFB	1 1	NUDOCS-ABSTRACT	1 1
OE DIR	1 1	OGC/HDS3	1 1
RGN4 FILE 01	1 1		
EXTERNAL: LITCO BRYCE, J H	1 1	NOAC	1 1
NRC PDR	1 1		


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 19

F
F
I
C
F
I
T
Y
2
D
O
C
U
M
E
N
T





UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION IV
611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-8064

JUL 27 1995

Pacific Gas and Electric Company
Nuclear Power Generation, B14A
ATTN: Gregory M. Rueger, Senior Vice
President and General Manager
Nuclear Power Generation Bus. Unit
77 Beale Street, Room 1451
P.O. Box 770000
San Francisco, California 94177

SUBJECT: NRC INSPECTION REPORT 50-275/95-11; 50-323/95-11

This refers to the inspection conducted by M. Tschiltz and G. Johnston of this office, and M. Miller of the Office of Nuclear Reactor Regulation, on May 14 through June 24, 1995. The inspection included a review of activities authorized for your Diablo Canyon Nuclear Power Plant, Units 1 and 2, facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress. The results of this inspection are documented on page 1, in the enclosed report.

Three noncited violations are included in this report. The first violation involved the failure to comply with a maintenance procedure for maintaining and monitoring a freeze seal. The second violation was for failing to provide adequate emergency lighting for safe shutdown areas of the plant. The third violation involved a solid state protection system design deficiency, discovered by your staff, which resulted in inadequate electrical separation between safety-related and nonsafety-related circuits. The actions that were taken by your staff to identify and correct this issue are considered to have been noteworthy. Although this deficiency had the potential to be of safety significance, the probability of the initiating event which could have potentially caused the failure was low. These violations are not being cited because the criteria in Paragraphs VII.B.1 or 2 of Appendix C to 10 CFR Part 2 of the NRC's "Rules of Practice," were satisfied. We note that there were several instances in this inspection period which demonstrated weaknesses in human performance. This area warrants further management attention.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room.


9508020033 950727
PDR ADDCK 05000275
Q PDR



Pacific Gas and Electric Company

-2-

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.


J. E. Dyer, Director
Division of Reactor Projects

Dockets: 50-275
50-323
Licenses: DPR-80
DPR-82

Enclosure:
NRC Inspection Report
50-275/95-11; 50-323/95-11

cc w/enclosure:
Sierra Club California
ATTN: Dr. Richard Ferguson
Energy Chair
6715 Rocky Canyon
Creston, California 93432

San Luis Obispo
Mothers for Peace
ATTN: Ms. Nancy Culver
P.O. Box 164
Pismo Beach, California 93448

Ms. Jacquelyn C. Wheeler
P.O. Box 164
Pismo Beach, California 93448

The County Telegram Tribune
ATTN: Managing Editor
1321 Johnson Avenue
P.O. Box 112
San Luis Obispo, California 93406

San Luis Obispo County Board of
Supervisors
ATTN: Chairman
Room 370
County Government Center
San Luis Obispo, California 93408



Pacific Gas and Electric Company

-3-

California Public Utilities Commission
ATTN: Mr. Truman Burns\Mr. Robert Kinosian
505 Van Ness, Rm. 4102
San Francisco, California 94102

Diablo Canyon Independent Safety Committee
Attn: Robert R. Wellington, Esq.
Legal Counsel
857 Cass Street, Suite D
Monterey, California 93940

Radiologic Health Branch
State Department of Health Services
ATTN: Mr. Steve Hsu
P.O. Box 942732
Sacramento, California 94234

State of California
ATTN: Mr. Peter H. Kaufman
Deputy Attorney General
110 West A Street, Suite 700
San Diego, California 92101

Pacific Gas and Electric Company
ATTN: Christopher J. Warner, Esq.
P.O. Box 7442
San Francisco, California 94120

Diablo Canyon Nuclear Power Plant
ATTN: Warren H. Fujimoto, Vice President
and Plant Manager
P.O. Box 56
Avila Beach, California 93424



Pacific Gas and Electric Company

-4-

JUL 27 1995

E-Mail report to D. Sullivan (DJS)
E-Mail report to NRR Event Tracking System (IPAS)

bcc to DMB (IE01)

bcc distrib. by RIV:

L. J. Callan

Resident Inspector

DRSS-FIPB

MIS System

Branch Chief (DRP/E, WCFO)

Senior Project Inspector (DRP/E, WCFO)

RIV File

Branch Chief (DRP/TSS)

Leah Tremper (OC/LFDCB, MS: TWFN 9E10) M. Hammond (PAO, WCFO)

DOCUMENT NAME: R:_DC\DC511rp.MDT

To receive copy of document, indicate in box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

RIV:SRI:DRP\E	C:DRP/E	D:WCFO					
MDTschiltz <i>HJW</i>	HJWong <i>HJW</i>	KEPerkins					
07/26/95	07/26/95	07/26/95					

OFFICIAL RECORD COPY



Pacific Gas and Electric Company

-4-

JUL 27 1995

E-Mail report to D. Sullivan (DJS)

E-Mail report to NRR Event Tracking System (IPAS)

bcc to DMB (IE01)

bcc distrib. by RIV:

L. J. Callan

DRSS-FIPB

Branch Chief (DRP/E, WCFO)

RIV File

Leah Tremper (OC/LFDCB, MS: TWFN 9E10)

Resident Inspector

MIS System

Senior Project Inspector (DRP/E, WCFO)

Branch Chief (DRP/TSS)

M. Hammond (PAO, WCFO)

DOCUMENT NAME: R:_DC\DC511rp.MDT

To receive copy of document, indicate in box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

RIV:SRI:DRP\E	C:DRP/E	D:WCFO				
MDTschiltz <i>HS</i>	HJWong <i>HS</i>	KEPerkins				
07/26/95	07/26/95	07/27/95				

OFFICIAL RECORD COPY

010012

111

