

ENCLOSURE 1


ERRATA CONTAINING REPLACEMENT PAGES FOR
THE THIRD QUARTER 1995
NPDES DISCHARGE MONITORING REPORT FOR
DIABLO CANYON POWER PLANT

Please locate the report listed in the Errata below and replace the incorrect page with the corrected form provided in the enclosure.

ERRATA: Third Quarter 1995 NPDES Discharge Monitoring Report, PG&E Letter DCL-95-229, dated October 19, 1995. A replacement page for the following errata is attached:

- o Q2 form page Q(1) for July 1995 incorrectly lists the "001H Quarterly Oil and Grease" concentration at <1 mg/l. The correct value is <3 mg/l.

9602290028 960222
PDR ADOCK 05000275
R PDR



CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
81 HIGUERA
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 1

FACILITY I.D.	YEAR / MO / DAY		YEAR / MO / DAY		STATE CODE	NPDES PERMIT #		
3 402003001	BEGINNING	95 / 07 / 01	ENDING	95 / 07 / 31	06	CA0003751		
STATION ANALYSIS UNITS SMPLE TYPE FREQ.	INFLUENT T CHROMIUM ug/l GRAB JAJAP/JUL/OCT	INFLUENT COPPER ug/l GRAB JAJAP/JUL/OCT	INFLUENT NICKEL ug/l GRAB JAJAP/JUL/OCT	INFLUENT AMMONIA (N) ug/l GRAB JAJAP/JUL/OCT	EFFLUENT 001 AMMONIA (N) ug/l GRAB JAJAP/JUL/OCT	EFFLUENT 001D OIL & GREASE mg/l GRAB JAJAP/JUL/OCT	EFFLUENT 001G OIL & GREASE mg/l GRAB JAJAP/JUL/OCT	EFFLUENT 001H OIL & GREASE mg/l GRAB JAJAP/JUL/OCT
1								< 3
2								
3								
4	< 5	< 3	< 3					
5								
6								
7						< 3		
8								
9								
10								
11								
12								
13								
14							< 3	
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25				< 41	51			
26								
27								
28								
29								
30								
31								
MONTHLY AVG	< 5	< 3	< 3	< 41	51	< 3	< 3	< 3
MONTHLY HIGH	< 5	< 3	< 3	< 41	51	< 3	< 3	< 3
MONTHLY LOW	< 5	< 3	< 3	< 41	51	< 3	< 3	< 3
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	6M-MEAN 3060 = 0	MO AVG 15 = 0	MO AVG 15 = 0	MO AVG 15 = 0
TIMES EXCEEDED					D MAX 12240 = 0	D MAX 20 = 0	D MAX 20 = 0	D MAX 20 = 0
TIMES EXCEEDED					I MAX 30600 = 0			

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
GREGORY M. RUEGER

RESUBMITTED 2-21-96
PGE LETTER NO. DL-96-045

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Kathleen Rumsey</i>	2-20-96

