

## INDIANA AND MICHIGAN POWER

**D. C. COOK NUCLEAR PLANT** 

Revision: 27.0 Table: 14.1-1 Page: 1 of 2

UPDATED FINAL SAFETY ANALYSIS REPORT

#### Unit 1 Design Power Capability Parameters Used in Non-LOCA Safety Analyses

|                                 | (MUR Power<br>Uprate) <sup>1,2</sup> |        | (Reduced Temperature<br>and Pressure) <sup>1,2</sup> |        | (Rerating) <sup>2</sup> |        | (Return to RCS<br>NOP/NOT) <sup>1</sup> |        |
|---------------------------------|--------------------------------------|--------|------------------------------------------------------|--------|-------------------------|--------|-----------------------------------------|--------|
| Parameter                       | Case 1                               | Case 2 | Case 3                                               | Case 4 | Case 5                  | Case 6 | Case 7                                  | Case 8 |
| NSSS Power, MWt                 | 3,327                                | 3,327  | 3,262                                                | 3,262  | 3,425                   | 3,425  | 3,327                                   | 3,327  |
| Core Power, MWt                 | 3,315                                | 3,315  | 3,250                                                | 3,250  | 3,413                   | 3,413  | 3,315                                   | 3,315  |
| RCS Flow, gpm/loop              | 83,200                               | 83,200 | 83,200                                               | 83,200 | 88,500                  | 88,500 | 83,200                                  | 83,200 |
| Minimum Measured Flow, gpm/loop | 84775                                | 84775  | 84775                                                | 84775  | 91600                   | 91600  | 84,775                                  | 84,775 |
| RCS Temperatures, °F            |                                      |        |                                                      |        |                         |        |                                         |        |
| Core Outlet                     | 593.1                                | 613.6  | 589.7                                                | 611.9  | 583.6                   | 614.0  | 593.1                                   | 613.6  |
| Vessel Outlet                   | 588.2                                | 609.1  | 586.8                                                | 609.1  | 580.7                   | 611.2  | 588.2                                   | 609.1  |

<sup>&</sup>lt;sup>1</sup> The non-LOCA analyses are based on a Thermal Design Flow (TDF) of 83,200 gpm / loop and a Minimum Measured Flow (MMF) of 84,775 gpm / loop. However, subsequent evaluations were performed to show that the following higher flows are also supported: 88,500 gpm / loop (TDF) and 90,725 gpm / loop (MMF).

<sup>&</sup>lt;sup>2</sup>Cook Unit 1 is not licensed to operate at the rerated conditions specified by Cases 5 and 6 with 30% steam generator tube plugging (SGTP) levels. However, several events that were previously performed using these conditions were subsequently evaluated to support the 30% SGTP program. Hence, the rerated conditions are also specified in this table for completeness.



### INDIANA AND MICHIGAN POWER D. C. COOK NUCLEAR PLANT

# Revision:27.0Table:14.1-1Page:2 of 2

### UPDATED FINAL SAFETY ANALYSIS REPORT

### Unit 1 Design Power Capability Parameters Used in Non-LOCA Safety Analyses

|                                         | (MUR Power<br>Uprate) <sup>1,2</sup> |                | (Reduced Temperature<br>and Pressure) <sup>1,2</sup> |                | (Rerating) <sup>2</sup> |                   | (Return to RCS<br>NOP/NOT) <sup>1</sup> |        |
|-----------------------------------------|--------------------------------------|----------------|------------------------------------------------------|----------------|-------------------------|-------------------|-----------------------------------------|--------|
| Parameter                               | Case 1                               | Case 2         | Case 3                                               | Case 4         | Case 5                  | Case 6            | Case 7                                  | Case 8 |
| Core Average                            | 557.6                                | 579.5          | 555.8                                                | 579.4          | 549.7                   | 581.8             | 557.6                                   | 579.5  |
| Vessel Average                          | 553.7                                | 575.4          | 553.0                                                | 576.3          | 547.0                   | 578.7             | 553.7                                   | 575.4  |
| Vessel/Core Inlet                       | 519.2                                | 471.7          | 519.2                                                | 543.5          | 513.3                   | 546.2             | 519.2                                   | 541.7  |
| Steam Generator Outlet                  | 518.9                                | 541.5          | 518.9                                                | 543.2          | 513.1                   | 546.0             | 518.9                                   | 541.5  |
| Zero Load                               | 547.0                                | 547.0          | 547.0                                                | 547.0          | 547.0                   | 547.0             | 547.0                                   | 547.0  |
| RCS Pressure, psia                      | 2,250 or<br>2,100                    | 2,250 or 2,100 | 2,250 or<br>2,100                                    | 2,250 or 2,100 | 2,250 or<br>2,100       | 2,250 or<br>2,100 | 2,250                                   | 2,250  |
| Steam Pressure, psia                    | 618                                  | 765            | 595                                                  | 749            | 603                     | 820               | 618                                     | 765    |
| Steam Flow $(10^6 \text{ lb/hr total})$ | 14.44                                | 14.50          | 14.12                                                | 14.17          | 14.98                   | 15.07             | 14.44                                   | 14.50  |
| Feedwater Temp., °F                     | 437.4                                | 437.4          | 434.8                                                | 434.8          | 442                     | 442               | 437.4                                   | 437.4  |
| SG Tube Plugging, %                     | 30                                   | 30             | 30                                                   | 30             | 10                      | 10                | 30                                      | 30     |