



**INDIANA AND MICHIGAN POWER  
D. C. COOK NUCLEAR PLANT  
UPDATED FINAL SAFETY ANALYSIS REPORT**

Revised: 27.0  
Table:14.3.1-4C  
Page: 1 of 1

**Minimum Safety Injection Pump (HHSI) and Residual Heat Removal Pump (RHR)  
Combined Injection Flow for the Return to NOP/NOT Evaluation**

<b>Pressure (psia)</b>	<b>HHSI and RHR Total Injected Flow at NOP/NOT Conditions (gpm)</b>
15.7	3099
19.7	2997
24.7	2853
29.7	2707
34.7	2561
39.7	2412
54.7	1928
74.7	1465
94.7	1140
114.7	745
134.7	275
154.7	271
174.7	267
194.7	262
214.7	258
234.7	254
254.7	249
274.7	245
294.7	240
314.7	236
414.7	212
514.7	184
614.7	149
714.7	108
814.7	58
914.7	0