CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL COAST REGION
1102A LAUREL LANE
SAN LUIS OBISPO,CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH,CALIF 93424
PAGE (M) 2

FACILITY I.D.	YEAR/ MO / DAY	YEAR/ MO /DAY	STATE CODE	NPDES PERMIT #
3 402003001	BEGINNING 93 / 08 / 01	ENDING 93 / 08 / 31	06	CA0003751

STATION	EFFLUENT 003		EFFLUENT 004		EFFLUENT 001N		EFFLUENT 001P		EFFLUENT 003		EFFLUENT 001F		EFFLUENT 001		EFFLUENT 001	
ANALYSIS	pH		pH		OIL & GREASE		OIL & GREASE		OIL & GREASE		OIL & GREASE		1 CHLOR RES		CHLORINE USED	
UNITS	pH UNITS		pH UNITS		mg/l		mg/l		mg/l		mg/l		ug/l		lbs/day	
SMPL TYPE	GRAB		GRAB		COMPOSITE		GRAB		GRAB		GRAB		GRAB		RECORDED	
FREQ.	MONTHLY		MONTHLY		WEEKLY		WEEKLY (##)		WEEKLY (###)		MONTHLY		2 per CYCLE		MONTHLY	
AUGUST	#		#		#		#		#		#		#		#	
1													12	44		518
2													14	37		662
3		8.0		8.1									14	33		662
4													14	36		662
5						9							14	46		662
6													14	43		662
7													12	38		518
8													12	30		518
9													14	33		662
10													14	33		662
11						8						<3	14	35		662
12													14	52		662
13													14	22		662
14													12	27		518
15													12	24		518
16													14	27		662
17						<3							13	37		588
18													14	40		662
19													6	53		259
20													12	55		518
21													12	38		518
22													12	40		518
23													12	55		518
24						7							14	48		662
25													14	43		662
26													14	47		662
27													14	43		662
28													12	27		518
29													12	21		518
30													12	17		662
31													14	30		662
MONTHLY AVG						7		NO DISCHARGE		NO DISCHARGE				36		595
MONTHLY HIGH						9								55		662
MONTHLY LOW						<3								17		259
TIMES EXCEEDED	NO LIMIT		NO LIMIT		NO AVG 15	=0	NO AVG 15	=0	NO AVG 15	=0	NO AVG 15	=0	1 MAX 200	=0	NO LIMIT	
TIMES EXCEEDED					D MAX 20	=0	D MAX 20	=0	D MAX 20	=0	D MAX 20	=0				
TIMES EXCEEDED																

9403140365 940228
PDR ADOCK 05000275
R PDR

REMARKS: (#) Number of Samples taken during the day.
(##) When 001N is discharging to 001P. (###) When 001P is discharging to 003.

PRINCIPAL EXECUTIVE OFFICER	SIGNATURE OF AUTHORIZED AGENT	DATE
GREGORY M. RUEGER	[signature]	2/25/94

Resubmitted, 2.28.94
PG&E Letter No. DCL-94-043
2.28.94