

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9710080152 DOC.DATE: 97/09/26 NOTARIZED: NO DOCKET #
 FACIL:50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000275
 AUTH.NAME . AUTHOR AFFILIATION
 POWERS,R.P. Pacific Gas & Electric Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 97-013-01 re TS 3.6.1.1, "Containment Integrity," not met due to misinterpretation of containment isolation valve surveillance requirements for certain test, vent & drain valves.Addl instances also included.

DISTRIBUTION CODE: IE22T COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1+12
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD4-2 PD	1 1	BLOOM,S	1 1
INTERNAL:	ACRS	1 1	AEOD/SPD/RAB	2 2
	AEOD/SPD/RRAB	1 1	FILE CENTER	1 1
	NRR/DE/ECGB	1 1	NRR/DE/EETB	1 1
	NRR/DE/EMEB	1 1	NRR/DRCH/HHFB	1 1
	NRR/DRCH/HICB	1 1	NRR/DRCH/HOLB	1 1
	NRR/DRCH/HQMB	1 1	NRR/DRPM/PECB	1 1
	NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
	RES/DET/EIB	1 1	RGN4 FILE 01	1 1
EXTERNAL:	L ST LOBBY WARD	1 1	LITCO BRYCE,J H	1 1
	NOAC POORE,W.	1 1	NOAC QUEENER,DS	1 1
	NRC PDR	1 1	NUDOCS FULL TXT	1 1

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED
 TOTAL NUMBER OF COPIES REQUIRED: LTR 25 ENCL 25



Pacific Gas and Electric Company

Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, CA 93424
805/545-6000

Robert P. Powers
Vice President—Diablo Canyon
Operations and Plant Manager

September 26, 1997

PG&E Letter DCL-97-162



U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 1 and 2

Licensee Event Report 1-97-013-01

Technical Specification 3.6.1.1 Not Met Due to Misinterpretation of
Containment Isolation Valve Surveillance Requirements for Certain Test,
Vent, and Drain Valves

Dear Commissioners and Staff:

Pursuant to 10 CFR 50.73(a)(2)(i)(B), PG&E is submitting the enclosed revision to Licensee Event Report (LER) 1-97-013 regarding Technical Specification 3.6.1.1, "Containment Integrity," not met due to misinterpretation of containment isolation valve surveillance requirements for certain test, vent, and drain valves. This revision reports additional instances of the missed surveillance found during visual inspections inside of containment after the original LER was submitted.

This event did not adversely affect the health and safety of the public.

Sincerely,


Robert P. Powers

cc: Donald B. Allen
Steven D. Bloom
Ellis W. Merschoff
Kenneth E. Perkins
Diablo Distribution
INPO

11
Ie22

010095

Enclosure

DPS/2246/ N0002036



9710080152 970926
PDR ADOCK 05000275
S PDR

