

CATEGORY 2

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9806260241 DOC.DATE: 98/06/22 NOTARIZED: NO DOCKET #
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000275
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga 05000323
 AUTH.NAME AUTHOR AFFILIATION
 WONG, H.J. Region 4 (Post 820201)
 RECIP.NAME RECIPIENT AFFILIATION
 RUEGER, G.M. Pacific Gas & Electric Co.

SUBJECT: Ack receipt of 980522 ltr informing NRC of steps taken to
 correct violations noted in insp repts 50-275/98-07 &
 50-323/98-07. Implementation of corrective actions will be
 reviewed during future insp.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3
 TITLE: General (50 Dkt) - Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD4-2	PD	1	1		BLOOM, S		1	1
INTERNAL:	ACRS		2	2		AEOD/SPD/RAB		1	1
	AEOD/TTC		1	1		DEDRO		1	1
	FILE CENTER		1	1		NRR/DRCH/HHFB		1	1
	NRR/DRPM/PECB		1	1		NRR/DRPM/PERB		1	1
	NUDOCS-ABSTRACT		1	1		OE DIR		1	1
	OGC/HDS3		1	1		RGN4 FILE 01		1	1
EXTERNAL:	LITCO	BRYCE, J H	1	1		NOAC		1	1
	NRC	PDR	1	1		NUDOCS FULLTEXT		1	1

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 19 ENCL 3

C
A
T
E
G
O
R
Y
2
D
O
C
U
M
E
N
T





UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION IV

611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-8064


June 22, 1998

Gregory M. Rueger, Senior Vice President
and General Manager
Nuclear Power Generation Bus. Unit
Pacific Gas and Electric Company
Nuclear Power Generation, B14A
77 Beale Street, Room 1451
P.O. Box 770000
San Francisco, California 94177

SUBJECT: NRC INSPECTION REPORT 50-275/323-98-007

Thank you for your letter of May 22, 1998, in response to our April 22, 1998, letter and Notice of Violation concerning: (1) failure to provide a procedure that assured proper stowage of a hoist, (2) failure to implement refueling procedures, in that the source range monitor high flux alarm was not restored, (3) multiple failures to properly implement the clearance procedure, and (4) failure to translate design information into the shutdown abnormal operating procedures. We have reviewed your reply and find it responsive to the concerns raised in our Notice of Violation. We will review the implementation of your corrective actions during a future inspection to determine that full compliance has been achieved and will be maintained.

Sincerely,


H. J. Wong, Chief
Reactor Projects Branch E

250042

Docket Nos.: 50-275
50-323
License Nos.: DPR-80
DPR-82

cc:
Dr. Richard Ferguson
Energy Chair
Sierra Club California
1100 11th Street, Suite 311
Sacramento, California 95814

9806260241 980622
PDR ADDCK 05000275
G PDR

101



Pacific Gas and Electric Company

-2-

Ms. Nancy Culver
San Luis Obispo Mothers for Peace
P.O. Box 164
Pismo Beach, California 93448

Chairman
San Luis Obispo County Board of
Supervisors
Room 370
County Government Center
San Luis Obispo, California 93408

Mr. Truman Burns\Mr. Robert Kinosian
California Public Utilities Commission
505 Van Ness, Rm. 4102
San Francisco, California 94102


Robert R. Wellington, Esq.
Legal Counsel
Diablo Canyon Independent Safety Committee
857 Cass Street, Suite D
Monterey, California 93940

Mr. Steve Hsu
Radiologic Health Branch
State Department of Health Services
P.O. Box 942732
Sacramento, California 94234

Christopher J. Warner, Esq.
Pacific Gas and Electric Company
P.O. Box 7442
San Francisco, California 94120

Robert P. Powers, Vice President
and Plant Manager
Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, California 93424

Managing Editor
Telegram-Tribune
1321 Johnson Avenue
P.O. Box 112
San Luis Obispo, California 93406



bcc to DCD (IE01)

bcc distrib. by RIV:

Regional Administrator
 DRP Director
 Branch Chief (DRP/E, WCFO)
 Senior Project Inspector (DRP/E, WCFO)
 Branch Chief (DRP/TSS)
 WCFO File

Resident Inspector
 DRS-PSB
 MIS System
 RIV File

DOCUMENT NAME: R:_DC\DC807AK.DLP

To receive copy of document, indicate in box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

RIV:SRI:DRP/E	C:DRP/E	<i>SC</i>					
DLProulx <i>HSW for</i>	HJWong <i>HJW</i>						
06/1/98	06/1/98						

Per C-17-11

OFFICIAL RECORD COPY

