



INDIANA AND MICHIGAN POWER  
 D. C. COOK NUCLEAR PLANT  
 UPDATED FINAL SAFETY ANALYSIS  
 REPORT

Revision: 17.1

Table: 14.3.4-35

Page: 1 of 1

**ICE CONDENSER AZIMUTHAL DIFFERENTIAL PRESSURE DISTRIBUTION**

TMD BREAK LOCATION ELEMENTS						
	1	2	3	4	5	6
<b>Ice Condenser</b>	Bays 1 thru 2.75	Bays 2.75 thru 6	Bays 7 thru 12.5	Bays 12.5 thru 17	Bays 18 thru 20.5	Bays 20.5 thru 24
<b>Elements</b>	9	12	15	18	21	24
Pressure	7.4 psid	6.1 psid	5.5 psid	5.5 psid	6.1 psid	7.4 psid
<b>Elements</b>	8	11	14	17	20	23
Pressure	9.2 psid	7.6 psid	6.8 psid	6.8 psid	7.5 psid	9.2 psid
<b>Elements</b>	7	10	13	16	19	22
Pressure	11.8 psid	9.8 psid	8.7 psid	8.7 psid	9.7 psid	11.8 psid
<b>Elements</b>	40	41	42	43	44	45
Pressure	14.8 psid	12.6 psid	11.2 psid	11.2 psid	12.4 psid	14.5 psid