



INDIANA AND MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22
Table: 14.3.9-4
Page: 1 of 1

DEGB COATINGS DEBRIS GENERATED WITHIN ZOI

Coating Type	Area, ft ²	Thickness, mils	Volume, ft ³	Density, lbs/ft ³	Weight, lbs
Qualified Coatings – Concrete Surfaces (ZOI – 5D)	894	12	0.894	111.6	99.8
Qualified Coatings – Steel Surfaces (ZOI – 5D)	1,007	12	1.007	111.6	112.7
Total Qualified (ZOI – 5D)	1,901	-	1.90	-	212.5
Unqualified Alkyd Coatings (ZOI – 10D)	57.7	4	0.019	98	1.9
Unqualified Epoxy Coatings (ZOI – 10D)	112.0	4	0.037	94	3.5
Total Unqualified (ZOI – 10D)	169.7	-	0.056	-	5.4