

**VUEZ CHEMICAL EFFECTS TESTING
NON-SUBMERGED MATERIAL QUANTITIES**

Material	Source	Quantity
Metallic Aluminum	HVAC Equipment	8,013.4 ft ²
Galvanized Steel, Cold Zinc Coated Steel	Structural Material	504,729 ft ²
Carbon Steel	Structural Material	32,666.2 ft ²
Copper	Wires, Tubing, HVAC Equipment	39,735.24 ft ²
Concrete	Containment Structure	1,077.1 ft ²
Grease ¹	Lubricant	420.9 ft ²

¹ 0.175 ft³ spread over the 420 ft² area.