

	INDIANA AND MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT	Revision: 24.0 Table: 14.3.1-4A Page: 1 of 1
---	---	---

Minimum HHSI and RHR Combined Injection Flow

Pressure (psia)	HHSI + RHR Total Injected Flow (gpm)
14.7	3,146.4
34.7	2,483.0
54.7	1,746.9
74.7	1,427.1
94.7	1,062.6
114.7	616.1
134.7	242.7
154.7	239.5
174.7	236.3
194.7	233.0
214.7	229.7
234.7	226.4
254.7	223.0
274.7	219.6
294.7	216.2
314.7	212.7