

**WEST STEAM ENCLOSURE STEAMLINER BREAK - BACKFLOW  
(PRESSURE RESPONSE)**

<b>Time (sec)</b>	<b>Mass Flow 10<sup>3</sup> lb/sec</b>	<b>Energy Release 10<sup>6</sup> Btu/sec</b>
0.0	7.54	8.99
0.1	5.09	6.07
0.2	4.61	5.50
0.3	4.41	5.26
0.4	4.30	5.13
0.5	4.58	5.46
0.6	4.97	5.92
0.7	5.09	6.07
0.8	5.11	6.09
0.9	5.13	6.11
1.0	5.07	6.04
1.5	5.29	6.31
2.0	5.11	6.10
2.5	4.96	5.91
3.0	4.93	5.88
3.5	4.81	5.77
4.0	4.68	5.58
4.5	4.59	5.47
5.0	4.53	5.40
5.5	4.65	5.16
6.0	5.28	5.17
6.5	5.90	5.55
7.0	6.46	5.78
7.5	6.88	5.93

	<p style="text-align: center;">INDIANA AND MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p>	<p>Revision: 16.6 Table: 14.4.6-6c Page: 2 of 2</p>
---	---	---

**WEST STEAM ENCLOSURE STEAMLINER BREAK - BACKFLOW  
(PRESSURE RESPONSE)**

Time (sec)	Mass Flow $10^3$ lb/sec	Energy Release $10^6$ Btu/sec
8.0	7.32	6.10
8.5	7.79	6.32
9.0	8.23	6.53
9.5	8.61	6.72
10.0	8.92	6.88