

## INDIANA AND MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 16.6

Table: 14.4.6-15

Page: 1 of 1

## PRESSURE CAPABILITY OF WALLS & SLABS AROUND MAIN STEAM LINE ENCLOSURE EAST OF CONTAINMENT

## 1. MATERIAL PROPERTIES

- a. Concrete  $f_c' = 3500 \text{ psi}$ ;
- b. Reinforcing steel f<sub>v</sub>= 40000 psi

## 2. PRESSURE CAPABILITIES TABULATED

- a. Are ultimate values under static conditions;
- b. Do not include any other loading condition

Panel ID	Thickness (in.)	Pressure Capability (psi)	Remarks
E-SL2	12	11.6	Punching Shear Around Col. Governs
E-SL3	30	72.5 1	
E-WN1	24	16.1 (1)	
E-WN2	24	80.0 (1)	
E-WS1	24	16.0 (1)	
E-WS2	24	83.2 (1)	
E-W1	24	13.4 (1)	
E-W2	24	78.0 <sup>(1)</sup>	
E-W3	24	11.6 (1)	E-W3 & E-W4, both curved are solved using planar projections
E-W4	24	4.5	Critical Value of 4.5 PSI. Results from 1 way action of lightly reinforced portion of panel between the two large openings. The side portions of the panel have capability of 86.1 (1)

See Figure 14.4.6-3 for wall and slab identification.

UNIT 2

<sup>&</sup>lt;sup>1</sup> Indicates diagonal tension failure governs.