

	INDIANA AND MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT	Revision: 16.6 Table: 14.4.6-19 Page: 1 of 1
---	---	---

**PANELS TO BE PROTECTED FROM MAIN STEAM LINE LONGITUDINAL
BREAKS**

Longitudinal Breaks	Panels To Be Protected	Remarks
1F	E-SL1, E-WN1, E-WS1	
4F	E-SL2, E-WN1, E-WS1	
1G	E-SL2, E-W1	
4G	E-SL2, E-W1	
2E	W-WS2, W-SL1, W-WN1	
3E	W-WS2, W-SL1, W-WN1	
2D	W-SL1, W-W4	
3D	W-SL1, W-W4	