



Three Mile Island Unit 1
Route 441 South, P.O. Box 480
Middletown, PA 17057
Telephone 717-948-8000

TMI-16-102
December 22, 2016

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Three Mile Island Nuclear Station, Unit 1
Renewed Facility Operating License No. DPR-50
NRC Docket No. 50-289

Subject: Supplemental Information – TMI-1 Steam Generator Tube Inspection Report for Refueling Outage T1R21

Reference: Exelon Generation Company, LLC Letter to USNRC TMI-1 Steam Generator Tube Inspection Report for Refueling Outage T1R21, dated May 21, 2016 (TMI-16-015)

In the above reference, Exelon Generation Company, LLC (EGC) provided a report on the completed examination of tubing in the TMI-1 steam generators during Refueling Outage T1R21. An issue was discovered during a subsequent review of the report, determined to be a typographical error. The typographical error occurred when a table was re-created from the original vendor's report.

The total number of plugged tubes was correctly reported. The breakdown by wear mechanism was incorrectly reported for the "B" steam generator.

The attached is a corrected page 13 of 226 for the referenced report. The correction pertains to the table on page 13 titled "Table 3: TMI-1 Tube Plugging History" and under the "TSP wear" and "TTW" columns for "SGB Plug History"; the summation "Total (Tubes)" row should read 192 for "TSP wear" instead of the original report listing of 195, and the summation "Total (Tubes)" row should read 3 for "TTW" instead of the original report listing of 0 (zero). All other information in the table is correct.

No new regulatory commitments are established by this submittal. If you have any questions or additional information is needed, please contact Mike Fitzwater at 717-948-8228.

Respectfully,

Edward W. Callan
Site Vice President, Three Mile Island Unit 1
Exelon Generation Company, LLC

cc: NRC Regional Administrator - Region I
NRC Senior Resident Inspector – Three Mile Island Nuclear Station
NRC Project Manager, NRR – Three Mile Island Nuclear Station
R. R. Janati, Chief, Division of Nuclear Safety, Pennsylvania Department of Environmental Protection, Bureau of Radiation Protection

IEO1
NRR

Attachment

TMI-1 Steam Generator Tube Inspection Report for Refueling Outage T1R21 –
Corrected Attachment 1, Page 13 of 226

TMI-16-015

(TS 6.9.6.e.) Number of tubes plugged during the inspection outage for each degradation mechanism:

A total of one hundred thirty-four (134) tubes were plugged and stabilized during T1R21. Three (3) tubes in SG 'A' were preventatively plugged based on engineering judgment due to growth rates and number of indications. One hundred thirty-one (131) tubes in SG 'B' were plugged for TSP wear. Twenty-five (25) of these tubes required plugging based on having indications at or above the Technical Specification limit of 40% Through Wall (TW). The other 106 tubes were preventatively plugged – the majority of these were in the "W-Axis" region of the periphery (Rows 1-4). There were no tubes plugged in either SG due to the TTW degradation mechanism.

(TS 6.9.6.f.) The number and percentage of tubes plugged to date, and the effective plugging percentage in each steam generator:

There were no tubes plugged prior to T1R19. Table 3 shows the number of tubes plugged during each of the three steam generator inspections and the cumulative number of tubes plugged to date.

Table 3: TMI-1 Tube Plugging History

Outage	SGA Plug History				SGB Plug History				Total Plugged
	TSP Wear	TTW	Other	SGA Total Plugged	TSP Wear	TTW	Other	SGB Total Plugged	
PSI	0	0	0	0	0	0	0	0	0
T1R19	0	4	0	4	30	3	0	33	37
T1R20	1	0	0	1	31	0	0	31	32
T1R21	3	0	0	3	131	0	0	131	134
Total (Tubes)	4	4	0	8	192	3	0	195	203
Total (%)	0.051%				1.25%				0.65%
Limit (%)	5.00%				5.00%				5.00%
Limit (Tubes)	779				779				1558

Note: There are 15,597 tubes per Steam Generator.

There are no sleeves or repairs other than plugs with stabilizers installed in the steam generators. The effective plugging percentage is the same as the actual plugged tube percentage. Following T1R21, the effective plugging percentage for SG 'A' is 0.051% and for SG 'B' 1.25%.