

| Table 2.7.2-2 Inspections, Tests, Analyses, and Acceptance Criteria | | | | |
|--|-----------|--|---|--|
| No. | ITAAC No. | Design Commitment | Inspections, Tests, Analyses | Acceptance Criteria |
| 705 | 2.7.02.04 | 4. Controls exist in the MCR to cause the components identified in Table 2.7.2-1 to perform the listed function. | Testing will be performed on the components in Table 2.7.2-1 using controls in the MCR. | Controls in the MCR operate to cause the components listed in Table 2.7.2-1 to perform the listed functions. |
| 706 | 2.7.02.05 | 5. Displays of the parameters identified in Table 2.7.2-1 can be retrieved in the MCR. | Inspection will be performed for retrievability of parameters in the MCR. | The displays identified in Table 2.7.2-1 can be retrieved in the MCR. |

| Table 2.7.2-3 | | |
|---------------------------|------------|--------------------|
| Component Name | Tag No. | Component Location |
| Water Chiller Pump A | VWS-MP-01A | Turbine Building |
| Water Chiller Pump B | VWS-MP-01B | Turbine Building |
| Air Cooled Chiller Pump 2 | VWS-MP-02 | Auxiliary Building |
| Air Cooled Chiller Pump 3 | VWS-MP-03 | Annex Building |
| Water Chiller A | VWS-MS-01A | Turbine Building |
| Water Chiller B | VWS-MS-01B | Turbine Building |
| Air Cooled Chiller 2 | VWS-MS-02 | Auxiliary Building |
| Air Cooled Chiller 3 | VWS-MS-03 | Auxiliary Building |