



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 3, 2017

Mr. Marty L. Richey, Site Vice President
FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
Mail Stop A-BV-SEB1
P.O. Box 4, Route 168
Shippingport, PA 15077

SUBJECT: BEAVER VALLEY POWER STATION, UNIT NOS. 1 AND 2 – REQUEST FOR
ADDITIONAL INFORMATION REGARDING RELIEF REQUEST NUMBERS
PR6 AND PR7 (CAC NOS. MF8340, MF8341, MF8342, AND MF8343)

Dear Mr. Richey:

By letter dated August 31, 2016 (Agencywide Documents Access and Management System Accession No. ML16245A320), FirstEnergy Nuclear Operating Company submitted 28 proposed alternatives and relief requests for the Beaver Valley Power Station, Unit Nos. 1 and 2 (BVPS-1 and BVPS-2). The relief requests are associated with the fifth and fourth 10-year intervals of inservice testing program for pumps and valves for BVPS-1 and BVPS-2, respectively. As a part of the submittal, the U.S. Nuclear Regulatory Commission (NRC) staff noted the licensee requests that the BVPS-2 fourth 10-year interval coincide with the BVPS-1 fifth 10-year interval. The NRC staff requests a response to the enclosed questions to complete its review regarding Relief Request Numbers PR6 and PR7.

The draft questions were sent to Mr. Phil Lashley of your staff to ensure that the questions were understandable, the regulatory basis for the questions was clear, and to determine if the information was previously docketed. Please respond to the enclosed questions within 30 days of the date of this letter.

If you have any questions regarding this matter, please contact me at 301-415-7128 or Taylor.Lamb@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Taylor A. Lamb".

Taylor A. Lamb, Project Manager
Plant Licensing Branch I
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

Enclosure:
Request for Additional Information

cc w/encl: Distribution via Listserv

REQUEST FOR ADDITIONAL INFORMATION
RELIEF REQUEST NUMBERS PR6 AND PR7
FOR THE FOURTH AND FIFTH 10-YEAR INSERVICE TESTING INTERVALS
FIRSTENERGY NUCLEAR OPERATING COMPANY
BEAVER VALLEY POWER STATION, UNIT NOS. 1 AND 2
DOCKET NOS. 50-334 AND 50-412

By letter dated August 31, 2016 (Agencywide Documents Access and Management System Accession No. ML16245A320), FirstEnergy Nuclear Operating Company submitted 28 proposed alternatives and relief requests for the Beaver Valley Power Station, Unit Nos. 1 and 2 (BVPS-1 and BVPS-2). The relief requests are associated with the fifth and fourth 10-year intervals of inservice testing program for pumps and valves for BVPS-1 and BVPS-2, respectively. As a part of the licensee's submittal, the staff notes that they requested that the BVPS-2 fourth 10-year interval coincide with BVPS-1 fifth 10-year interval.

The NRC staff has reviewed and evaluated the information provided by the licensee and has determined that the following information is needed in order to complete its review of the relief requests.

Request for Additional Information PR6-1:

In Section 3, "Applicable Code Requirement," of the submittal, Table ISTB-3000-1, "Inservice Test Parameters," identifies flow rate as a test parameter, and Note 1 of the table states, in part, "... differential pressure or flow rate shall be measured or determined." Note 1 in Table ISTB-3000-1 is applicable to Group B tests. The boric acid transfer pumps are Group A pumps. Explain why Note 1 is referenced in Section 3, if it is not applicable to Group A pumps.

Request for Additional Information PR6-2:

Section 6, "Proposed Alternative and Basis for Use," of the submittal states, "separate vibration reference and acceptance criteria values will be used for the different test conditions of the recirculation and full flow tests." Please provide the vibration reference and acceptance criteria values.

Request for Additional Information PR7-1:

In Section 1, "ASME Code Components Affected," of the submittal, the residual heat removal pumps are listed as ASME Class 2 pumps. In Alternative Request Number PR8, the residual heat removal pumps are listed as ASME Class 3 pumps. Please state which classification is correct.

SUBJECT: BEAVER VALLEY POWER STATION, UNIT NOS. 1 AND 2 – REQUEST FOR ADDITIONAL INFORMATION REGARDING RELIEF REQUEST NUMBERS PR6 AND PR7 (CAC NOS. MF8340, MF8341, MF8342, AND MF8343)

DISTRIBUTION:

Public
LPL1 R/F
RidsRgn1MailCenter Resource
RidsACRS_MailCTR Resource
RidsNrrDorlLpl1 Resource
RidsNrrPMBeaverValley Resource
RidsNrrLALRonewicz Resource
RidsNrrDeEpn Resource
RWolfgang, NRR

ADAMS Accession Number: ML17031A036

*by e-mail dated

OFFICE	DORL/LPL1/PM	DORL/LPL1/LA	DE/EPNB/BC*	DORL/LPL1/BC	DORL/LPL1/PM
NAME	TLamb	LRonewicz	DAley	SKoenick	TLamb
DATE	2/02/2017	2/02/2017	1/25/2017	2/02/2017	2/03/2017

OFFICIAL RECORD COPY