

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
631 PARK AVENUE  
KING OF PRUSSIA, PENNSYLVANIA 19406

*DR Central Files*

DEC 18 1975

Niagara Mohawk Power Corporation  
Attention: Mr. R. R. Schneider  
Vice President  
Electric Operations  
300 Erie Boulevard West  
Syracuse, New York 13202

License No. DPR-63  
Inspection No. 75-19  
Docket No. 50-220


Reference: Your letter dated November 12, 1975  
In response to our letter dated October 23, 1975

Gentlemen:

Thank you for informing us of the corrective and preventive actions you documented in response to our correspondence. These actions will be examined during a subsequent inspection of your licensed program.

Your cooperation with us is appreciated.

Sincerely,


  
Eldon J. Brunner, Chief  
Reactor Operations and  
Nuclear Support Branch

cc: T. E. Lempges, General Superintendent, Nuclear Generation  
T. J. Perkins, Plant Superintendent  
C. L. Stuart, Operations Supervisor  
E. B. Thomas, Jr., Esquire  
A. Z. Roisman, Counsel for Citizens Committee for  
Protection of the Environment

bcc:-  
IE Mail & Files (For Appropriate Distribution)  
PDR  
Local PDR  
NSIC  
TIC  
REG:I Reading Room  
State of New York



*gph*



NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST  
SYRACUSE, N. Y. 13202

November 12, 1975

Mr. Eldon J. Brunner, Chief  
Reactor Operations Branch  
United States Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, Pa. 19406

RE: Docket No. 50-220  
Inspection Report 75-19

Dear Mr. Brunner:

Following a thorough review of Inspection Report No. 75-19, conducted by Mr. J.T. Shedlosky of your office on September 22-26, 1975 at the Nine Mile Point Nuclear Station Unit #1, we have concluded that the report may be placed in the NRC's Public Document Room in accordance with Section 2.790, Part 2 Title 10 CFR. Concerning the surveillance test data and evaluations of control rod drive performance, the following is submitted:

June 29-30, 1974


The Technical Specifications, Appendix A, in effect at this time, require a maximum scram insertion time no greater than: a) 90%-5.30 sec.; b) 50%-2.17 sec. and c) 10%-.74 sec. time for 50% insertion. No control rod within a nine rod array was: a) in excess of the scram insertion limits; b) operating with a malfunction accumulation; or c) valved out-of-service in a non-fully inserted position. Thus compliance with the specification following this evaluation was achieved.

October 13, 1974

Enclosed are the initial and revised scram insertion time sheets for this event. Unfortunately, the revised sheet was not placed in the scram time book. All control rod scram times meet the criteria.

December 21, 1974

There appears to be an inconsistency between the data presented in the inspection report and the data available at the plant. Enclosed is a requested copy of the rod scram time data, however, as can readily be seen, there is no correlation between the report and the data.



February 11, 1975

The evaluation indicated that the particular control rod, 34-51, was a unique problem involving either the method of scram recording, or a problem with the insert and withdraw valves. As a precaution, the control rod was inserted to 00 and valved out of service. Repairs were made to the insert valve allowing full operation of the control rod.

Procedures will be established by December 15, 1975 regarding control rod scram time testing. These procedures will include documented evaluations, where required, and incorporate the existing Technical Specification regarding scram times and evaluations.

Concerning the Alleged Deficiency

The Administrative Procedure, AP-16A, has been implemented. This was completed on September 26, 1975. The Plant Superintendent and the Operation's Supervisor have been informed as to the method of implementing an Administrative Procedure when it supersedes a Standing Order.

Very truly yours,



R.R. Schneider  
Vice President  
Electric Operations

Enc.

TJD/nmm

1

