



PRC  
APERTURE  
CARD

NOTES:  
1. ALL EQUIPMENT LOCATED AT SWGR  
UNLESS OTHERWISE NOTED  
2. CELL SWITCH CLOSED IN TEST AND WITHDRAWN POSN

520C-	52-AUX CONTACTS									
Y10	Y15	Y17	Y19	Y21	Y23	Y25	Y27	Y29	Y31	
Y11	Y12	Y18	Y20	Y22	Y24	Y26	Y28	Y30	Y32	
SP	ALM NO 3734	CKT-2EJSX06 ESK-6EJS02	COMPUTER ESK-7EJS02	SPARE	CKT-2EJSX06 ESK-6EJS02	SPARE				

- 74-
- 1 | 2 ESK-7EJS03 CKT. 2EJSX09
  - 3 | 4 COIL CLEARING CONTACT
  - 5 | 6 INOP. ESK-7EJS01
  - 7 | 8 SP

CS	DETAIL	ESK	SPARES
1-	D	3A	2, 4, 7, 8, 9, 10
NO CHANGE DESIGN CONTROL ISSUE			
M 11/20/72	M 1/22/73	M 6/26/73	M 2-27-74
G ECH-001	S SPC 1/14/73	M SPC 1/14/73	M 2-27-74
		JRM	JWC

NUCLEAR SAFETY RELATED  
QA CAT I

DC ELEM DIAG-600V SWGR CKT  
UNIT SUB 2EJS\*USI SUPPLY BREAKER  
NINE MILE POINT NUCLEAR STATION UNIT-2  
NIAGARA MOHAWK POWER CORPORATION

STONB & WEBSTER ENGINEERING CORPORATION

12177-ESK-6EJS01

D