

49X-

1 2 THIS DWG
3 4 THIS DWG
5 6 SPARE
7 8 THIS DWG

3-2CCPN03

3 4 SPARE
5 6 ESK-7CCP03

74-2CCPN03

7 8
3 4 ALARM NO. 4287

49X-2CCPN03

420-

4 5 THIS DWG
9
13 14 SPARE
15 16
NOT WIRED OUT

42C-

7 8 THIS DWG
6
17 18 SPARE
19 20
NOT WIRED OUT

74-

5 6 INOP ESK-7CCP03
3 4 INOP ESK-7CCP05
7 8 THIS DWG
1 2 SPARE

LIMIT SWITCH DEVELOPMENT

TOP		33 VALVE POSITION (FULL OPEN, 5%, 95%, FULL CLOSED)	FUNCTION
	1		2CCP*MOV265
	2		ESK-7DR501 SPARE
1	3		GREEN LT
	4		OPEN LIMIT
	5		BYPASS
2	6		SPARE
	7		RED LT
	8		ESK-7SC132
	9		SPARE
3	10		SPARE
	11		ESK-7SC132
	12		SPARE
	13		
	14		
4	15		BYPASS
	16		SPARE
TORQUE SW	17	CLOSING TORQUE SW INTERRUPTS CLOSING CYCLE IF MECHANICAL OVERLOAD OCCURS DURING CLOSING CYCLE	
	18	OPENING TORQUE SW INTERRUPTS OPENING CYCLE IF MECHANICAL OVERLOAD OCCURS DURING OPENING CYCLE	

GE-NED ✓ GE-LSTG

4-2CCP & 3-2CCP

PRC APERTURE CARD

NOTES:
1. VALVE LIMIT SWITCHES LOCATED ON VALVE ACTUATOR. ALL OTHER EQUIPMENT LOCATED AT MCC UNLESS OTHERWISE NOTED.
2. LOGIC DIAGRAM LSK-9-1.

CS	DETAIL	ESK	SPARES	USED ON
1-2CCPN03	H5	3B	1B, 1T	—

NUCLEAR SAFETY RELATED
QA CAT I

AC ELEM DIAG-600V MCC CKT
CL LOOP CLG WTR DRYWELL CLR ISOL V
NINE MILE POINT NUCLEAR STATION-UNIT 2
NIAGARA MOHAWK POWER CORPORATION
PGCC
STONE & WEBSTER ENGINEERING CORPORATION

	DESIGN CONTROL ISSUE 2	DESIGN CONTROL ISSUE
6		
5		
4	M 4/28/82 ECN-001, 003, 004, 005	M 3
3		M 2
2		1
1		

12177-ESK-6CCP18

RK

D