
125 VDC DIV I (GREEN) FROM MCC
F1-(+)
P00
F1-(-)
N00
720-
4 5 THIS DWG
9
13 14 SPARE
15 16
72C-
7 8 THIS DWG
6
17 18 SPARE
19 20
72X-
7 8 THIS DWG
5 6 GE 807E173TY, SH. 12A ALM NO. 0241
3 4 COIL CLRNG CONTACT
1 2 THIS DWG
74-
7 8 GE 807E173TY, SH. 11A INOP IND
5 6 GE 807E173TY, SH. 11 ALM NO. 0235
3 4 COIL CLEARING CONTACT
1 2 SPARE
72-0L1
72-0L2
33
TQS O
TQS C
E51-F068
S03
S04
S01
S00
SC3
SC2
SC1
SC0
P405
P621
P601
SW5-2RSSN84
S3-CR2940
K2-GP 1T
SW25-
T1 P405 3X13-M1 2RSSN07 ESK-11RSS07
T3 P405 3X1-M3 2RSSN07 ESK-11RSS07
72X-J13
74-J13
L1
L2
72 C-
72 O-
72X-
72-
COO
CO1
ROO
GOO
R
G
NO1
LIMIT SWITCH DEVELOPMENT
ROTOR
33
VALVE POSITION
FULL OPEN
5%
95%
FULL CLOSED
FUNCTION
1 SPARE
2 GE 807E173TY, SH. 4
3 GREEN LT
4 OPEN LIMIT
5 (ESK-11RSS03)
6 GE 807E173TY, SH. 5
7 RED LT
8 (ESK-11RSS08)
9 SPARE
10
11 BYPASS
12 SPARE
13
14
15 BYPASS
16 SPARE
TORQUE SW
17 CLOSING TORQUE SWITCH INTERRUPTS CLOSING CIRCUIT IF MECHANICAL OVERLOAD OCCURS DURING CLOSING CYCLE
18 OPENING TORQUE SWITCH INTERRUPTS CLOSING CIRCUIT IF MECHANICAL OVERLOAD OCCURS DURING CLOSING CYCLE
GE NED
GE LSTG
RCIC STEAM VALVE TO TURBINE MOV 2ICS*MOV120
(G.E. NO. E51-F045) MCC 2DMS* MCCA1
CKT NO. 2ICSN03 (GREEN)
CONTROL ELEMENTS
S3
K2
REF G.E. DWGS.
807E173TY, SH.8
807E173TY, SH.8
CS
SW25-2ICSN03
SW5-2RSSN84
DETAIL
BG1
BE
ESK
3L
3K
SPARES USED ON
2-2T, 4-4T
NOTES:
1. VALVE LIMIT SWITCHES LOCATED ON VALVE ACTUATOR. ALL OTHER EQUIPMENT LOCATED AT MCC UNLESS OTHERWISE NOTED.
2. APPLICABLE G.E. ELEMENTARY: 807E173TY
3. ☒ INDICATES PNL. P405 TERMINATION
NUCLEAR SAFETY RELATED
QA CAT I
DESIGN CONTROL ISSUE 2
REDRAWN
DESIGN CONTROL ISSUE
M 10/8/92 ECN-005
2
3
DC ELEM DIAG-125V
RCIC STEAM VALVE TO TURBINE
NINE MILE POINT NUCLEAR STATION-UNIT 2
NIAGARA MOHAWK POWER CORPORATION
STONE & WEBSTER ENGINEERING CORPORATION
12177-ESK-11ICS01
RK/RD
PRC APERTURE CARD