

DISTRIBUTION AFTER ISSUANCE OF OPERATING LICENSE

NRC FORM 195
(2-76)

U.S. NUCLEAR REGULATORY COMMISSION

DOCKET NUMBER

50-220

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:
Mr. George Lear

FROM:
Niagara Mohawk Power Corp.
Syracuse, New York
Donald P. Dise

DATE OF DOCUMENT
12/16/77

DATE RECEIVED
12/19/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1516ND

DESCRIPTION

ENCLOSURE

Consists of info. concerning licensee's review of 304 & 316 austenitic stainless steel piping, fitting material & weld metal in the reactor coolant pressure boundary at Nine Mile Point.....w/att table listing the systems which are in non-compliance.....

PLANT NAME: Nine Mile Point Unit No. 1
RJL 12/20/77 (2-P)+(1-P)

SAFETY FOR ACTION/INFORMATION

BRANCH CHIEF: (7)

LEAR

INTERNAL DISTRIBUTION

REG FILE

- NRC PDR
- T & E (2)
- WELD
- HANAUER
- CHECK
- EISENHIT
- SHAO
- BAER
- BITLER
- GRIMES
- J. COLLINS
- J. MCGOUGH

EXTERNAL DISTRIBUTION

LPDR: DSW60 N.Y.
TIC
NSIC
ACRS 16 CYS SENT CATEGORY B

CONTROL NUMBER

773540058

mk4

12-1-68

Donald P. Dise
Vice President
Engineering

NIAGARA MOHAWK POWER CORPORATION/300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202/TELEPHONE (315) 474-1511

December 16, 1977

Director of Nuclear Reactor Regulation
Attn: Mr. George Lear, Chief
Operating Reactors Branch #3
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63



Gentlemen:


Your letter of September 16, 1977 requested that all 304 and 316 austenitic stainless steel piping, fitting material and weld metal in the reactor coolant pressure boundary at Nine Mile Point Unit 1 be reviewed with respect to the requirements of NUREG-0313.

The results of this review indicate that piping and material used at Nine Mile Point Unit 1 do not comply fully with the requirements of NUREG-0313 for minimizing the susceptibility to stress corrosion cracking. Table 1 lists the systems which are in non-compliance.

With regard to intergranular stress corrosion cracking, "as-welded" Type 316 stainless steel should not be classified with Type 304 stainless steel. This conclusion is based on full-scale laboratory pipe tests and the fact that Niagara Mohawk is not aware of any instances where intergranular stress corrosion cracking has occurred in Type 316 stainless steel pressure boundary lines. Since our recirculation system is built of this Type 316 stainless steel, it is not planned to increase the inservice inspection associated with this system.

It is not practical to replace piping in the service sensitive systems listed in Table 1 because of the excessive occupational exposures that would be incurred and extensive work involved with primary containment penetrations. However, Niagara Mohawk plans to implement increased levels of inservice inspection as outlined in NUREG-0313 for systems built of Type 304 stainless steel and to adopt the model Technical Specification on leakage detection.

773540058




Since austenitic stainless steel piping has an inherent high material toughness, stress corrosion cracking will not cause a rapidly propagating failure. Therefore, implementation of increased inservice inspection and coolant boundary leakage detection will enhance the detection of cracks before they would propagate to create a significant safety hazard. Should any indications be found as a result of the above inspections, appropriate replacement schedules will be developed.

A license amendment dated December 16, 1977 covering both inservice inspection and leakage detection is being transmitted under separate cover.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



DONALD P. DIZE
Vice President-Engineering

PEF/szd

Attachment



TABLE II

REACTOR COOLANT PRESSURE BOUNDARY PIPING
CONTAINING 304 AND 316 STAINLESS STEEL

NON-SERVICE SENSITIVE

1. Reactor Recirculation
2. Clean-Up
3. Reactor Drain

SERVICE SENSITIVE

1. Core Spray
2. Shutdown Cooling
3. Emergency Condensers
4. Liquid Poison
5. Reactor Head Spray
6. Recirculation Bypass
7. Control Rod Drive Return
8. Reactor Instruments

RECEIVED DOCUMENT
PROCESSING UNIT

1977 DEC 19 AM 9 27