

D-3/9/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)  
DISTRIBUTION FOR INCOMING MATERIAL 50-220

REC: LEAR G E  
NRC

ORG: RHODE G K  
NIAGARA MOHAWK PWR

DOC DATE: 03/02/78  
DATE RCVD: 03/06/78

DOCTYPE: LETTER NOTARIZED: NO  
SUBJECT:

COPIES RECEIVED  
LTR 1 ENCL 0

FURNISHING INFO CONCERNING AUTOMATIC FEEDWATER PUMP TRIP ON HIGH  
REACTOR VESSEL WATER LEVEL IN REPSONSE TO NRC LTR DTD 02/01/78.

PLANT NAME: NINE MILE PT - UNIT 1

REVIEWER INITIAL: XEF  
DISTRIBUTOR INITIAL:

\*\*\*\*\* DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS \*\*\*\*\*

GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LICENSE.  
(DISTRIBUTION CODE A001)

FOR ACTION: BR CHIEF LEAR\*\*LTR ONLY(7)

INTERNAL: REG-FILE\*\*LTR ONLY(1)  
I & E\*\*LTR ONLY(2)  
HANAUER\*\*LTR ONLY(1)  
EISENHUT\*\*LTR ONLY(1)  
BAER\*\*LTR ONLY(1)  
GRIMES\*\*LTR ONLY(1)  
J. MCGOUGH\*\*LTR ONLY(1)

NRC PDR\*\*LTR ONLY(1)  
OELD\*\*LTR ONLY(1)  
CHECK\*\*LTR ONLY(1)  
SHAD\*\*LTR ONLY(1)  
BUTLER\*\*LTR ONLY(1)  
J COLLINS\*\*LTR ONLY(1)

EXTERNAL: LPDR'S  
OSWEGO, NY\*\*LTR ONLY(1)  
TIC\*\*LTR ONLY(1)  
NSIC\*\*LTR ONLY(1)  
ACRS CAT B\*\*LTR ONLY(16)

DISTRIBUTION: LTR 40 ENCL 0  
SIZE: 1P

CONTROL NBR: 780650169

\*\*\*\*\* THE END \*\*\*\*\*

TO: [Illegible] FROM: [Illegible] SUBJECT: [Illegible]

[Illegible text block]

[Illegible text block]

[Illegible text block]

[Illegible text block]

[Illegible text block]

[Illegible text block]


[Illegible text block]

[Illegible text block]

[Illegible text block]

March 2, 1978

Director of Nuclear Reactor Regulation  
Attn: Mr. George Lear, Chief  
Operating Reactors Branch #3  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555



Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63

Gentlemen:

Your letter of February 1, 1978 requested information as to whether or not we plan to install an automatic feedwater pump trip on high reactor vessel water level. At Nine Mile Point Unit 1 there are no safety or safety/relief valves located on the main steam lines which could be damaged by high water level conditions. Safety valves are located on the reactor vessel head; therefore, this safety function is maintained. Relief valves are located on the main steam lines. The discharge from these valves is routed directly to the suppression pool. Thus, no damage would result to any equipment located inside of the primary containment should these valves actuate during a high water level condition.


The feedwater system consists of three (3) strings. One (1) string utilizes a shaft-driven pump off the turbine whereas the other two (2) strings utilize motor-driven pumps.

The motor-driven pumps are also used in the high pressure coolant injection mode. A high reactor vessel level trip of the motor-driven feedwater pumps would disable this function.

For operational reasons, it may be advantageous to trip the shaft-driven pump on high water level to reduce the possibility of damage to the relief valves on the main steam lines. We are currently investigating methods to implement this trip. We will notify you by April 15, 1978 as to the feasibility of installing such a trip on the shaft-driven pump.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION

  
Gerald K. Rhode, Vice President  
System Project Management

780650169

A001/S \*  
1/0

