

see docket 50-277  
for enclosure

8/11/77

DISTRIBUTION:

- Docket
- NRC PDR
- Local PDR
- ORB#3 Rdg
- GLear
- CParrish
- SNowicki
- RSnaider
- OELD
- OI&E (3)
- DEisenhut
- TBAbernathy
- JRBuchanan
- ACRS (16)
- File

Docket No. 50-220

Niagara Mohawk Power Corporation  
 ATTN: Mr. Gerald K. Rhode  
 Vice President - Engineering  
 300 Erie Boulevard West  
 Syracuse, New York 13202

Gentlemen:

RE: NINE MILE POINT NUCLEAR STATION UNIT NO. 1

The NRC has completed its initial evaluation of the BWR feedwater nozzle and control rod drive (CRD) line return nozzle cracking phenomena and experience to date. This evaluation has considered examination results reported by BWR owners, theoretical analyses of the causes of the cracking and propagation, and studies of potential remedial measures to minimize crack initiation and growth for the short term and also to eliminate the causes of cracking for the longer term. The enclosed staff report presents our position regarding feedwater nozzle and CRD nozzle cracking and includes inspection criteria to be used by licensees to monitor crack growth until such time as the causes of cracking have been eliminated.

As indicated in Part I, Section 7 and Part II, Section 5 of this report, you should provide a detailed description of your proposed inspection program, 90 days prior to the next refueling outage for each BWR facility.

Sincerely,

George Lear, Chief  
 Operating Reactors Branch #3  
 Division of Operating Reactors

Enclosure: <sup>see</sup>  
 Staff Report 50-277

cc w/enclosure:  
 See next page

Misc  
f

OFFICE >	ORB#2	ORB#3	ORB#3		
SURNAME >	RSnaider:acr	SNowicki	GLear		
DATE >	8/ 11 /77	8/ 11 /77	8/ 11 /77		

1952  
JAN 10  
P. 10  
1952

Faded body text of the document, consisting of several lines of illegible characters.

10	11	12	13	14	15
----	----	----	----	----	----

cc: Arvin E. Upton, Esquire  
LeBoeuf, Lamb, Leiby & MacRae  
1757 N Street, N. W.  
Washington, D. C. 20036

Anthony Z. Roisman, Esquire  
Roisman, Kessler and Cashdan  
1025 15th Street, N. W.  
5th Floor  
Washington, D. C. 20005

Oswego City Library  
46 E. Bridge Street  
Oswego, New York 13126

