

Central files



UNITED STATES
ATOMIC ENERGY COMMISSION
DIRECTORATE OF REGULATORY OPERATIONS
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

MAY 14 1974

Niagara Mohawk Power Corporation
Attention: R. R. Schnieder
Vice President
Electric Operations
300 Erie Boulevard West
Syracuse, New York 13202

License No. DPR-17
Inspection No. 50-220/74-02

Reference: Your letter dated April 23, 1974
In response to our letter dated April 5, 1974

Gentlemen:

Thank you for informing us of the corrective and preventive actions you documented in response to our correspondence. These actions will be examined during a subsequent inspection of your licensed program.

Your cooperation with us is appreciated.

Sincerely,

E. J. Brunner acting for

Eldon J. Brunner, Chief
Operations Branch


cc: Mr. P. A. Burt, General Superintendent, Nuclear Generation
Mr. T. J. Perkins, Plant Superintendent, Nuclear Generation
Mr. C. L. Stuart, Assistant Plant Superintendent

bcc:
Chief, FS&EB
RO:HQ (4)
DL (4)
RO Files
DR Central Files
OGC
RS
PDR
Local PDR
NSIC
DTIE

RO:I Regulatory Reading Room
State of New York
A. Z. Roisman, Counsel for Citizens
Committee for Protection of the
Environment

MISC
Rg

OFFICE	..CRESS..	<i>Capton</i>	<i>ASB acting</i>			
SURNAME	..Plumlee/jd..	..Capton..	..Brunner..	<i>O'Rourke</i>	<i>5/14/74</i>	



NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD WEST
SYRACUSE, N. Y. 13202

April 23, 1974

Elden J. Brunner
Chief
Reactor Operation Branch
Directorate of Regulator, Operation
Region 1
631 Park Avenue
King of Prussia, Penn. 19406

Dear Mr. Brunner:

Following a thorough review of your April 5, 1974 letter, regarding Inspection No. 50-220/74-02 at Nine Mile Point Nuclear Station Unit 1, we have concluded that there is no information in the report of a proprietary nature.

In response to the two alleged violations the following is submitted:

1. Control for spilled liquid in Waste Disposal Building - The Final Safety Analysis Report in Part III 2.1 (page III-29) will be changed according to 10CFR50.59, reflecting the as built conditions. The curbs would hinder operation of vehicles and personnel on Elevation 261 and would allow the fluid to spread over a wider area on the upper elevation. This is undesirable. The designed control for spilled liquid is to allow the fluid to seek a lower level and thus be accommodated by the sumps, which contain the fluid, and pump directly to storage tanks. It is expected that this request will be submitted by May 1, 1974.
2. Posting of Information to Employees - The information required by 10CFR 19.11 consists of, in part, the FSAR. This set of station documents is in constant use by not only station employees, but various consultants working at the station. The complete set of documents was located in the Administration Building and had not been properly signed out. As a corrective measure, documents placed in the locations pursuant to 10CFR 19.11 will be labeled with "Not to be removed unless properly signed out". The sign




1 2

Mr. Elden J. Brunner
U.S. Atomic Energy Commission

April 23, 1974

out will be accomplished by placing a removable book tag in the document. When the document is removed the tag will be placed in a specially marked container. It is expected that this system will be fully operable by May 1, 1974. In addition all documents and/or the shelves upon which they are stored will be marked indicating the particular document. This will aid in quick identification from other filed information stored in the same area. Also the signs designating the location of posted information will be corrected. This corrective action is also expected to be completed by May 1, 1974.

Very Truly Yours,



R.R. Schneider
Vice President - Electric Operations

TJD;bar

