

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:
Mr. Edson G. Case

FROM:
LeBoeuf, Lamb, Leiby & MacRae
Washington, D. C.
E. B. Thomas, Jr.

DATE OF DOCUMENT
5/11/77

DATE RECEIVED
5/11/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP
INPUT FORM

NUMBER OF COPIES RECEIVED
3 SIGNED

DESCRIPTION

Ltr. trans the following:

DO NOT REMOVE

ACKNOWLEDGED (I-P)

PLANT NAME:
Nine Mile Point Unit No. 1

RJL

ENCLOSURE

Amdt. to OL/change to Appendix A tech specs....notorized 5/6/77....concerns certain repairs at facility and concomitantly to allow a continuation of a slightly lower water level in the reactor vessel.....


(6-P)

40 encl.

SAFETY		FOR ACTION/INFORMATION		ENVIRO	
ASSIGNED AD:		ASSIGNED AD:		ASSIGNED AD:	
BRANCH CHIEF: (6)	<i>LEAR</i>	BRANCH CHIEF:		BRANCH CHIEF:	
PROJECT-MANAGER:	<i>NOWICKI</i>	PROJECT-MANAGER:		PROJECT-MANAGER:	
LIC.-ASST. :	<i>PARRISH</i>	LIC. ASST. :		LIC. ASST. :	

INTERNAL DISTRIBUTION			
<input checked="" type="checkbox"/> REG-FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY
<input checked="" type="checkbox"/> NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
<input checked="" type="checkbox"/> I & E	SCHROEDER	BENAROYA	DENTON & MILLER
<input checked="" type="checkbox"/> OELD		LAINAS	
<input checked="" type="checkbox"/> GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACARY	KIRKWOOD	ERNST
CASE	BOSNAK		BALLARD
HANAUER	SIHWEIL	OPERATING REACTORS	YOUNGBLOOD
HARLESS	PAWLICKI	STELLO	
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	SITE TECH.
BOYD	ROSS	EISENHUT	GAMMILL
P. COLLINS	NOVAK	SHAO	STEPP
HOUSTON	ROSZTOCZY	BAER	HULMAN
PETERSON	CHECK	BUTLER	SITE ANALYSIS
MELTZ		GRIMES	VOLLNER
HELTEMES	AT & I		BUNCH
SKOVHOLT	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

EXTERNAL DISTRIBUTION			CONTROL NUMBER
<input checked="" type="checkbox"/> LPDR: <i>OSWEGO NY</i>	NAT. LAB:	BROOKHAVEN NAT. LAB.	771320257 <i>Ap 2</i> <i>GD</i>
<input checked="" type="checkbox"/> TIC:	REG V.IE	ULRIKSON (ORNL)	
<input checked="" type="checkbox"/> NSIC:	LA PDR		
<input checked="" type="checkbox"/> ASLB:	CONSULTANTS:		
<input checked="" type="checkbox"/> ACRS / CYS HOLDING/ SENT AS CAT. B			



LAW OFFICES OF
LEBOEUF, LAMB, LEIBY & MACRAE
1757 N STREET, N.W.
WASHINGTON, D. C. 20036

TELEPHONE 202 457-7500

CABLE ADDRESS

LEBWIN, WASHINGTON, D. C.

TELEX: 440274

RANDALL J. LEBOEUF, JR. 1929-1975
ADRIAN C. LEIBY 1952-1976

LEON A. ALLEN, JR.
JOSEPH E. BACHELDER, III
ERNEST S. BALLARD, JR.
G. S. PETER BERGEN, JR.
GEOFFREY D. C. BEST
DAVID P. BICKS
TAYLOR R. BRIGGS
CHARLES N. BURGER
THOMAS E. BURKE
WILLIAM O. DOUB, JR.
ROGER D. FELDMAN
EUGENE R. FIDELL, JR.
JACOB FRIEDLANDER
DONALD J. GREENE
JAMES A. GREER, II
JOHN L. GROSE
DOUGLAS W. HAWES
CARL D. HOBELMAN
MICHAEL IOVENKO
JAMES F. JOHNSON, 4TH
RONALD D. JONES
LEX K. LARSON, JR.
GRANT S. LEWIS

CAMERON F. MACRAE, JR.
CAMERON F. MACRAE, III
GERARD A. MAHER
SHEILA H. MARSHALL
JAMES G. MCELROY
JAMES P. MCGRANERY, JR.
PHILIP PALMER MCGUIGAN
L. MANNING MUNTZING, JR.
JAMES O'MALLEY, JR.
J. MICHAEL PARISH
JOHN A. RUOY
PAUL G. RUSSELL
HAROLD M. SEIDEL
CHARLES P. SIFTON
HALCYON G. SKINNER
JOSEPH S. STRAUSS
SAMUEL M. SUGDEN
EUGENE B. THOMAS, JR.
LEONARD M. TROSTEN, JR.
HARRY H. VOIGT, JR.
H. RICHARD WACHTEL
GERARD P. WATSON

May 11, 1977

OF COUNSEL
ARVIN E. UPTON

140 BROADWAY
NEW YORK, N.Y. 10005

TELEPHONE 212 269-1100

CABLE ADDRESS

LEBWIN, NEW YORK

TELEX: 423416



*RESIDENT PARTNERS WASHINGTON OFFICE
*ADMITTED TO THE DISTRICT OF COLUMBIA BAR

REGULATORY DOCKET FILE COPY

Mr. Edson G. Case
Acting Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Niagara Mohawk Power Corporation
Nine Mile Point Unit 1
Docket No. 50-220

Dear Mr. Case:

I enclose herewith three (3) originals and nineteen (19) copies of an Application for Amendment to Operating License No. DPR-63. Also enclosed are forty (40) copies of each of the two technical documents accompanying the Application.

The purpose of this request is to change a recently approved Technical Specification allowing the Licensee more time in which to make certain repairs at its facility and concomitantly to allow a continuation of a slightly lower water level in the reactor vessel.

Very truly yours,

LEBOEUF, LAMB, LEIBY & MACRAE
Attorneys for Niagara Mohawk Power Corporation

By E. B. Thomas, Jr.
Eugene B. Thomas, Jr.
Partner

Enclosures

771320257

WASHINGTON, D.C. 20540
U.S. DEPARTMENT OF JUSTICE
FEDERAL BUREAU OF INVESTIGATION
WASHINGTON, D.C. 20535

[The body of the document contains several paragraphs of text that are extremely faint and illegible due to the quality of the scan. The text appears to be a formal report or letter, but the specific content cannot be discerned.]

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)

NIAGARA MOHAWK POWER CORPORATION)
(Nine Mile Point Nuclear Station)
Unit No. 1))

Docket No. 50-220


APPLICATION FOR AMENDMENT

TO

OPERATING LICENSE


Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. DPR-63, hereby requests that Sections 2.1.1 and 3.1.4 of the Technical Specifications and Bases set forth in Appendix A to that License be amended. This proposed change has been concurred with by the Site Operations Review Committee and Safety Review and Audit Board.

The proposed Technical Specification change is set forth in Attachment A to this application. Supporting Information, which demonstrates that the proposed change does not involve a significant hazards consideration, is set forth in Attachment B. The proposed change would not authorize any change in the types or any increase in the amounts of effluents or any change in the authorized power level of the facility.





WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-63 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By 
Gerald K. Rhode
Vice President-Engineering

Subscribed and sworn to before me this 6th day of May, 1977.


NOTARY PUBLIC
PHYLLIS D. VOYTKO
Notary Public in the State of New York
Qualified in Onon. Co. No. 34-948535
My Commission Expires March 30, 1978



ATTACHMENT A


NIAGARA MOHAWK POWER CORPORATION

License No. DPR-63

Docket No. 50-220

Proposed Changes to Technical Specifications

Attached are revisions to Pages 6 and 53a of
Appendix A to DPR-63.



SAFETY LIMIT


- c. The neutron flux shall not exceed its scram setting for longer than 1.5 seconds as indicated by the process computer. When the process computer is out of service, a safety limit violation shall be assumed if the neutron flux exceeds the scram setting and control rod scram does not occur.

To ensure that the Safety Limit established in Specifications 2.1.1a and 2.1.1b is not exceeded, each required scram shall be initiated by its expected scram signal. The Safety Limit shall be assumed to be exceeded when scram is accomplished by a means other than the expected scram signal.

- d. Whenever the reactor is in the shutdown condition with irradiated fuel in the reactor vessel, the water level shall not be more than 7 feet 11 inches (127.1 inches indicator scale) below minimum normal water level (Elevation 302'9"), except as specified in "e" below.
- e. For the purpose of performing major maintenance (not to exceed 12 weeks in duration) on the reactor vessel, the reactor water level may be lowered 9' below the minimum normal water level (Elevation 302'9"). Whenever the reactor water level is to be lowered below the low-low-low level set point redundant instrumentation will be provided to monitor the reactor water level.

LIMITING SAFETY SYSTEM SETTING

- d. The reactor water low level scram trip setting shall be no lower than -12 inches (53 inches indicator scale) relative to the minimum normal water level (302'9").
- e. The reactor water low-low level setting for core spray initiation shall be no less than -5 feet (5 inches indicator scale) relative to the minimum normal water level (Elevation 302'9").
- f. The flow biased APRM rod block trip settings shall be less than or equal to that shown in Figure 2.1.1.




LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENT

h. For the purpose of performing major maintenance (not to exceed 12 weeks in duration) on the reactor vessel, the reactor water level may be lowered to 9' below the minimum normal water level (elevation 302'9"). Whenever the reactor water level is to be lowered below the low-low-low level set point, redundant instrumentation will be provided to monitor the reactor water level and written procedures will be developed and followed whenever the reactor water level is lowered below the low-low level set point. The procedures will define the valves that will be used to lower the vessel water level. All other valves that have the potential of lowering the vessel water level will be identified by valve number in the procedures and these valves will be red tagged to preclude their operation during the major maintenance with the water level below the low-low level set point.

During the period of major maintenance requiring lowering the water level to more than 7 feet 11 inches below minimum normal water level (127.1 inches indicator scale), either both Core Spray Systems must be operable or, if one Core Spray System is inoperable because of the maintenance, all of the redundant components of the other Core Spray System must be operable.



Attachment B

NIAGARA MOHAWK POWER CORPORATION

License No. DPR-63

Docket No. 50-220

Supporting Information

Our submittal of March 9, 1977 requested a change which would allow lowering of the reactor vessel water level below the low-low-low level set point. This was required so that maintenance could be performed on the feed-water spargers and nozzles.

The maintenance work on the spargers and nozzles has been slower than anticipated. Also, additional work has been found to be necessary on the control rod drive hydraulic return line. Therefore, a change in the duration from 6 to 12 weeks is necessary.

Since the core decay heat generation is constantly decreasing, the consequences of a LOCA while in the shutdown condition will continue to be less severe.



1
1