

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

9881

CONTROL NO: _____

FILE: _____

FROM: LeBoeuf, Lamb, Leiby, MacRae Washington, D.C. 20036 Mr. E.B. Thomas, Jr.		DATE OF DOC 9-25-74	DATE REC'D 9-25-74	LTR X	TWX	RPT	OTHER
TO: AEC		ORIG 1 signed	CC	OTHER	SENT AEC PDR SENT LOCAL PDR		XXX XXX
CLASS	UNCLASS XXX	PROP INFO	INPUT XXX	NO CYS REC'D 40	DOCKET NO: 50-220		

DESCRIPTION:

Ltr trans the following....

PLANT NAME: Nine Mile Pt.

ENCLOSURES:

Amdt to the OL...consist of changes to the Tech specs.....

ACKNOWLEDGED
(40 cys encl rec'd)

DO NOT REMOVE

FOR ACTION/INFORMATION 9-26-74 JB

- | | | | |
|-------------------------|----------------------------|-----------------------------|------------------------|
| BUTLER (L)
W/ Copies | SCHWENCER (L)
W/ Copies | ZIEMANN (L)
W/ Copies | REGAN (E)
W/ Copies |
| CLARK (L)
W/ Copies | STOLZ (L)
W/ Copies | DICKER (E)
W/ Copies | LEAR (L)
W/9 Copies |
| PARR (L)
W/ Copies | VASSALLO (L)
W/ Copies | KNIGHTON (E)
W/ Copies | W/ Copies |
| KNIEL (L)
W/ Copies | PURPLE (L)
W/ Copies | YOUNGBLOOD (E)
W/ Copies | W/ Copies |

INTERNAL DISTRIBUTION

- | | | | | |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| REG FILE
AEC PDR
OGC, ROOM P-506A
MUNTZING/STAFF
CASE
GIAMBUSSO
BOYD
MOORE (L) (BWR)
DEYOUNG (L) (PWR)
SKOVHOLT (L)
GOLLER (L)
P. COLLINS
DENISE
REG OPR
FILE & REGION (3)
MORRIS
STEELE | TECH REVIEW

SCHROEDER
MACCARY
KNIGHT
PAWLICKI
SHAO
STELLO
HOUSTON
NOVAK
ROSS
IPPOLITO
TEDESCO
LONG
LAINAS
BENAROYA
VOLIMER | DENTON
GRIMES
GAMMILL
KASTNER
BALLARD
SPANGLER

ENVIRO
MULLER
DICKER
KNIGHTON
YOUNGBLOOD
REGAN
PROJECT LDR
<u>Dittman</u>
HARLESS | LIC ASST

DIGGS (L)
GEARIN (L)
GOULBOURNE (L)
KREUTZER (E)
LEE (L)
MAIGRET (L)
REED (E)
SERVICE (L)
SHEPPARD (L)
SLATER (E)
SMITH (L)
TEETS (L)
WILLIAMS (E)
WILSON (L) | A/T IND
BRAITMAN
SALTZMAN
B. HURT

PLANS
MCDONALD
CHAPMAN
DUBE w/input
E. COUPE
Scheme 1
D. THOMPSON (2)
KLECKER
EISENHUT |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

EXTERNAL DISTRIBUTION

- | | | |
|-----------------------------------|---------------------------------|-----------------------------------------|
| 1 - LOCAL PDR <u>Oswego, Ill.</u> | 1 - NATIONAL LABS _____ | 1 - PDR-SAN/LA/NY |
| 1 - TIC (ABERNATHY) (1)(2)(10) | 1 - ASLBP (E/W Bldg, Rm 529) | 1 - BROOKHAVEN NAT LAB |
| 1 - NSIC (BUCHANAN) | 1 - W. PENNINGTON, Rm E-201 GT | 1 - G. ULRIKSON, ORNL |
| 1 - ASLB | 1 - B&M SWINEBROAD, Rm E-201 GT | 1 - AGMED (RUTH GUSSMAN)
Rm B-127 GT |
| 1 - Newton Anderson | 1 - CONSULTANTS | 1 - R. D. MUELLER, Rm E-201
GT |
| 16 - ACRS HOLDING | NEWMARK/BLUME/AGBABIAN | |

[The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and does not form any recognizable words or sentences.]

Regulatory Docket File

LAW OFFICES OF
LEBOEUF, LAMB, LEIBY & MACRAE
1757 N STREET, N.W.
WASHINGTON, D. C. 20036

ARVIN E. UPTON
EUGENE B. THOMAS, JR.
LEONARD M. TROSTEN
HARRY H. VOIGT
LEX K. LARSON
WASHINGTON PARTNERS

September 25, 1974

ONE CHASE MANHATTAN PLAZA
NEW YORK, N. Y. 10005

WASHINGTON TELEPHONE
202-672-8668

CABLE ADDRESS
LALALU, WASHINGTON D.C.



Director of Licensing
U.S. Atomic Energy Commission
Washington, D.C. 20545

Re: Niagara Mohawk Power Corporation
Docket No. 50-220
Provisional Operating License DPR-17

Dear Sir:


As counsel for Niagara Mohawk Power Corporation, we hereby transmit three (3) originals and nineteen (19) copies of an Application for Amendment to the Provisional Operating License in the above-captioned docket. Accompanying this application are forty (40) copies of a document entitled, "Proposed Changes in Technical Specifications".

These changes to the Technical Specifications are proposed in accordance with the requirements of Sections 50.59(c) and 50.90 of the Commission's Rules and Regulations. They would increase the safety margin for the isolation function for the emergency condensers.

Very truly yours,

LEBOEUF, LAMB, LEIBY & MacRAE

By Eugene B. Thomas, Jr.
Eugene B. Thomas, Jr.
Partner



Enclosures

9881



1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942

1942


1942

BEFORE THE UNITED STATES
ATOMIC ENERGY COMMISSION

In the Matter of)
)
NIAGARA MOHAWK POWER CORPORATION)
(Nine Mile Point Unit 1))

Docket No. 50-220

APPLICATION FOR AMENDMENT
TO
PROVISIONAL OPERATING LICENSE




Niagara Mohawk Power Corporation, Licensee in the above-captioned docket, hereby files an Application for Amendment to its Provisional Operating License DPR-17.

This Amendment would change the Technical Specifications with respect to the set-point for high steam flow in the emergency cooling system.

With this Application for Amendment, Licensee hereby transmits a document entitled "Proposed Change to Technical Specifications" describing the change and the reasons therefore. The proposed change has been reviewed and approved by the Safety Review and Audit Board and the Site Operations Review Committee.

9881



WHEREFORE, Licensee prays as in its original Application for
Licenses.

Respectfully submitted,

NIAGARA MOHAWK POWER CORPORATION

By Philip D. Raymond
Philip D. Raymond
Vice President-Engineering

Subscribed and sworn to before
me this 20th day of September, 1974.

Hazel J. Carrick

HAZEL J. CARRICK
Notary Public in the State of New York
Qualified in Onon. Co. No. 4524460
My Commission Expires March 30, 1976

1948
1949
1950
1951
1952

Proposed Changes to Technical Specifications

Proposed changes to the Technical Specifications would increase safety margin for the isolation function for the emergency condensers.

The original set point for high steam flow in the emergency cooling system supply line was ≤ 29.5 psid. That set point was established on the basis of a short radius elbow installation. After initial operation, a check of the fabrication drawings and field measurements indicated that a long radius elbow was actually installed.

A recalculation results in a revised set point of 19 psid representing a flow of 291 percent of maximum design capacity. This revised set point provides sufficient capability to isolate the emergency condensers on high flow due to a line break. Also sufficient margin exists such that the unit will not trip during normal operation. The high flow used for this calculation is equivalent to a rupture of 30 percent of the pipe cross-sectional area.



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

NIAGARA MOHAWK POWER CORPORATION

License No. DPR-17

Docket No. 50-220

Proposed Change to Technical Specifications

<u>Item</u>	<u>Location</u>	<u>Change</u>
Basis for Section 3.6.2	Page 95	Change the fourth and fifth sentences in the first paragraph to read as follows: "The high flow set point for the emergency cooling system supply line is 19 psi differential. This represents a flow of approximately 8.7×10^5 pounds per hour at rated condition."
Table 3.6.2 c and 4.6.2 c	Page 102	Change the set point under item (3) High Steam Flow Emergency Cooling System to 19 psid from ≤ 29.5 psid.



Handwritten scribbles and marks in the top right corner.