

WF3 Outfall 001
(Once-Through Non-Contact Cooling Water)

Month/ Year	Temperature (°F)		Thermal Discharge (MBTU/hr)	Flow (mgd)		Total Chlorine (lbs/day)
	Monthly Average	Daily Maximum	Daily Maximum	Monthly Average	Daily Maximum	Daily Maximum
LPDES Limit	<u>Report</u>	<u>118</u>	<u>9,500</u>	<u>Report</u>	<u>Report</u>	<u>211</u>
Jan-14	65.8	69.1	8,850	1,011	1,172	(a)
Feb-14	71.1	80.0	8,800	866	1,145	(a)
Mar-14	71.6	84.0	8,860	1,106	1,269	(a)
Apr-14	70.6	90.2	8,930	992	1,291	(a)
May-14	79.7	96.8	8,813	974	1,373	(a)
Jun-14	101.1	106.8	8,930	1,098	1,305	(a)
Jul-14	103.9	109.7	8,982	1,217	1,272	(a)
Aug-14	105.7	107.8	8,869	1,149	1,189	(a)
Sep-14	104.0	111.0	8,900	1,229	1,479	(a)
Oct-14	92.7	100.2	8,963	1,276	1,462	(a)
Nov-14	81.7	88.5	8,995	1,097	1,319	(a)
Dec-14	74.9	83.5	8,900	984	1,158	(a)
Jan-15	69.7	78.9	8,815	1,022	1,342	(a)
Feb-15	73.0	85.5	8,940	936	1,250	(a)
Mar-15	68.9	83.6	8,740	1,026	1,230	(a)
Apr-15	88.4	93.6	8,850	911	1,110	(a)
May-15	98.1	107.5	8,850	911	1,160	(a)
Jun-15	96.0	105.0	8,900	1,026	1,470	(a)
Jul-15	103.8	109.0	8,920	1,243	1,298	(a)
Aug-15	105.9	110.0	8,910	1,210	1,275	(a)
Sep-15	106.0	110.0	8,910	1,066	1,298	(a)
Oct-15	86.0	108.0	8,820	1,108	1,143	(a)
Nov-15	65.0	69.0	0	0.383	0.750	(a)
Dec-15	74.8	80.8	8,746	1,072	1,303	(a)
Jan-16	75.7	84.7	8,770	921	1,150	(a)
Feb-16	74.7	81.3	8,735	878	1,127	(a)
Mar-16	82.3	91.4	8,730	892	1,190	(a)
Apr-16	87.5	92.5	8,850	1,000	1,209	(a)
May-16	94.3	98.3	8,770	1,057	1,330	(a)
Jun-16	101.2	106.6	8,900	1,149	1,292	(a)

a. No chlorination or biocide usage occurred during this reporting period.

WF3 Outfall 001
(Once-Through Non-Contact Cooling Water) ^(b)

Month/ Year	NOEC, Pass/Fail [0/1] Lethality, 48-Hour Acute, Pimephales promelas		NOEC, Value [%], Lethality, 48-Hour Acute, Pimephales promelas		NOEC, Value [%], Coefficient of Variation, 48-Hour Acute, Pimephales promelas	
	Monthly Average Minimum	48-Hour Minimum	Monthly Average Minimum	48-Hour Minimum	Monthly Average Minimum	48-Hour Minimum
<i>LPDES Limit</i>	<i>Report</i>	<i>Report</i>	<i>Report</i>	<i>Report</i>	<i>Report</i>	<i>Report</i>
Mar-14	0	0	42.0	42.0	0	0
Jun-14	0	0	42.0	42.0	0	0
Sep-14	0	0	42.0	42.0	6.6	6.6
Dec-14	0	0	42.0	42.0	0	0
Mar-15	0	0	42.0	42.0	0	0
Jun-15	0	0	42.0	42.0	6.63	6.63
Sep-15	0	0	42.0	42.0	5.3	5.3
Dec-15	0	0	42.0	42.0	10.1	10.1
Mar-16	0	0	42.0	42.0	5.3	5.3
Jun-16	0	0	42.0	42.0	0	0

b. All results reported Passed.

WF3 Outfall 001
(Once-Through Non-Contact Cooling Water) ^(b)

Month/ Year	NOEC, Pass/Fail [0/1] Lethality, 48-Hour Acute, Daphnia pulex		NOEC, Value [%], Lethality, 48-Hour Acute, Daphnia pulex		NOEC, Value [%], Coefficient of Variation, 48-Hour Acute, Daphnia pulex	
	Monthly Average Minimum	48-Hour Minimum	Monthly Average Minimum	48-Hour Minimum	Monthly Average Minimum	48-Hour Minimum
<i>LPDES Limit</i>	<i>Report</i>	<i>Report</i>	<i>Report</i>	<i>Report</i>	<i>Report</i>	<i>Report</i>
Mar-14	0	0	42.0	42.0	10.1	10.1
Jun-14	0	0	42.0	42.0	5.28	5.28
Sep-14	0	0	42.0	42.0	10.1	10.1
Dec-14	0	0	42.0	42.0	5.3	5.3
Mar-15	0	0	42.0	42.0	0	0
Jun-15	0	0	42.0	42.0	0	0
Sep-15	0	0	42.0	42.0	0	0
Dec-15	0	0	42.0	42.0	5.3	5.3
Mar-16	0	0	42.0	42.0	5.3	5.3
Jun-16	0	0	42.0	42.0	5.3	5.3

b. All results reported Passed.

WF3 Outfall 101
(Liquid Waste Management)

Month/ Year	pH (s.u.)		TSS (mg/l)	Oil & Grease (mg/l)	Flow (mgd)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum
<i>LPDES Limit</i>	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>20</u>	<u>Report</u>
Jan-14	6.15	6.40	0	0	0.0129
Feb-14	6.09	6.18	0	0	0.0129
Mar-14	6.02	6.25	0	0	0.0124
Apr-14	6.09	6.56	0	0	0.0133
May-14	6.03	6.91	0	0	0.013
Jun-14	6.08	6.72	0	0	0.0124
Jul-14	6.08	6.72	0	0	0.0134
Aug-14	6.02	6.17	0	0	0.0130
Sep-14	6.06	6.14	0	0	0.0126
Oct-14	6.06	6.52	0	0	0.0128
Nov-14	6.02	6.74	0	0	0.0116
Dec-14	6.04	6.21	0	0	0.0130
Jan-15	6.09	6.64	0	0	0.013
Feb-15	6.10	6.10	0	0	0.0126
Mar-15	6.04	6.22	0	0	0.0126
Apr-15	6.10	6.50	0	0	0.0133
May-15	6.06	6.43	0	0	0.0122
Jun-15	6.07	6.33	0	0	0.0128
Jul-15	(c)	(c)	(c)	(c)	(c)
Aug-15	6.08	7.07	0	0	0.0126
Sep-15	6.04	6.36	0	0	0.0131
Oct-15	6.01	6.25	0	0	0.0130
Nov-15	6.17	6.17	0	0	0.0134
Dec-15	6.04	6.21	0	0	0.013
Jan-16	(c)	(c)	(c)	(c)	(c)
Feb-16	6.01	6.14	0	0	0.012
Mar-16	6.02	6.17	0	0	0.013
Apr-16	6.06	6.12	0	0	0.013
May-16	6.03	6.24	0	0	0.013
Jun-16	6.05	6.17	0	0	0.013

c. **No discharges occurred.**

WF3 Outfall 201
(Boron Management System) ^(d)

Month/ Year	pH (s.u.)		TSS (mg/l)	Oil & Grease (mg/l)	Flow (mgd)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum
<i>LPDES Limit</i>	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>20</u>	<u>Report</u>
Feb-14	6.03	6.11	0	0	0.0122
Mar-14	6.02	6.08	0	0	0.0126
Apr-14	6.04	6.43	0	0	0.0129
May-14	6.19	6.87	0	0	0.0125
Jul-14	6.09	6.61	0	0	0.0129
Aug-14	6.08	6.97	0	0	0.0126
Oct-14	6.04	6.12	0	0	0.0127
Mar-14	6.14	6.14	0	0	0.0118
May-15	6.02	6.38	0	0	0.0122
Jun-15	6.11	6.27	0	0	0.0121
Jul-15	6.21	6.50	0	0	0.0122
Aug-15	6.10	6.20	0	0	0.0124
Sep-15	6.07	6.23	0	0	0.0123
Oct-15	6.03	6.28	0	0	0.01285
Dec-15	6.03	6.07	0	0	0.013
Feb-16	6.04	6.12	0	0	0.013

d. Includes only months where there was a discharge.

**WF3 Outfall 301
(Filter Flush Water)**

Month/Year	Flow (mgd)
	Daily Maximum
<i>LPDES Limit</i>	<u>Report</u>
2014	(c)
2015	(c)
2016	(e)

- c. **No discharges occurred.**
- e. **No discharges through June 2016.**

WF3 Outfall 401
(Steam Generator Blowdown) ^(d)

Month/ Year	pH (s.u.)		TSS (mg/l)	Oil & Grease (mg/l)	Flow (mgd)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum
<i>LPDES Limit</i>	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>20</u>	<u>Report</u>
Apr-14	6.96	8.23	0	0	0.05113
May-14	6.85	7.18	0	0	0.0388
2015	(c)	(c)	(c)	(c)	(c)
2016	(e)	(e)	(e)	(e)	(e)

- c. No discharges occurred.
- d. Includes only months where there was a discharge.
- e. No discharges through June 2016.

WF3 Outfall 501
(Auxiliary Cooling Water Basin A) ^(d)

Month/ Year	pH (s.u.)		TSS (mg/l)	TOC (mg/l)	Oil & Grease (mg/l)	Flow (mgd)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum
<i>LPDES Limit</i>	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>50</u>	<u>20</u>	<u>Report</u>
2014	(c)	(c)	(c)	(c)	(c)	(c)
Nov-15	7.55	7.57	0	0.74	0	0.193
2016	(e)	(e)	(e)	(e)	(e)	(e)

- c. No discharges occurred.
- d. Includes only months where there was a discharge.
- e. No discharges through June 2016.

WF3 Outfall 601
(Auxiliary Cooling Water Basin B) ^(d)

Year	pH (s.u.)		TSS (mg/l)	TOC (mg/l)	Oil & Grease (mg/l)	Flow (mgd)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum
<i>LPDES Limit</i>	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>50</u>	<u>20</u>	<u>Report</u>
May-14	7.62	7.63	0	0	0	0.180
Nov-15	7.50	7.51	0	0.77	0	0.173
2016	(e)	(e)	(e)	(e)	(e)	(e)

d. Includes only months where there was a discharge.

e. No discharges through June 2016.

WF3 Outfall 701
(Dry Cooling Tower Sump #1)

Month/ Year	PH (s.u.)		TSS (mg/l)	Total Zinc (mg/l)	Oil & Grease (mg/l)	Flow (mgd)	FAC (mg/l)	TOC (mg/l)	Total Chromium (mg/l)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum
LPDES Limit	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>1.0</u>	<u>20</u>	<u>Report</u>	<u>0.5</u>	<u>50</u>	<u>0.2</u>
Jan-14	7.36	7.36	8.0	(c)	0	0.0836	(c)	----	----
Feb-14	7.41	7.42	0	(c)	0	0.1203	(c)	----	----
Mar-14	7.38	7.38	0	(c)	0	0.0180	(c)	5.8	----
Apr-14	7.09	7.11	0	(c)	0	0.0713	(c)	----	----
May-14	7.86	7.86	0	(c)	0	0.0446	(c)	----	----
Jun-14	7.43	7.45	0	(c)	0	0.1694	(c)	7.0	----
Jul-14	7.55	7.57	0	(c)	0	0.0982	(c)	----	----
Aug-14	7.70	7.71	0	(c)	0	0.0947	(c)	----	----
Sep-14	7.52	7.53	0	(c)	0	0.3779	(c)	5.2	----
Oct-14	7.56	7.57	0	(c)	0	0.0078	(c)	----	----
Nov-14	7.38	7.39	4.0	(c)	0	0.0034	(c)	----	----
Dec-14	7.23	7.24	0	(c)	0	0.0166	(c)	3.42	(c)
Jan-15	7.89	7.89	0	(c)	0	0.0098	(c)	----	----
Feb-15	7.74	7.74	5.2	(c)	0	0.0037	(c)	----	----
Mar-15	7.56	7.57	0	(c)	0	0.0058	(c)	4.36	----
Apr-15	7.87	7.88	0	(c)	0	0.0107	(c)	----	----
May-15	7.88	7.89	0	(c)	0	0.0188	(c)	----	----
Jun-15	7.46	7.47	4.4	(c)	0	0.0147	(c)	9.60	----
Jul-15	7.49	7.49	0	(c)	0	0.0046	(c)	----	----
Aug-15	7.45	7.46	0	(c)	0	0.0050	(c)	----	----
Sep-15	7.22	7.23	0	(c)	0	0.0125	(c)	1.40	

**WF3 Outfall 701
(Dry Cooling Tower Sump #1)**

Month/ Year	PH (s.u.)		TSS (mg/l)	Total Zinc (mg/l)	Oil & Grease (mg/l)	Flow (mgd)	FAC (mg/l)	TOC (mg/l)	Total Chromium (mg/l)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum
<i>LPDES Limit</i>	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>1.0</u>	<u>20</u>	<u>Report</u>	<u>0.5</u>	<u>50</u>	<u>0.2</u>
Oct-15	7.17	7.18	0	(c)	6.26	0.0397	(c)	----	----
Nov-15	7.59	7.61	0	(c)	0	0.061	(c)	----	----
Dec-15	8.01	8.02	0	(c)	5.52	0.016	(c)	3.2 ^(h)	(c)
Jan-16	7.57	7.59	0	(c)	0	0.007	(c)	----	----
Feb-16	7.36	7.36	4.1	(c)	0	0.008	(c)	----	----
Mar-16	7.41	7.43	0	(c)	5.97	0.015	(c)	4.50	----
Apr-16	7.27	7.32	4.2	(c)	5.34	0.019	(c)	----	----
May-16	7.13	7.14	0	(c)	0	0.014	(c)	----	----
Jun-16	6.75	7.12	0	(c)	0	0.017	(c)	11.70	----

c. No discharges occurred.

f. Sample result included in January 2016 Discharge Monitoring Reports.

WF3 Outfall 801
(Dry Cooling Tower Sump #2)

Month/ Year	PH (s.u.)		TSS (mg/l)	Total Zinc (mg/l)	Oil & Grease (mg/l)	Flow (mgd)	FAC (mg/l)	TOC (mg/l)	Total Chromium (mg/l)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum
LPDES Limit	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>1.0</u>	<u>20</u>	<u>Report</u>	<u>0.5</u>	<u>50</u>	<u>0.2</u>
Jan-14	7.31	7.31	5.3	(c)	0	0.0043	(c)	----	----
Feb-14	7.36	7.38	0	(c)	0	0.0093	(c)	----	----
Mar-14	7.02	7.02	0	(c)	0	0.0086	(c)	6.7	----
Apr-14	7.14	7.16	0	(c)	0	0.0062	(c)	----	----
May-14	7.56	7.56	8.3	(c)	0	0.031	(c)	----	----
Jun-14	7.32	7.33	0	(c)	0	0.008	(c)	8.1	----
Jul-14	7.41	7.42	0	(c)	0	0.022	(c)	----	----
Aug-14	7.62	7.63	0	(c)	0	0.008	(c)	----	----
Sep-14	7.64	7.65	0	(c)	0	0.005	(c)	4.0	----
Oct-14	7.34	7.35	0	(c)	0	0.006	(c)	----	----
Nov-14	7.41	7.42	6.0	(c)	0	0.022	(c)	----	----
Dec-14	7.56	7.57	0	(c)	0	0.0186	(c)	3.72	(c)
Jan-15	7.98	7.99	0	(c)	0	0.0162	(c)	----	----
Feb-15	7.65	7.66	4.3	(c)	0	0.0043	(c)	----	----
Mar-15	7.97	7.98	4.9	(c)	0	0.0103	(c)	2.96	----
Apr-15	7.65	7.65	0	(c)	5.37	0.0105	(c)	----	----
May-15	8.11	8.13	0	(c)	0	0.0165	(c)	----	----
Jun-15	7.64	7.65	0	(c)	5.3	0.0197	(c)	6.70	----
Jul-15	7.60	7.61	0	(c)	0	0.0047	(c)	----	----
Aug-15	7.49	7.50	4.2	(c)	5.26	0.0032	(c)	----	----
Sep-15	7.54	7.55	0	(c)	0	0.0109	(c)	1.40	----

**WF3 Outfall 801
(Dry Cooling Tower Sump #2)**

Month/ Year	PH (s.u.)		TSS (mg/l)	Total Zinc (mg/l)	Oil & Grease (mg/l)	Flow (mgd)	FAC (mg/l)	TOC (mg/l)	Total Chromium (mg/l)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum
<i>LPDES Limit</i>	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>1.0</u>	<u>20</u>	<u>Report</u>	<u>0.5</u>	<u>50</u>	<u>0.2</u>
Oct-15	7.96	7.98	13.3	(c)	0	0.0797	(c)	----	----
Nov-15	7.78	7.80	12.1	(c)	6.11	0.091	(c)	----	----
Dec-15	7.73	7.75	0	(c)	5.51	0.020	(c)	2.9 ^(h)	(c)
Jan-16	7.41	7.42	7.1	(c)	0	0.009	(c)	----	----
Feb-16	7.52	7.52	0	(c)	0	0.009	(c)	----	----
Mar-16	7.67	7.67	0	(c)	5.3	0.021	(c)	3.10	----
Apr-16	7.58	7.59	0	(c)	6.0	0.019	(c)	----	----
May-16	6.90	7.07	4.2	(c)	5.92	0.015	(c)	----	----
Jun-16	7.08	7.10	0	(c)	0	0.023	(c)	1.40	----

c. No discharges occurred.

f. Sample result included in January 2016 Discharge Monitoring Reports.

WF3 Outfall 901
(Mobile Metal Cleaning Wastewater)

Year	pH (s.u.)		TSS (mg/l)	Total Copper (mg/l)	Total Iron (mg/l)	Oil & Grease (mg/l)	Flow (mgd)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum
<i>LPDES Limit</i>	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>1.0</u>	<u>1.0</u>	<u>20.0</u>	<u>Report</u>
2014	(c)	(c)	(c)	(c)	(c)	(c)	(c)
2015	(c)	(c)	(c)	(c)	(c)	(c)	(c)
2016	(e)	(e)	(e)	(e)	(e)	(e)	(e)

c. No discharges occurred.

e. No discharges through June 2016.

WF3 Outfall 1001
(Miscellaneous Intermittent Wastewater)

Month/ Year	pH (s.u.)		TSS (mg/l)	Oil & Grease (mg/l)	Flow (mgd)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum
<i>LPDES Limit</i>	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>20</u>	<u>Report</u>
Jan-14	7.23	8.85	10.0	8.2	0.025
Feb-14	7.99	8.15	11.3	7.0	0.0539
Mar-14	7.97	8.35	8.8	6.9	0.0431
Apr-14	8.11	8.12	7.0	7.8	0.0778
May-14	7.62	8.12	14.4	9.4	0.121
Jun-14	7.62	8.12	14.4	9.4	0.121
Jul-14	8.11	8.62	8.5	11.8	0.056
Aug-14	8.34	8.63	10.2	11.6	0.023
Sep-14	8.37	8.57	7.6	6.8	0.031
Oct-14	7.65	8.58	8.7	0	0.029
Nov-14	8.26	8.73	8.0	18.7	0.026
Dec-14	8.12	8.13	12.2	7.7	0.0462
Jan-15	7.84	8.61	9.2	9.5	0.0307
Feb-15	7.85	8.25	7.6	13.1	0.0195
Mar-15	7.87	8.18	0	7.78	0.0235
Apr-15	7.86	8.44	0	10.3	0.0408
May-15	7.69	8.43	0	8.9	0.0520
Jun-15	7.67	8.02	6.1	15.0	0.0565
Jul-15	7.88	8.00	4.7	8.6	0.0237
Aug-15	7.95	8.51	5.3	11.3	0.0171
Sep-15	7.97	8.22	5.9	8.21	0.0247
Oct-15	8.11	8.52	0	10.04	0.1198
Nov-15	7.70	8.06	0	9.07	0.043
Dec-15	7.40	9.00	6.30	10.19	0.066
Jan-16	7.57	8.65	0	9.66	0.022
Feb-16	7.89	8.76	14.9	13.09	0.030
Mar-16	7.77	8.37	10.5	12.6	0.036
Apr-16	7.97	8.56	6.4	11.62	0.045
May-16	7.84	8.02	5.2	7.89	0.037
Jun-16	7.22	8.39	5.5	7.04	0.016

WF3 Outfall 004
(Stormwater Runoff)

Month/ Year	pH (s.u.)		TSS (mg/l)	TOC (mg/l)	Oil & Grease (mg/l)	Flow (mgd)
	Instantaneous Minimum	Instantaneous Maximum	Daily Maximum	Daily Maximum	Daily Maximum	Daily Maximum
LPDES Limit	<u>6.0</u>	<u>9.0</u>	<u>100</u>	<u>50</u>	<u>15</u>	<u>Report</u>
Mar-14	7.14	7.16	8.4	3.96	0	9.72
Jun-14	7.32	7.32	5.4	0	0	12.0
Sep-14	7.51	7.52	7.5	2.8	0	12.8
Dec-14	7.70	7.71	11.3	4.1	0	11.0
Mar-15	7.02	7.12	9.2	5.6	0	6.14
Jun-15	7.94	7.96	8.6	5.0	0	10.60
Sep-15	7.34	7.91	9.4	6.8	0	5.29
Dec-15	7.27	7.28	7.27	5.20	8.76	30.600
Mar-16	7.12	7.13	7.20	4.80	0	6.8
Jun-16	7.88	7.90	9.60	6.50	0	9.76

WF3 Outfall 005
(Energy Education Sewage Plant)

Month/ Year	BOD-5 Day (mg/l)		PH (s.u.)		TSS (mg/l)		Flow (mgd)	Fecal Coliform (colonies/100 ml)	
	Monthly Average	Daily Maximum	Instantaneous Minimum	Instantaneous Maximum	Monthly Average	Daily Maximum	Daily Maximum	Monthly Average	Daily Maximum
<i>LPDES Limit</i>	<u>30</u>	<u>45</u>	<u>6.0</u>	<u>9.0</u>	<u>30</u>	<u>45</u>	<i>Report</i>	<u>200</u>	<u>400</u>
Jun-14	0	0	7.91	7.91	6.0	6.0	0.05	0	0
Dec-14	0	0	7.61	7.65	0	0	0.0458	0	0
Jun-15	4.5	5.8	7.57	7.60	2	4	0.057	0	0
Dec-15	0	0	7.67	7.68	0	0	0.0541	0	0
Jun-16	0	0	7.28	7.34	13.0	13.0	0.041	0	0