



| REVISIONS | | | |
|-----------|-----|--------------|---------------|
| ZONE | LTR | DESCRIPTION | DATE APPROVED |
| | | REVISED DATE | 7/77 |
| | | SEE SHEET 1 | 8-14-78 |

THE TOLEDO EDISON COMPANY
 NUCLEAR FACILITY ENGINEERING
 SAFETY REVIEW

1. NO WORK MAY PROCEED
2. IF WORK AND REQUIRING WORK MAY PROCEED SUBJECT TO INCORPORATION OF CHANGES INDICATED
3. IF REVIEW AND REQUIRING WORK MAY NOT PROCEED
4. IF REVIEW NOT REQUIRED, WORK MAY PROCEED

REQUIREMENT TO PROCEED ON THIS DOCUMENT DOES NOT RELIEVE SUPPLIER FROM FULL COMPLIANCE WITH ALL CONTRACT SPECIFICATION REQUIREMENTS

BY: [Signature]
 DATE: 1-23-78
 CONTROL NUMBER: E-30-42-15

- NOTES:**
1. IF 64A DRILL IS USED TO REPLACE A 64 SUPPLY HOLES MUST BE FIELD DRILLED FOR 6-32 SCREWS. 64A DRILL SHOULD BE MOUNTED WITH MAIN PLATE AND VOLTAGE ADJUST FACING UP.
 2. CONNECTORS 3084310 TO BE INSTALLED ON SUPPORT BAR INSIDE CABINET. TIE-WRAP SHALL BE USED. (APPLIES TO SENSOR CHANNELS #1 THRU #4 ONLY.)

| NO. | DATE | REVISIONS | BY | CHK | SUPV |
|-----|------|---------------------------------------|----|-----|------|
| T5 | | INC DZN E-30-42-14 PER ECK 03-0521-00 | BT | W | TK |

| NO. | DATE | REVISIONS | BY | CHK | ENGR | GEN | SUPV |
|-----|---------|--|-----|-----|------|-----|------|
| 1 | 4/7/77 | INC DZN E-30-42-12 13 PER MOD 93-0051 SUP 0 | DVK | AW | | | |
| 2 | 11/1/80 | INC. VDCN E-30-42-12 (FN 26LA) PER PER 82-135 SUP 0 | RLM | W | CER | WLD | ODS |
| 3 | 4/6/80 | INC. VDCN E-30-42-4, 5, 6, 7, FOR MOD 87-1019 AND GENERAL UPDATE RE-USED NOTES | ETL | W | CER | WLD | ODS |
| 4 | 2/24/87 | AS BUILT FOR FCR 86-135, SUP. 2, INC. VDCN E-30-42-3 | | | | | |

| ITEM NO. | NOMENCLATURE OR DESCRIPTION | DWG SIZE | PART OR IDENTIFYING NO. | SPECIFICATION | MATERIAL OR NOTE | REMARKS |
|---|-----------------------------|----------|-------------------------|---------------|------------------|---------|
| LIST OF MATERIAL | | | | | | |
| UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES .X .XX .XXX ANGLES ±.03 ±.01 ±.008 ±1/32" FRACTIONS & ALL MACH. SURFACES ✓ RUG DRILL HOLES PER ANSI/ASME BURS & SHARP EDGES PER JE131 45° CHAMFER FIRST THREAD TOLERANCES PER UNAS-YANKEE GO/NI TOL APPLY TO STOOD SIZES | | | | | | |
| CONSOLIDATED CONTROLS CORPORATION | | | | | | |
| SAFETY FEATURES ACTUATION SYSTEM | | | | | | |
| DRAWN: J.FOWENS 6-9-78 | | | SCALE 1:4 | | | |
| MATERIAL: | | | FINISH: | | | |
| E-30-42-15 | | | D 02750 9N16 | | | |
| APPLICATION | | | SHEET 2 of 4 | | | |