



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
REGION II
245 PEACHTREE CENTER AVENUE NE, SUITE 1200
ATLANTA, GEORGIA 30303-1257

February 10, 2017

Mr. Joseph W. Shea
Vice President, Nuclear Licensing
Tennessee Valley Authority
1101 Market Street, LP 3R-C
Chattanooga, TN 37402-2801

**SUBJECT: WATTS BAR NUCLEAR PLANT - NOTIFICATION OF INSPECTION AND
REQUEST FOR DOCUMENTS**

Dear Mr. Shea:

During the weeks of March 27 - 31 and April 17 - 21, 2017, the Nuclear Regulatory Commission (NRC) will perform a baseline Radiation Safety Inspection at the Watts Bar Nuclear Plant (NRC Inspection Procedures 71124.01, 71124.02, 71124.03, 71124.04, 71124.05, and 71151). In order to minimize the impact to your on-site resources and to ensure a productive inspection, we have enclosed a request for documents needed for this activity. The NRC requests that these documents be provided to the inspectors no later than March 16, 2017.

We have discussed the schedule for these inspection activities with your staff and understand that our regulatory contact for this inspection will be Gordon Arent (423) 365-2004. If there are any questions about this inspection, or the material requested, please contact the lead inspector, Robert Kellner, at (404) 997-4508, or the Plant Support Branch 1 Chief, Brian Bonser, at (404) 997-4653.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its Enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records component of NRC's Agency Wide Documents Access and Management System (ADAMS). ADAMS is accessible from the NRC web site at <http://www.nrc.gov/reading-rm/adams.html>.

This letter does not contain new or amended information collection requirements subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). Existing information collection requirements were approved by the Office of Management and Budget under control numbers 3150-0008, 3150-0011, 3150-0014, 3150-0044, and 3150-0135. The NRC may not conduct or

sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid Office of Management and Budget control number.

Sincerely,

/RA: Adam Nielsen for/

Brian R. Bonser, Chief
Plant Support Branch 1
Division of Reactor Safety

Docket No. 50-390, 391
License No. NPF-90, NFP-96

Enclosure:
Pre-Inspection Document Request

SUBJECT: WATTS BAR NUCLEAR PLANT - NOTIFICATION OF INSPECTION AND REQUEST FOR DOCUMENTS

Distribution:

R. Kellner, RII
 B. Bonser, RII
 A. Blamey, RII
 C. Kontz, RII
 J. Seat, RII
 RIDSNRRDIRS
 PUBLIC

PUBLICLY AVAILABLE NON-PUBLICLY AVAILABLE SENSITIVE NON-SENSITIVE
 ADAMS: Yes ACCESSION NUMBER: _____ SUNSI REVIEW COMPLETE FORM 665 ATTACHED

OFFICE	RII:DRS	RII:DRS					
SIGNATURE	ADN FOR RXK3	ADN FOR BRB1					
NAME	RKELLNER	BBONSER					
DATE	2/10/2017	2/10/2017					
E-MAIL COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY DOCUMENT NAME: G:\DRSI\PSB1\RFI INFORMATION REQUEST LETTERS\WATTS BAR\2017\WBN_2017001_PSB1-RP RFI LETTER_DRAFT.DOCX

Pre-Inspection Document Request

Occupational Radiation Safety Cornerstone

Inspection Dates: March 27–31, 2017
April 17–21, 2017

Documents Due by: March 16, 2017

Licensee: Watts Bar Nuclear Plant

Docket Number(s): 05000390 and 05000391

Inspection Procedures (IPs):

71124.01	Radiological Hazard Assessment and Exposure Controls
71124.02	Occupational ALARA Planning and Controls
71124.03	In-Plant Airborne Radioactivity Control and Mitigation
71124.04	Occupational Dose Assessment
71124.05	Radiation Monitoring Instrumentation
71151	Performance Indicator Verification

Lead Inspector: Robert Kellner
Sr. Health Physicist
US NRC Region II
(404) 997-4508
Robert.Kellner@nrc.gov

Note: Unless specified otherwise, the current version of these documents is expected. Electronic media is preferred if readily available (the preferred file format is MSWord, or searchable “.pdf” files on CDROM). *[Note that the inspectors cannot accept data provided on USB or “flash” drives due to NRC IT security policies.]* To the extent possible, please organize the information in the order shown below. Experience has shown that a poorly organized CD leads to a less efficient inspection, and places additional burden on licensee staff. Pay particular attention to the date ranges for the items requested as they may change from item to item. If there are questions regarding the documents requested, or if the documents cannot be provided by the due date, please do not hesitate to contact the lead inspector.

Documentation from October 25, 2015, to the present is requested for all procedures, except 71124.01 and 71151, which should be from August 1, 2016, to present. This reflects the last time these areas were inspected. We would prefer as much of the information as possible in electronic form. An index to the CD contents is also helpful. For those items requesting a list of items, the inspector will select items from the list for onsite review.

General and Miscellaneous Information

- List of primary site contact(s) for each inspection area including name(s) and telephone numbers.
- List of radiation protection procedures, including title and number.

Enclosure

- Plant Management, Radiation Protection, and Chemistry organizational charts w/ contact numbers
- Outage schedule, including work activities to be conducted during the week(s) of the inspection
- Most recent DAW 10 CFR Part 61 analytical results
- Corrective Action Program procedure(s)

71124.01 - Radiological Hazard Assessment and Exposure Controls

(Last Inspected August 2016)

1. List of active Radiation Work Permits (RWPs), including outage RWPs, with their administrative limits, electronic dosimeter dose rate limit, and dose limit.
2. List of locations, or plant maps indicating the location, of all LHRAs and VHRAs. Include areas with the potential to become a LHRA during routine operations or outages.
3. Most recent survey of all Locked HRAs and VHRAs (as applicable).
4. Independent spent fuel storage installation (ISFSI) information to include surveys, exposure data, as low as reasonably achievable (ALARA) planning and reviews conducted for the last two moves. Also, the last two routine surveys of the facility and any Thermoluminescent Dosimeter area monitoring results for the facility.
5. Procedures related to HP controls (e.g. Posting, labeling, surveys, RWPs, contamination control, HRA/LHRA/VHRA control, key control, control of divers, special controls during fuel offload, hot spots, etc.).
6. Procedures related to release of personnel and materials (e.g. release surveys, decontamination, guidance for alarm follow up, etc.).
7. List of Nationally Tracked Sources, change of ownership and copies of any National Source Tracking System transaction documentation (e.g., annual reconciliation).
8. Most recent sealed source inventory record.
9. List of all non-fuel items stored in spent fuel pool.
10. All self-assessments and audits covering HP controls since August 1, 2016.
11. List of CRs related to HP controls where the cause was listed as human performance (radworker error) or human performance (HP technician error) issued since August 1, 2016. *This should be a list of corrective action documents containing a CR number and brief description, not full CRs.*
12. All CRs related to Nationally Tracked Sources since August 1, 2016.

71124.02 - ALARA Planning and Controls

(Last Inspected October 2015)

1. Site and corporate procedures associated with maintaining site dose ALARA, including those involving ALARA work activities. These procedures should include:
 - ALARA program implementation, including ALARA committee activities and ALARA planning, briefing, and reviews
 - Radiation work permit preparation and worker compliance
 - Processes used to estimate and track work activity specific exposures
 - Making changes to dose estimates during task performance
 - Work controls
 - Engineering controls
 - Exposure mitigation requirements

2. List of top five dose jobs for the upcoming refueling outage and ALARA planning packages (including dose estimates, work-hour estimates, special HP controls, and dose reduction initiatives).
3. Most recent annual ALARA report and most recent refueling outage report.
4. Annual ALARA goals for 2016 and 2017, and the methodology utilized to make the projections.
5. ALARA Committee activity summaries (e.g. meeting minutes) discussing activities associated with the upcoming refueling outage.
6. Outline of the source term reduction strategy. Information should include:
 - Historic trends and current status of plant source term
 - Factors that affect the source term
 - Activities employed to reduce the source term
 - Specific sources identified for reduction actions
 - Source term reduction evaluation
 - Results achieved since October 2015.
7. Audits and self-assessments performed since October 25, 2015 concerning the ALARA program and its implementation.
8. List of corrective action reports generated since October 25, 2015, related to the ALARA program (*this should be a list of corrective action documents containing a CR number and brief description, not full CRs*), including the following:
 - ALARA planning
 - Post-job review identified problems
 - Radiation worker practices
 - Occurrences where the collective exposure was greater than intended dose determined to be ALARA for the individual work activities
9. Available for onsite review during the inspection:
 - ALARA planning packages for jobs to be performed during the outage
 - Temporary shielding requests generated for the outage
 - Completed ALARA packages (including post-job reviews) for the five work activities that were completed during the last outage that had the greatest collective dose, and/or presented significant radiological risk.

71124.03 - In-Plant Airborne Radioactivity Control and Mitigation

(Last Inspected October 2015)

1. Site and corporate procedures/manuals associated with airborne radiation monitoring instrumentation and respiratory protection. Procedures/manuals should include:
 - Operation, calibration, and maintenance of air sampling instrumentation, including set-point determination (e.g., low-vols, high vols, goosenecks, AMS 4s, etc.)
 - Calibration and maintenance of portable instruments
 - Actions to be taken when air sampling instrumentation is found to be significantly out of tolerance/calibration
 - Issuance and use of respiratory protective equipment (emphasis on SCBA and air-supplied equipment)
 - Total Effective Dose Equivalent-ALARA evaluation guidance
 - Training, including fit-testing, for use of SCBA and supplied-air systems
 - SCBA maintenance activities, including vital components (i.e. regulators)
 - Determination/verification of Grade D air for SCBA

2. Two most recent HEPA filter DOP and charcoal test results or the following ventilation systems:
 - Main Control Room
 - Auxiliary Building Ventilation Exhaust
 - Unit 1 Post accident Sampling Facility (PASF) Environmental Control System
3. Records of certification of air quality for equipment used to provide breathing air for air-supplied respirators and SCBA bottles (air compressors and bottled breathing air) since October 25, 2015.
4. Documentation for last two surveillances performed on SCBA stored for emergency use.
5. Audits and self-assessments performed since October 25, 2015 of the respiratory protection program, airborne radioactivity monitoring, and/or mitigation and engineering controls.
6. List of corrective action reports generated since October 25, 2015 involving radiation monitoring and protective equipment deficiencies, including the following:
 - Continuous air monitors
 - Respiratory protection equipment and program implementation
7. Available for onsite review by inspector during inspection:
 - Inventory, inspection, and maintenance records for SCBA equipment
 - Training records, including fit-testing, for SCBA-qualified individuals
 - i. List of all licensed operators qualified to use SCBA
 - ii. List of all instrumentation and control personnel qualified to use SCBA
 - iii. List of all HP personnel qualified to use SCBA
 - Training records/certification for individuals qualified to perform maintenance on vital components (e.g. regulators) on SCBA

71124.04: Occupational Dose Assessment

(Last Inspected October 2015)

1. Site and corporate Procedures/Guidance Documents for external dose monitoring, i.e. dosimetry issuance and use. The documents should include:
 - Guidance for multi-badging; monitoring in steep/highly variable dose rate gradients
 - Personnel contamination events; storage/care of personal dosimeters; use of electronic dosimeters including evaluation of any biases identified relative to TLD monitoring
 - Internal dose assessment, i.e., both *in vivo* and *in vitro* bioassay and air sampling capabilities. The documents should include guidance for calibration/QC and use of whole body counter (WBC); release of contaminated individuals, use of passive monitoring as screening method for evaluations, and special *in vitro* sample collection and analysis, and actions for declared pregnant workers
2. NVLAP accreditation documentation for current dosimetry used by the site.
3. List of all positive whole body count (WBC), *in vitro*, or air sampling analyses which resulted in an assigned CEDE equal to, or exceeding, 10 millirem since October 25, 2015. [Note: only a listing should be provided for use by the inspectors to select a sample of issues for in-depth review during the onsite inspection].
4. List of all personnel contamination events, dispersed contamination/discrete particles, identified since October 25, 2015. [Note: only a listing should be provided for use by the inspectors to select a sample of issues for in-depth review during the onsite inspection].
5. Copies of all audits, self-assessments, and/or reviews related to internal or external dosimetry issues generated since October 25, 2015. The documents provided should

include any reviews/evaluations conducted of vendor facilities, e.g., corporate or outside vendor/ or corporate calibration facilities.

6. List of Condition Reporting (CR) documents generated since October 25, 2015, for internal or external dosimetry issues/events. *[Note: only titles and a summary statement should be provided for use by the inspectors to select a sample of issues for in-depth review].*

71124.05 - Radiation Monitoring Instrumentation

(Last Inspected October 2015)

1. Procedures/Guidance Documents for:
 - use of portable instrument calibrators (e.g. Shepherd calibrator)
 - calibration and functional test/source checks of portable radiation detection instrumentation
 - calibration and functional tests of small article monitor (SAM), personnel contamination monitor (PCM), portal monitor (PM), whole body counting (WBC) equipment; and continuous air monitors (CAMs)
 - determination of set-points for Area Radiation Monitor (ARM), CAM, PCM, PM and SAM equipment
 - collection and analysis of high-range, post- accident effluent samples
 - QA program for count room instruments (e.g. laboratory inter-comparison data)
2. The last two calibration records for the following monitors:
 - 1-RE-90-7/2-RE-90-7 Sample Room ARM
 - 1-RE-90-272 RB Upper Comp Post Accident
 - 1-RE-90-273 RB Lower Comp Post Accident
 - 0-RE-90-135 Main Control Room Area Radiation Monitor.
3. Documentation for the radioactive sources used to calibrate the instruments in item 2 above, including paperwork showing traceability to a National Institute of Standards & Technology standard and/or traceability to the primary calibration, as applicable.
4. The last two surveillances performed on the Post-accident Sampling System, as applicable if it is still required in the plant technical specifications.
5. The last two test records of the instrument calibrator (Shepherd validation testing/dose rate curves).
6. List of the portable instruments currently in service and available for use. Several will be selected for on-site review of the calibration records.
7. List of the following radiation monitors currently in service. Several will be selected for on-site review of the calibration records.
 - Portal Monitors used in Dosimetry for Passive Monitoring
 - SAMs at RCA exit point
 - Whole Body Contamination Monitors at RCA exit point
 - Portal Monitors at RCA exit point
 - Countroom High-purity Germanium and liquid scintillation systems
8. Documentation for the radioactive sources used to calibrate the monitors requested for item 7 above showing traceability to a national standard (NIST).
9. Chart or procedure listing any Emergency Action Level (EAL) value associated with installed or portable radiation monitoring instrument indication(s).
10. Latest system health report for the Radiation Monitoring system.
11. List of installed area and airborne radiation and/or radioactivity monitors (System 90) that were Out of Service during the last year. Include OOS dates.

12. Most recent Whole Body Counter (WBC) calibration record, documentation of calibration source traceability to NIST, and copies of WBC libraries.
13. Audits and self-assessments performed since October 25, 2015 of radiological monitoring instrumentation (portable, installed, and counting room instruments).
14. List of CRs generated since October 25, 2015, related to portable instruments, area monitors, CAMs, WBCs, and count room instruments. *This should be a list of corrective action documents containing a CR number and brief description, not full CRs.*

71151 – Performance Indicator (PI) Verification

(Last Inspected August 2016)

1. Site procedures/manuals for gathering and reporting PI data.
2. Monthly/Quarterly PI reports since August 1, 2016, and copies of associated condition reports for any RETS/ODCM Radiological Effluent occurrences.
3. End of calendar year (CY) 2016 liquid and gaseous effluent release permits which specify the monthly, quarterly, and annual curies released by isotope, and associated public dose assessments.
4. List of all corrective action documents since August 1, 2016, using keywords such as: HRA, LHRA, VHRA, unintended dose, unlocked door, etc.
5. List of all electronic dosimeter (ED) dose rate alarms and ED dose alarms since August 1, 2016 which includes dose or dose rate alarm received, and the alarm setpoint(s).
6. List of all corrective action reports generated since August 1, 2016, using keywords abnormal/ unmonitored effluent release, etc.

Assistance Requested During On-Site Inspection

- Identification of work activities available during the inspection for inspector observations, including notification of pre-job briefings, notification of risk significant work activities, and audio/visual surveillance for remote job coverage
- HP assistance as needed of plant walkdowns assessing access controls, verifying posting and locking of entrances to high and very high radiation areas (HRA and VHRA), SFP controls, and the ISFSI.

Inspector Contact Information:

Robert Kellner
 (404) 997-4508
robert.kellner@nrc.gov

Mailing Address

US Nuclear Regulatory Commission, Region II
 ATTN: Robert Kellner
 245 Peachtree Center Ave., NE
 Suite 1200
 Atlanta, GA 30303