



NOTE:
 1. FIELD TO INSTALL A 1 MICROFARAD 250V CAPACITOR ACROSS TERMINALS.

REFERENCE DWG'S.
 D8047555-LEGEND & REFERENCE DWG'S.
 D8047543-EXTERNAL
 D8047544-EXTERNAL

NO.	DATE	REVISIONS	BY	CHK'D	ENGR.	GEN. SUPV.
T3		GENERAL UPDATE: ADD PROPRIETARY NOTE REFERENCE BACK (NOT CARRIED FORWARD AT T2 UPDATE) PER REVIEW OF HISTORY RECORD FOR PREVIOUS SUBMITTAL. (REF. CR 2012-08589).				

SCHMATIC DIAGRAM
 POWER DISTRIBUTION
 SUBASSEMBLY "C"

CUSTOMER: TOLEDO EDISON COMPANY
 PLANT: DAVIS-BESSE NUCLEAR, UNIT #1
 CONTRACTING ENG.: BECHTEL
 B.M. CO. JOB NO.: 1220M

INC. DCN M-536-57-5 PER ECR 05-0192-02		INITIALS ON FILE	
NO.	DATE	REVISIONS	BY
SCALE NONE		RESTORED N/A	DATE 5-16-08
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1			
SCHMATIC DIAGRAM POWER DISTRIBUTION SUBASSEMBLY "C"			
BARCOCK & WELCO, U.S.A. BAILEY METER COMPANY		SHEET NO.	REV.
D8047584E			T3

7749-M-536-57-8-7

THIS DRAWING WAS REDRAWN ON
 CAD AND SUPERSEDES SUBMITTAL 5.

THIS DRAWING IS THE PROPERTY OF BAILEY METER COMPANY
 NEITHER THE DRAWING, NOR REPRODUCTION OF IT, NOR
 INFORMATION DERIVED FROM IT IS TO BE GIVEN TO OTHERS.
 NO USE IS TO BE MADE OF IT WHICH IS OR MAY BE INJURIOUS
 TO BAILEY METER COMPANY.

FENOC

020592LJ,
 CUST. ORDER NO.: 620-0014