

TABLE 15.1-1

NUCLEAR STEAM SUPPLY SYSTEM POWER RATINGS

Guaranteed Nuclear Steam Supply System thermal power output	3471 MWt
The Engineered Safety Features design rating (maximum calculated turbine rating)	3577 MWt
Thermal power generated by the reactor coolant pumps (nominal)	12 MWt
Guaranteed Core Thermal Power	3459 MWt

TABLE 15.1-2

SUMMARY OF INITIAL CONDITIONS AND COMPUTER CODES USED

Faults	Computer Codes Utilized	Reactivity Coefficients Assumed		Doppler(2)	Initial NSSS Thermal Power Output Assumed (MWt)
		Moderator Temperature(1) ($\Delta k/^\circ F$)	Moderator Density(1) ($\Delta k/gm/cc$)		
CONDITION II					
Uncontrolled RCC Assembly Bank Withdrawal from a Subcritical Condition	TWINKLE, FACTRAN + 5×10^{-5} THINC	---	---	Lower	0
Uncontrolled RCC Assembly Bank Withdrawal at Power	LOFTRAN	---	0 and 0.52	Lower and upper	3431 ⁽³⁾ 2058.6 and 343.1
RCC Assembly Misalignment	THINC, ANC, LOFTRAN	---	0	Upper	3411 ⁽⁴⁾
Uncontrolled Boron Dilution	NA	NA	NA	NA	0 and 3423
Partial Loss of Forced Reactor Coolant Flow	LOFTRAN THINC, FACTRAN	---	0	Upper	3431
Start-up of an Inactive Reactor Coolant Loop	---	---	---	---	---
Loss of External Electrical Load and/or Turbine Trip	LOFTRAN	---	0 and 0.52	Lower and Upper	3423 (DNB Cases) 3491.5 (Pressure Cases) ⁽⁵⁾
Loss of Normal Feedwater	LOFTRAN	---	NA	NA	3491.5 ⁽⁵⁾

TABLE 15.1-2 (Cont)

<u>Faults</u>	<u>Computer Codes Utilized</u>	<u>Reactivity Coefficients</u>		<u>Doppler(2)</u>	<u>Initial NSSS Thermal Power Output Assumed (MWt)</u>
		<u>Assumed Moderator Temperature(1) ($\Delta k/^\circ F$)</u>	<u>Assumed Moderator Density(1) ($\Delta k/gm/cc$)</u>		
CONDITION II (cont'd)					
Loss of Offsite Power to the Plant Auxiliaries	LOFTRAN	---	NA	NA	3491.5 ⁽⁵⁾
Excessive Heat Removal Due to Feedwater System Malfunctions	LOFTRAN	---	0.52	Lower	0 and 3411 ⁽⁶⁾
Excessive Load Increase	LOFTRAN	---	0 and 0.52	Lower	3411 ⁽⁶⁾
Accidental Depressurization of the Reactor Coolant System	LOFTRAN	---	0	Upper	3411 ⁽⁶⁾
Accidental Depressurization of the Main Steam System	LOFTRAN	---	Function of Moderator Density (See Sec 15.2.13) (Fig 15.2-41)	Fig. 15.4-49	0 (Subcritical)
Inadvertent Operation of ECCS During Power Operation	LOFTRAN	---	0	Lower	3491.5 ⁽⁵⁾

TABLE 15.1-2 (Cont)

Reactivity Coefficients

<u>Faults</u>	<u>Computer Codes Utilized</u>	<u>Assumed Moderator Temperature(1) ($\Delta k/^\circ F$)</u>	<u>Moderator Density(1) ($\Delta k/gm/cc$)</u>	<u>Doppler(2)</u>	<u>Initial NSSS Thermal Power Output Assumed (MWt)</u>
CONDITION III					
Loss of Reactor Coolant from Small Ruptured Pipes or from Cracks in Large Pipe which Actuate Emergency Core Cooling	NOTRUMP, SBLOCTA				3479
Inadvertent Loading of a Fuel Assembly into an Improper Position	PHOENIX-P, ANC	---	NA	NA	3216-3563 ⁽⁴⁾
Complete Loss of Forced Reactor Coolant Flow	LOFTRAN THINC, FACTRAN	---	0	Upper	3431
Waste Gas Decay Tank Rupture	NA	---	NA	NA	3577
Single RCC Assembly Withdrawal at Full Power	ANC, THINC PHOENIX-P	---	NA	NA	3423
CONDITION IV					
Major rupture of pipes containing reactor coolant up to and including double-ended rupture of the largest pipe in the Reactor Coolant System (Loss of Coolant Accident)	SATAN BASH COCO LOCBART		Function of Moderator Density (See Section 15.4.1)	Function of Fuel Temp. (See Section 15.4.1)	3579

TABLE 15.1-2 (Cont)

<u>Faults</u>	<u>Computer Codes Utilized</u>	<u>Reactivity Coefficients Assumed</u>		<u>Doppler(2)</u>	<u>Initial NSSS Thermal Power Output Assumed (MWt)</u>
		<u>Moderator Temperature(1) ($\Delta k/^\circ F$)</u>	<u>Moderator Density(1) ($\Delta k/gm/cc$)</u>		
CONDITION IV (cont)					
Major Secondary System Pipe Rupture, up to and Including Double-Ended Rupture (Rupture of a Steam Pipe)	LOFTRAN, THINC	Function of Moderator Density (See Section 15.2.13) (Fig. 15.4-50 Unit 1) (Fig. 15.4-48 Unit 2)		Fig. 15.4-49	0 (Subcritical)
Steam Generator Tube Rupture	NA	NA	NA	NA	3577
Single Reactor Coolant Pump Locked Rotor and Reactor Coolant Pump Shaft Break	LOFTRAN THINC, FACTRAN	---	0	Upper	3431
Fuel Handling Accident	NA	NA	NA		3600
Rupture of a Control Rod	TWINKLE, FACTRAN	-0 pcm/ $^\circ F$ BOL	---	Consistent	0 and 3479 (7)
Mechanism Housing (RCCA Ejection)	PHOENIX-P	-26 pcm/ $^\circ F$ EOL		with lower limit shown on Fig 15.1-5	

NOTES:

- (1) Only one is used in an analysis, i.e., either moderator temperature or moderator density coefficient.
- (2) Reference Figure 15.1-5 for Doppler power coefficients. See UFSAR Section 4.5 for the applicable station reload analysis.
- (3) Cases are considered at 3 different initial power levels - 100%, 60%, and 10%.
- (4) Core power is assumed in the analysis.
- (5) Analysis is performed at 102% of an NSSS power of 3423 MWt which is equivalent to 100.6% of 3471 MWt.
- (6) No pump heat is assumed in the analysis.
- (7) Analysis is performed at 102% of a core power of 3411 MWt which is equivalent to 100.6% of 3459 MWt.

TABLE 15.1-3

TRIP POINTS AND TIME DELAYS TO TRIP ASSUMED IN ACCIDENT ANALYSIS

<u>Trip Function</u>	<u>Limiting Trip Point Assumed In Analyses</u>	<u>Time Delay (sec)</u>
Power range high neutron flux, high setting	118 percent	0.5
Power range high neutron flux, low setting	35 percent	0.5
Overtemperature ΔT	Variable, see Figure 15.1-1	7.0(1) (Ref.21)(2)
Overpower ΔT	Variable, see Figure 15.1-1	7.0(1) (Ref.21)
High pressurizer pressure	2425 psig	2.0
Low pressurizer pressure	1825 psig	2.0
Low reactor coolant flow (from loop flow detectors)	87-percent loop flow	1.0
Undervoltage trip	68 percent nominal	1.5
Turbine trip	Not Applicable	1.0
Low-low steam generator level	0 percent of Narrow Range Level Span	2.0
High steam generator level trip of feedwater pumps and closure of feedwater system valves, and turbine trip	73 percent of Narrow Range Level Span	2.0
Underfrequency trip	53.9 Hz	0.6
Loss of offsite power time delay	Not Applicable	1.5 (3)

NOTES:

- (1) Total time delay (including RTD response time and trip circuit channel electronics delay) from the time the temperature difference in the coolant loops exceeds the trip setpoint at the channel sensor until the rods begin to drop.
- (2) See Reference 21, Section 15.1.10.
- (3) From rod motion

TABLE 15.1-4

DETERMINATION OF MAXIMUM OVERPOWER TRIP POINT - POWER RANGE NEUTRON FLUX CHANNEL - BASED ON NOMINAL SETPOINT CONSIDERING INHERENT INSTRUMENTATION ERRORS

Nominal Setpoint (percent of rated power) 109

Calorimetric Errors in the Measurement of Secondary System Thermal Power:

<u>Variable</u>	<u>Accuracy of Measurement of Variable (Percent Error)</u>	<u>Estimated Effect on Thermal Power Determination (Percent Error)</u>
Feedwater temperature	<u>+0.5</u>	
Feedwater pressure (small correction on enthalpy)	<u>+0.5</u>	0.3
Steam pressure (small correction on enthalpy)	<u>+2</u>	
Feedwater flow	<u>+1.25</u>	1.25

Assumed calorimetric error (percent of rated power) 2

Axial power distribution effects on total ion chamber current

Estimated error (percent of rated power) 3

Assumed error (percent of rated power) 5

Instrumentation channel drift and setpoint reproducibility

Estimated error (percent of rated power) 1

Assumed error (percent of rated power) 2

Maximum overpower trip point assuming all individual errors are simultaneously in the most adverse direction (percent of rated power) 118

TABLE 15.1-5

THIS TABLE HAS BEEN DELETED

TABLE 15.1-6

THIS TABLE HAS BEEN DELETED