



Bentley K. Jones
Director, Organizational Effectiveness
Harris Nuclear Plant
5413 Shearon Harris Road
New Hill, NC 27562-9300

919.362.2305

FEB 16 2017

Serial: HNP-17-014

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Shearon Harris Nuclear Power Plant, Unit 1
Docket No. 50-400/Renewed License No. NPF-63

Subject: Annual Report in Accordance with Technical Specifications, Section 6.9.1.2

Ladies and Gentlemen:

In accordance with Shearon Harris Nuclear Power Plant, Unit 1 (HNP), Technical Specifications, Section 6.9.1.2, Duke Energy Progress, LLC, is providing the following information regarding reactor coolant specific activity for 2016.

During 2016, specific activity of the HNP reactor coolant did not exceed 1.0 $\mu\text{Ci}/\text{gram}$ dose equivalent I-131 or 100/E-bar $\mu\text{Ci}/\text{gram}$ gross radioactivity as set forth in Technical Specifications, Section 3.4.8.

This submittal contains no regulatory commitments. Please refer any questions regarding this submittal to Jeff Robertson, Manager – Regulatory Affairs, at (919) 362-3137.

Sincerely,

A handwritten signature in blue ink that reads 'Bentley K. Jones'.

Bentley K. Jones

cc: Mr. R. Patterson, NRC Sr. Resident Inspector, HNP
Ms. M. Barillas, NRC Project Manager, HNP
NRC Regional Administrator, Region II



Bentley K. Jones
Director, Organizational Effectiveness
Harris Nuclear Plant
5413 Shearon Harris Road
New Hill, NC 27562-9300

919.362.2305

Serial: HNP-17-014

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Shearon Harris Nuclear Power Plant, Unit 1
Docket No. 50-400/Renewed License No. NPF-63

Subject: Annual Report in Accordance with Technical Specifications, Section 6.9.1.2

Ladies and Gentlemen:

In accordance with Shearon Harris Nuclear Power Plant, Unit 1 (HNP), Technical Specifications, Section 6.9.1.2, Duke Energy Progress, LLC, is providing the following information regarding reactor coolant specific activity for 2016.

During 2016, specific activity of the HNP reactor coolant did not exceed 1.0 $\mu\text{Ci}/\text{gram}$ dose equivalent I-131 or 100/E-bar $\mu\text{Ci}/\text{gram}$ gross radioactivity as set forth in Technical Specifications, Section 3.4.8.

This submittal contains no regulatory commitments. Please refer any questions regarding this submittal to Jeff Robertson, Manager – Regulatory Affairs, at (919) 362-3137.

Sincerely,

Bentley K. Jones

cc: Mr. R. Patterson, NRC Sr. Resident Inspector, HNP
Ms. M. Barillas, NRC Project Manager, HNP
NRC Regional Administrator, Region II