

David B. Hamilton
Vice President

440-280-5382

January 23, 2017
L-17-020

10CFR50.4, 10CFR50.54(q), 10CFR72.44(f)

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555-0001Perry Nuclear Power Plant
Docket No. 50-440, License No. NPF-58
EMERGENCY PLAN FOR PERRY NUCLEAR POWER PLANT DOCKET No's. 50-440

Pursuant to 10CFR50.4, enclosed is a summary of changes for Rev. 49 to the Emergency Plan for the Perry Nuclear Power Plant (PNPP).

The changes have been reviewed in accordance with 10CFR50.54 (q), and it has been determined that the changes do not result in a reduction of the effectiveness of the Emergency Plan. It has also been determined that the Plan, as changed, continues to meet the standards of 10CFR50.47 (b) and 10CFR50 Appendix E.

There are no regulatory commitments contained in this letter. If there are any questions or if additional information is required, please contact Mr. Rick O'Connor, Manager, Emergency Response Section, at (440) 280-5693.

Sincerely,



David Hamilton

Enclosure:
Summary of ChangesAX45
NRR

Perry Nuclear Power Plant
L-17-020
Page 2

cc: United States Regulatory Commission
United States Nuclear Regulatory Commission Document Control Desk
U.S. Nuclear Regulatory Commission NRC Project Manager
United States Environmental Protection Agency, Mr. Steve Ostrodka, Chief
Division of Spent Fuel Storage and Transportation Office of Nuclear Material Safety
and Safeguards NRC Regional Response Center
Regional Administrator United States Nuclear Regulatory Commission, Region III -
Incident Response Center

Enclosure
L-17-020

Summary of Changes

ENCLOSURE

Perry Nuclear Power Plant EP 0000 Revision 49 Change Summary

Revision 49 of EP 0000, Emergency Plan for Perry Nuclear Power Plant Docket Nos. 50-440 contained the following change.

Changes were made in PNPP Emergency Plan training requirements for individuals needing unescorted access. An industry initiative changed the frequency for plant access training (PAT) from annually to two (2) years for contractors and four (4) years for plant personnel. The emergency plan training content for individuals needing unescorted access was imbedded in PAT. Annual emergency plan training is required for individuals needing unescorted access.

References to PAT were removed from the emergency plan while retaining the annual emergency plan training frequency and content for individuals needing unescorted access.

The removal of the plant access training reference from the emergency plan was evaluated in 10CFR50.54(q) PY-2016-016-00 and found to be consistent with 10CFR50.47(b) and 10CFR50, Appendix E requirements and not cause a reduction in effectiveness of the Emergency Plan.