

February 21, 2017

MEMORANDUM TO: Robert J. Pascarelli, Chief
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

FROM: Robert G. Lukes, Chief */RA/*
Nuclear Performance and Code Review Branch
Division of Safety Systems
Office of Nuclear Reactor Regulation

SUBJECT: PLAN FOR SECOND AUDIT SUPPORTING U.S. NUCLEAR
REGULATORY COMMISSION REVIEW OF "PALO VERDE
NUCLEAR GENERATING STATION, UNITS 1, 2, AND
3 – TRANSITION TO COMBUSTION ENGINEERING 16X16
NEXT GENERATION FUEL AND REVISED TECHNICAL
SPECIFICATIONS 5.6.5 AND 4.2.1" (CAC NOS. MF8076,
MF8077, MF8078, MF8079, MF8080, AND MF8081)

By application dated July 1, 2016, Arizona Public Service requested changes to the Technical Specifications (TS) for Palo Verde Nuclear Generating Station (PVNGS), Units 1, 2, and 3. The proposed changes revise TS 4.2.1, "Reactor Core, Fuel Assemblies" and 5.6.5.b, "Core Operating Limits Report (COLR)" and will allow the use of Combustion Engineering 16x16 Next Generation Fuel clad with the Optimized ZIRLO™ material in PVNGS, Units 1, 2, and 3.

The staff are proposing a second regulatory audit at this point in the review process to focus the staff's requests for additional information and enhance technical understanding of the submitted documentation. A proposed audit plan is attached.

Docket Nos.: 50-528
50-529
50-530

Enclosure:
As stated

CONTACT: Daniel R. Beacon, NRR/DSS
301-415-2820

MEMORANDUM TO: Robert J. Pascarelli, Chief
 Plant Licensing Branch IV
 Division of Operating Reactor Licensing
 Office of Nuclear Reactor Regulation

FROM: Robert G. Lukes, Chief */RA/*
 Nuclear Performance and Code Review Branch
 Division of Safety Systems
 Office of Nuclear Reactor Regulation

SUBJECT: PLAN FOR SECOND AUDIT SUPPORTING U.S. NUCLEAR REGULATORY COMMISSION REVIEW OF "PALO VERDE NUCLEAR GENERATING STATION, UNITS 1, 2, AND 3 – TRANSITION TO COMBUSTION ENGINEERING 16X16 NEXT GENERATION FUEL AND REVISED TECHNICAL SPECIFICATIONS 5.6.5 AND 4.2.1" (CAC NOS. MF8076, MF8077, MF8078, MF8079, MF8080, AND MF8081)

By application dated July 1, 2016, Arizona Public Service requested changes to the Technical Specifications (TS) for Palo Verde Nuclear Generating Station (PVNGS), Units 1, 2, and 3. The proposed changes revise TS 4.2.1, "Reactor Core, Fuel Assemblies" and 5.6.5.b, "Core Operating Limits Report (COLR)" and will allow the use of Combustion Engineering 16x16 Next Generation Fuel clad with the Optimized ZIRLO™ material in PVNGS, Units 1, 2, and 3.

The staff are proposing a second regulatory audit at this point in the review process to focus the staff's requests for additional information and enhance technical understanding of the submitted documentation. A proposed audit plan is attached.

Docket Nos.: 50-528
 50-529
 50-530

Enclosure:
 As stated

CONTACT: Daniel R. Beacon, NRR/DSS
 301-415-2820

DISTRIBUTION: RLukes SLingam MMarkley JLehning RidsNrrPMPaloVerde
 DBeacon

Accession No.: ML17048A496 NRR-106

OFFICE	NRR/DSS/SNPB	NRR/DSS/SNPB	NRR/DSS/SNPB: BC
NAME	DBeacon	JLehning	RLukes
DATE	02/21/2017	02/21/2017	02/21/ 2017

OFFICIAL RECORD COPY

**SECOND REGULATORY AUDIT SUPPORTING U.S. NUCLEAR REGULATORY
COMMISSION REVIEW OF “PALO VERDE NUCLEAR GENERATING STATION, UNITS 1, 2,
AND 3 – TRANSITION TO COMBUSTION ENGINEERING 16X16 NEXT GENERATION FUEL
AND REVISED TECHNICAL SPECIFICATIONS 5.6.5 AND 4.2.1”**
DOCKET NOS.: 50-528, 50-529, AND 50-530

BACKGROUND

By application dated July 1, 2016, Arizona Public Service (APS) requested changes to the Technical Specifications (TS) for Palo Verde Nuclear Generating Station (PVNGS), Units 1, 2, and 3. The proposed changes revise TS 4.2.1, “Reactor Core, Fuel Assemblies” and 5.6.5.b, “Core Operating Limits Report (COLR)” and will allow the use of Combustion Engineering (CE) 16x16 Next Generation Fuel (NGF) clad with the Optimized ZIRLO™ material in PVNGS, Units 1, 2, and 3. To support the fuel transition, APS also requested an exemption from certain requirements of Title 10 of the *Code of Federal Regulations* (10 CFR) 50.46 and 10 CFR 50 Appendix K to allow the use of Optimized ZIRLO™ as a cladding material in PVNGS.

The U.S. Nuclear Regulatory Commission (NRC) staff conducted a regulatory audit on November 2nd and 3rd, 2016 to focus the staff’s requests for additional information (RAIs) and enhance technical understanding of the submitted documentation. During this audit, it was determined that further time would be needed to examine materials related to the statistical methodology proposed for analyzing the fuel assembly misload event and the use of the SKBOR code in the boric acid precipitation analysis that were provided during the audit, but not originally available as part of the submittal. Additionally, the NRC staff requested justification for the proposed penalty to address the lack of treatment of thermal conductivity degradation (TCD) in the FATES-3B code.

Therefore, the NRC staff has proposed to conduct a second regulatory audit at this point in the review process in an effort to resolve or focus the questions that arose from further consideration of the outstanding issues and to observe the justification for the proposed TCD penalty. This audit will help the NRC staff better understand the supporting documentation and analysis results through interaction with APS’s technical experts and will help to focus the staff’s RAIs on those questions where docketed information is needed to complete the review.

The proposed audit will be held in accordance with Office of Nuclear Reactor Regulation (NRR) procedure as described in LIC-111, “Regulatory Audits.”

REGULATORY AUDIT SCOPE

The NRC staff would like APS to make available appropriate staff with detailed knowledge of the PVNGS licensing basis and the related topical reports, the statistical methods used in the fuel assembly misload methodology, and the SKBOR boric acid precipitation analysis method. Additionally, APS staff should be prepared to present and answer questions about the justification for the proposed TCD penalty.

ENCLOSURE

Discussion at the audit is expected to pertain to a limited scope of the submittal, specifically including the following subjects and related points of discussion:

- Boric acid precipitation analysis methodology (SKBOR)
- Statistical treatment of the inadvertent fuel assembly misload event
- Justification for the proposed penalty to FATES-3B to account for the lack of TCD treatment

TEAM AND REVIEW ASSIGNMENTS

Siva Lingam, Project Manager (NRR/DORL/LPL4-1)
Daniel Beacon, Technical Reviewer (NRR/DSS/SNPB)
John Lehning, Technical Reviewer (NRR/DSS/SNPB)
Robert Lukes, Branch Chief (NRR/DSS/SNPB)

LOGISTICS

Audit Date: Wednesday, March 8, 2017

Audit Location: Rockville, MD

APS should provide a conference room with a white board for discussions, as well as printed copies of reports containing the following information:

- Detailed description of the SKBOR boric acid precipitation methodology and relevant calculation notes.
- Detailed description of the statistical misload methodology and relevant calculation notes.
- Justification for the adequacy of the proposed TCD penalty on FATES-3B and relevant calculation notes.

APS should also provide any other documentation that may aid discussion on the specific topics of interest.

DELIVERABLES

A regulatory audit summary will be provided within 90 days of the completion of the audit.