

## NRR-PMDAPem Resource

---

**From:** Ruben Crosslin <Ruben.Crosslin@tn.gov>  
**Sent:** Wednesday, February 15, 2017 10:34 AM  
**To:** Schaaf, Robert  
**Cc:** Debra Shults; Anthony Hogan; Andrew Holcomb; Saba, Farideh  
**Subject:** [External\_Sender] RE: State Consultation: Request for Comments on Amendments to Watts Bar Units 1 and 2 Operating Licenses Related to Inoperable Dynamic Restraints (Snubbers) (CAC Nos. MF7549 and MF7550)

Thank you for the opportunity to review and comment in regard to the Technical Specification requirements for inoperable dynamic restraints (snubbers). We do not have any comments to submit.

---

**From:** Schaaf, Robert [mailto:Robert.Schaaf@nrc.gov]  
**Sent:** Thursday, February 09, 2017 4:22 PM  
**To:** Ruben Crosslin  
**Cc:** Debra Shults; Anthony Hogan; Andrew Holcomb; Saba, Farideh  
**Subject:** State Consultation: Request for Comments on Amendments to Watts Bar Units 1 and 2 Operating Licenses Related to Inoperable Dynamic Restraints (Snubbers) (CAC Nos. MF7549 and MF7550)

**\*\*\* This is an EXTERNAL email. Please exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email - STS-Security. \*\*\***

Mr. Crosslin,

The NRC is finalizing license amendments for Watts Bar Nuclear Plant (WBN), Units 1 and 2. Per 10 CFR 50.91(b), 10 CFR 50.91(b)(3) and (b)(4), we are notifying you of the proposed issuance. The amendments revise Watts Bar Nuclear Plant, Units 1 and 2, Technical Specification requirements for inoperable dynamic restraints (snubbers) by adding Limiting Condition for Operation (LCO) 3.0.8. The change is consistent with approved Revision 4 to Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-372, "Addition of LCO 3.0.8, Inoperability of Snubbers." The amendment for WBN, Unit 1, also makes an administrative change to add a reference to LCO 3.0.7 in LCO 3.0.1, consistent with TSTF-6, Revision 1, "Add exception for LCO 3.0.7 to LCO 3.0.1."

The licensee's submittal dated March 29, 2016, is available in ADAMS under Accession No. ML16089A452.

The amendment was noticed in the Federal Register on November 22, 2016 (81 FR 83878). See the attachment to this email. No public comments were received.

Please provide any comments regarding this license amendment to me, with a copy to Farideh Saba (address copied on this e-mail), by February 23, 2017. Please note that I will be out of the office February 13 through February 24, please contact Farideh Saba by e-mail or at 301-415-1447 if you have any questions or comments.

Sincerely,  
Robert G. Schaaf  
Robert G. Schaaf  
Senior Project Manager, Watts Bar/Bellefonte

-----  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Mail Stop O-8G9A  
Washington, DC 20555

---

301-415-6020 (o)

[Robert.Schaaf@nrc.gov](mailto:Robert.Schaaf@nrc.gov)

**Hearing Identifier:** NRR\_PMDA  
**Email Number:** 3344

**Mail Envelope Properties** (6563383442558F4A87AF699B3FC17A233C891E79)

**Subject:** [External\_Sender] RE: State Consultation: Request for Comments on Amendments to Watts Bar Units 1 and 2 Operating Licenses Related to Inoperable Dynamic Restraints (Snubbers) (CAC Nos. MF7549 and MF7550)  
**Sent Date:** 2/15/2017 10:34:29 AM  
**Received Date:** 2/15/2017 10:34:42 AM  
**From:** Ruben Crosslin

**Created By:** Ruben.Crosslin@tn.gov

**Recipients:**  
"Debra Shults" <Debra.Shults@tn.gov>  
Tracking Status: None  
"Anthony Hogan" <Anthony.Hogan@tn.gov>  
Tracking Status: None  
"Andrew Holcomb" <Andrew.Holcomb@tn.gov>  
Tracking Status: None  
"Saba, Farideh" <Farideh.Saba@nrc.gov>  
Tracking Status: None  
"Schaaf, Robert" <Robert.Schaaf@nrc.gov>  
Tracking Status: None

**Post Office:** AG03SDCWE00055.net.ads.state.tn.us

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	2633	2/15/2017 10:34:42 AM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**