

TELECOPY MESSAGE

TO: ~~215-557-5000 ext 214~~ ~~FRONT: 515-343-2110 ext~~ ¹³¹² DATE/TIME 10/26/78 / 10:35
Telephone Number Telephone Number

TO: BOYCE H. GRIER
Director of Regulatory Operation
USNRC Region I
631 Park Avenue
King of Prussia, PA. 19406
From: Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
Unit #1
P.O. Box #32
Lycoming, New York 13093

SUBJECT: PROMPT REPORTABLE OCCURRENCE
DOCKET NO. 50-220 LICENSE NO. DPR-63
ASSIGNED LER NO. 78-36

EVENT DATE: 10/25/78 REPORT DATE: 10/26/78

EVENT DESCRIPTION: Analysis of September's Proportional Composite found that concentrations of sodium and sulfate exceeded the values for maximum increase over lake ambient concentration specified in Table 2.3-1 in Environmental Technical Specifications.

COMPONENTS INVOLVED: Make-up Demineralizer Waste Tank, Flow Control Discharge Valve, Flow Meters

CAUSE AND REMEDIAL ACTION: Waste tanks were discharged at rates which exceeded the maximum calculated rate on the discharge data sheets. This was due to a failure of the flow meter on the discharge line, and attempts to control discharge rate by manually throttling the discharge valve. As of October 10, 1978 a newly designed flow control system has been installed, permitting accurate control of discharge meter. In addition, more timely review of discharge records has been established.

FACILITY STATUS: 91 THERMAL EM

- c) Routine Startup _____
- d) Routine Shutdown _____
- e) Steady State Oper X
- f) Load Change _____
- g) Shutdown _____
- h) Refueling _____
- i) Other _____
- j) Not Applicable _____

A written follow-up report will be sent within ten days.

TELECOPY TO B. H. Grier FROM T. J. Perkins DATE 11/26/78
NAME NAME

081157