

APPENDIX A

NOTICE OF VIOLATION

Niagara Mohawk Power Corporation

Docket No. 50-220

This refers to the inspection conducted by representatives of the Region I (Philadelphia) office at the Nine Mile Point Nuclear Station, Unit 1, Scriba, New York, of activities authorized by NRC License No. DPR-63.

During this inspection, conducted on November 27-29, 1978, the following apparent item of noncompliance was identified. This item is an infraction.

- A. Technical Specification (TS) 6.11, "Radiation Protection Program," requires that "procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure."

Procedure RP-2, Radiation Work Permit Procedure (dated September, 1978), developed pursuant to TS 6.11, requires in paragraph 4.6 that the radiation protection technician enter the remaining authorized exposure during the calendar quarter on the Radiation Work Permit (RWP) for each individual selected to work on the job. Paragraph 5.8 of procedure RP-2 requires that individuals added to the work force review their exposure authorization with a radiation protection technician and that the review be recorded by entering the remaining authorized radiation exposure when signing in on the RWP.

Contrary to the above requirements, exposures other than actual remaining authorized exposures were entered for two individuals working under RWP No. 8973, dated October 31, 1978 and one individual working under RWP No. 9072, dated November 14, 1978.

790308

7903080013



RECEIVED
JUN 10 1964
U.S. AIR FORCE