

## UNITED STATES

## NUCLEAR REGULATORY COMMISSION

## REGION I

631 PARK ÄVENUE KING OF PRUSSIA, PENNSYLVANIA 19406

JAN 1 7 1979

Docket No. 50-220

Niagara Mohawk Power Corporation ATTN: Mr. R. R. Schneider Vice President Electric Operations 300 Erie Boulevard West Syracuse, New York 13202

Gentlemen:

Subject: Inspection 50-220/78-15

This refers to your letter dated December 1, 1978, in response to our letter dated November 9, 1978.

Based on the information provided in your letter dated December 1, 1978, and telephone conversations between Mr. J. P. Stohr and Dr. M. Shanbaky of this office and Mr. T. Lempges of your staff on January 3 and 4, 1979, item A will be considered as a licensee identified item. Our records will be modified to reflect this change. However, it is our understanding that all the environmental water samples will be analyzed at your contractor's laboratory until your proposed environmental laboratory is completed, so as to ensure an acceptable level of analytical sensitivity.

With regard to item B, based on the above conversation, it is our understanding that the referenced procedure will be further modified with consideration to operator action so as to ensure that flow reversal operations do not cause the Technical Specification 2.1.5 temperature limits to be exceeded.

With regard to items D and E, your interpretation has been reviewed and has been found to be incorrect. The eight hours, within any 24 hour period, do not have to be consecutive. Therefore these items will remain as items of noncompliance. Please provide this office, within twenty (20) days, as previously requested, a written response including: (1) corrective steps which have been taken by you and the results achieved; (2) corrective steps which will be taken to avoid further items of noncompliance; and (3) the date when full compliance will be achieved.

Thank you for informing us of the corrective and preventive actions documented in your letter and discussed in the aforementioned telephone conversations. These actions will be examined during a subsequent inspection of your licensed program.

7903220327

W

 $\frac{1}{2} \frac{2}{3} \frac{2}{3} \frac{1}{3} = -1.5$ 

Your cooperation with us is appreciated.

Sincerely,

George H. Smith, Chief

Fuel Facility and Materials Safety Branch

cc:

T. E. Lempges, General Superintendent, Nuclear Generation
T. J. Perkins, Station Superintendent
C. L. Stuart, Operations Supervisor
E. B. Thomas, Jr., Esquire

A. Z. Roisman, Natural Resources Defense Council

.

,

.

,