



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220


NINE MILE POINT NUCLEAR STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 31  
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated November 21, 1978, as supplemented January 2, and February 12, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

7904170370



2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraphs 2.C.(2) and 2.C.(3) of Facility Operating License No. DPR-63 are hereby amended to read as follows:

(2) Technical Specifications


The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 31, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

- (3) Operation beyond the end-of-cycle (all rods out condition) thermal power is limited to seventy (70) percent minimum.

Increasing core power level via reduced feedwater heating, once operation in the coastdown mode has begun, is not allowed.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Thomas A. Lippolito, Chief  
Operating Reactors Branch #3  
Division of Operating Reactors

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: April 2, 1979



Handwritten marks and symbols in the top right corner, including a small 'y' and several dots.

A vertical line of small handwritten marks or characters on the left side of the page.

ATTACHMENT TO LICENSE AMENDMENT NO. 31

FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220

Revise Appendix A as follows:

<u>Remove</u>	<u>Insert</u>
5	5
8	8
10	10
11	11
12	12
16	16
17	17
20	20
63	63
64	64
64a	64n
64b	64b
65	65
66	66
67	67
68	68
68a	68a
69a	69a
70c	70c
237a	237a

Marginal lines indicate area of change



## SAFETY LIMIT

### 2.1.1 FUEL CLADDING INTEGRITY

#### Applicability:

Applies to the interrelated variables associated with fuel thermal behavior.

#### Objective:

To establish limits on the important thermal-hydraulic variables to assure the integrity of the fuel cladding.

#### Specification:

- a. When the reactor pressure is greater than 800 psia and the core flow is greater than 10%, the existence of a Minimum Critical Power Ratio (MCPR) less than 1.07 shall constitute violation of the fuel cladding integrity safety limit.
- b. When the reactor pressure is less than or equal to 800 psia or core flow is less than 10% of rated, the core power shall not exceed 25% of rated thermal power.

## LIMITING SAFETY SYSTEM SETTING

### 2.1.2 FUEL CLADDING INTEGRITY

#### Applicability:

Applies to trip settings on automatic protective devices related to variables on which the fuel loading safety limits have been placed.

#### Objective:

To provide automatic corrective action to prevent exceeding the fuel cladding safety limits.

#### Specification:

Fuel cladding limiting safety system settings shall be as follows:

- a. The flow biased APRM scram trip settings shall be less than or equal to that shown in Figure 2.1.1.
- b. The IRM scram trip setting shall not exceed 12% of rated neutron flux.
- c. The reactor high pressure scram trip setting shall be  $\leq$  1080 psig.



4

1

2

3






Figure 2.1.1. Flow Biased Scram and APRM Rod Block

05-4

3.


4

0.1 2

## BASES FOR 2.1.1 FUEL CLADDING - SAFETY LIMIT

The fuel cladding integrity limit is set such that no calculated fuel damage would occur as a result of an abnormal operational transient. Because fuel damage is not directly observable, a step-back approach is used to establish a safety limit such that the Minimum Critical Power Ratio (MCPR) is no less than 1.07.  $MCPR > 1.07$  represents a conservative margin relative to the conditions required to maintain fuel cladding integrity. The fuel cladding is one of the physical barriers which separate radioactive materials from the environs. The integrity of this cladding barrier is related to its relative freedom from perforations or cracking. Although some corrosion or use-related cracking may occur during the life of the cladding, fission product migration from this source is incrementally cumulative and continuously measurable. Fuel cladding perforations, however, can result from thermal stresses which occur from reactor operation significantly above design conditions and the protection system safety settings. While fission product migration from cladding perforation is just as measurable as that from use-related cracking, the thermally caused cladding perforations signal a threshold, beyond which still greater thermal stresses may cause gross rather than incremental cladding deterioration. Therefore, the fuel cladding safety limit is defined with margin to the conditions which would produce onset of transition boiling, (MCPR of 1.0). These conditions represent a significant departure from the condition intended by design for planned operation.

Onset of transition boiling results in a decrease in heat transfer from the clad and, therefore, elevated clad temperature and the possibility of clad failure. However, the existence of critical power, or boiling transition, is not a directly observable parameter in an operating reactor. Therefore, at reactor pressure  $> 800$  psia and core flow  $> 10\%$  of rated the margin to boiling transition is calculated from plant operating parameters such as core power, core flow, feedwater temperature, and core power distribution. The margin for each fuel assembly is characterized by the Critical Power Ratio (CPR) which is the ratio of the bundle power which would produce onset of transition boiling divided by the actual bundle power. The minimum value of this ratio for any bundle in the core is the Minimum Critical Power Ratio (MCPR). It is assumed that the plant operation is controlled to the nominal protective set points via the instrumented variables, by the nominal expected flow control line. The safety limit (MCPR of 1.07) has sufficient conservatism to assure that in the event of an abnormal operational transient initiated from a normal operating condition more than 99.9% of the fuel rods in the core are expected to avoid boiling transition. The margin between MCPR of 1.0 (onset of transition boiling) and the safety limit 1.07 is derived from a detailed statistical analysis considering all of the uncertainties in monitoring the core operating state including uncertainty in the boiling transition correlation as described in References 1 and 12.



## BASES FOR 2.1.1 FUEL CLADDING - SAFETY LIMIT

Because the boiling transition correlation is based on a large quantity of full scale data there is a very high confidence that operation of a fuel assembly at the condition of  $MCPR = 1.07$  would not produce boiling transition. Thus, although it is not required to establish the safety limit, additional margin exists between the safety limit and the actual occurrence of loss of cladding integrity.

However, if boiling transition were to occur, clad perforation would not be expected. Cladding temperatures would increase to approximately  $1100^{\circ}\text{F}$  which is below the perforation temperature of the cladding material. This has been verified by tests in the General Electric Test Reactor (GETR) where similar fuel operated above the critical heat flux for a significant period of time (30 minutes) without clad perforation.

If reactor pressure should ever exceed 1400 psia during normal power operating (the limit of applicability of the boiling transition correlation) it would be assumed that the fuel cladding integrity safety limit has been violated.

In addition to the boiling transition limit ( $MCPR = 1.07$ ) operation is constrained to a maximum LHGR of 13.4 kW/ft for 8x8 fuel and 13.4 kW/ft for 8x8R fuel. At 100% power this limit is reached with a Maximum Total Peaking Factor (MTPF) of 3.02 for 8x8 fuel and 3.00 for 8x8R fuel. For the case of the MTPF exceeding these values, operation is permitted only at less than 100% of rated thermal power and only with reduced APRM scram settings as required by Specification 2.1.2.a. (In cases where for a short period the total peaking factor was above 3.02 for 8x8 fuel and 3.00 for 8x8R fuel the equation in Figure 2.1.1 will be used to adjust the flow biased scram and APRM rod block set points.

At pressure equal to or below 800 psia, the core elevation pressure drop (0 power, 0 flow) is greater than 4.56 psi. At low power and all core flows, this pressure differential is maintained in the bypass region of the core. Since the pressure drop in the bypass region is essentially all elevation head, the core pressure drop at low powers and all flows will always be greater than 4.56 psi.

Analyses show that with a bundle flow of  $28 \times 10^3$  lb/hr, bundle pressure drop is nearly independent of bundle power and has a value of 3.5 psi. Therefore, due to the 4.56 psi driving head, the bundle flow will be greater than  $28 \times 10^3$  lb/hr irrespective of total core flow and independent of bundle power for the range of bundle powers of concern. Full scale ATLAS test data taken at pressures from 14.7 psia to 800 psia indicate that the fuel assembly critical power at  $28 \times 10^3$  lb/hr



1941

4

1941

22

## BASES FOR 2.1.1 FUEL CLADDING - SAFETY LIMIT

is approximately 3.35 MWt. With the design peaking factor, this corresponds to a core thermal power of more than 50%. Thus, a core thermal power limit of 25% for reactor pressures below 800 psia or core flow less than 10% is conservative.

During transient operation the heat flux (thermal power-to-water) would lag behind the neutron flux due to the inherent heat transfer time constant of the fuel which is 8 to 9 seconds. Also, the limiting safety system scram settings are at values which will not allow the reactor to be operated above the safety limit during normal operation or during other plant operating situations which have been analyzed in detail.<sup>(3,4)</sup> In addition, control rod scrams are such that for normal operating transients the neutron flux transient is terminated before a significant increase in surface heat flux occurs. Scram times of each control rod are checked periodically to assume adequate insertion times. Exceeding a neutron flux scram setting and a failure of the control rods to reduce flux to less than the scram setting within 1.5 seconds does not necessarily imply that fuel is damaged; however, for this specification a safety limit violation will be assumed any time a neutron flux scram setting is exceeded for longer than 1.5 seconds.

If the scram occurs such that the neutron flux dwell time above the limiting safety system setting is less than 1.7 seconds, the safety limit will not be exceeded for normal turbine or generator trips, which are the most severe normal operating transients expected. These analyses show that even if the bypass system fails to operate, the design limit of MCPR = 1.07 is not exceeded. Thus, use of a 1.5-second limit provides additional margin.

The process computer has a sequence annunciation program which will indicate the sequence in which scrams occur such as neutron flux, pressure, etc. This program also indicates when the scram set point is cleared. This will provide information on how long a scram condition exists and thus provide some measure of the energy added during a transient. Thus, computer information normally will be available for analyzing scrams; however, if the computer information should not be available for any scram analysis, Specification 2.1.1.c will be relied on to determine if a safety limit has been violated.



112

113

114



### BASES FOR 2.1.2 FUEL CLADDING - LS<sup>3</sup>

void content are minor, cold water from sources available during startup is not much colder than that already in the system, temperature coefficients are small, and control rod patterns are constrained to be uniform by operating procedures backed up by the rod worth minimizer. Worth of individual rods is very low in a uniform rod pattern. Thus, of all possible sources of reactivity input, uniform control rod withdrawal is the most probable cause of significant power rise. Because the flux distribution associated with uniform rod withdrawals does not involve high local peaks, and because several rods must be moved to change power by a significant percentage of rated, the rate of power rise is very slow. Generally, the heat flux is in near equilibrium with the fission rate. In an assumed uniform rod withdrawal approach to the scram level, the rate of power rise is no more than 5% of rated per minute, and the IRM system would be more than adequate to assure a scram before the power could exceed the safety limit.

Procedural controls will assure that the IRM scram is maintained up to 20% flow. This is accomplished by keeping the reactor mode switch in the startup position until 20% flow is exceeded and the APRM's are on scale. Then the reactor mode switch may be switched to the run mode, thereby switching scram protection from the IRM to the APRM system.

In order to ensure that the IRM provided adequate protection against the single rod withdrawal error, a range of rod withdrawal accidents was analyzed. This analysis included starting the accident at various power levels. The most severe case involves an initial condition in which the reactor is just subcritical and the IRM system is not yet on scale. This condition exists at quarter rod density. Additional conservatism was taken in this analysis by assuming that the IRM channel closest to the withdrawn rod is bypassed. The results of this analysis show that the reactor is scrammed and peak power limited to 1% of rated power, thus maintaining MCPR above 1.07. Based on the above analysis, the IRM provides protection against local control rod withdrawal errors and continuous withdrawal of control rods in sequence and provides backup protection for the APRM.

- c. As demonstrated in Appendix E-I\* and the Technical Supplement to Petition to Increase Power Level, the reactor high pressure scram is a backup to the neutron flux scram, turbine stop valve closure scram, generator load rejection scram, and main steam isolation valve closure



11/14

11/14

11/14

11/14

### BASES FOR 2.1.2 FUEL CLADDING - LS<sup>3</sup>

---

scram, for various reactor isolation incidents. However, rapid isolation at lower power levels generally results in high pressure scram preceding other scrams because the transients are slower and those trips associated with the turbine generator are bypassed.

The operator will set the trip setting at 1080 psig or lower. However, the actual set point can be as much as 15.8 psi above the 1080 psig indicated set point due to the deviations discussed above.


- d. A reactor water low level scram trip setting -12 inches (53 inches indicator scale) relative to the minimum normal water level (Elevation 302' 9") will assure that power production will be terminated with adequate coolant remaining in the core. The analysis of the feedwater pump loss in the Technical Supplement to Petition to Increase Power Level, dated April 1970, has demonstrated that approximately 4 feet of water remains above the core following the low level scram.

The operator will set the low level trip setting no lower than -12 inches relative to the lowest normal operating level. However, the actual set point can be as much as 2.6 inches lower due to the deviations discussed above.

- e. A reactor water low-low level signal -5 feet (5 inches indicator scale) relative to the minimum normal water level (Elevation 302' 9") will assure that core cooling will continue even if level is dropping. Core spray cooling will adequately cool the core, as discussed in LCO 3.1.4.

The operator will set the low-low level core spray initiation point at no less than -5 feet (5 inches indicator scale) relative to the minimum normal water level (Elevation 302' 9"). However, the actual set point can be as much as 2.6 inches lower due to the deviations discussed above.


- f. Reactor power level may be varied by moving control rods or by varying the recirculation flow rate. The APRM system provides a control rod block to prevent rod withdrawal beyond a given point at constant recirculation flow rate, and thus to protect against the condition of a MCPR less than 1.07. This rod block trip setting, which is automatically varied with recirculation flow rate, prevents an increase in the reactor power level to excessive values due to control rod withdrawal. The flow variable trip setting provides substantial margin from fuel damage, assuming a steady-state operation at the trip setting, over the entire recirculation flow range. The margin to the safety limit increases as the flow decreases for the specified trip setting versus flow relationship; therefore, the worst case MCPR which could occur during



REFERENCES FOR BASES 2.1.1 AND 2.1.2 FUEL CLADDING

---

- (1) General Electric BWR Thermal Analysis Basis (GETAB) Data, Correlation and Design Application, NEDO-10958 and NEDE-10958.
- (2) Linford, R. B., "Analytical Methods of Plant Transient Evaluations for the General Electric Boiling Water Reactor," NEDO-10801, February 1973.
- (3) FSAR, Volume II, Appendix E.
- (4) FSAR, Second Supplement.
- (5) FSAR, Volume II, Appendix E.
- (6) FSAR, Second Supplement.
- (7) Letters, Peter A. Morris, Director of Reactor Licensing, USAEC, to John E. Logan, Vice-President, Jersey Central Power and Light Company, dated November 22, 1967 and January 9, 1968.
- (8) Technical Supplement to Petition to Increase Power Level, dated April 1970.
- (9) Letter, T. J. Brosnan, Niagara Mohawk Power Corporation, to Peter A. Morris, Division of Reactor Licensing, USAEC, dated February 28, 1972.
- (10) Letter, Philip D. Raymond, Niagara Mohawk Power Corporation, to A. Giambusso, USAEC, dated October 15, 1973.
- (11) Nine Mile Point Nuclear Power Station Unit 1 Load Line Limit Analysis, NEDO 24012, May, 1977.
- (12) Licensing Topical Report General Electric Boiling Water Reactor Generic Reload Fuel Application, NEDE-24011-P-A, August, 1978.



## LIMITING CONDITION FOR OPERATION

### 31.7 FUEL RODS

#### Applicability:

The Limiting Conditions for Operation associated with the fuel rods apply to those parameters which monitor the fuel rod operating conditions.

#### Objective:

The objective of the Limiting Conditions for Operation is to assure the performance of the fuel rods.

#### Specification:

a. Average Planar Linear Heat Generation Rate (APLHGR)

During power operation, the APLHGR for each type of fuel as a function of average planar exposure shall not exceed the limiting value shown in Figures 3.1.7a, 3.1.7b, and 3.1.7c. If at any time during power operation it is determined by normal surveillance that the limiting value for APLHGR is being exceeded at any node in the core, action shall be initiated within 15 minutes to restore operation to within the prescribed limits. If the APLHGR at all nodes in the core is not returned to within the prescribed limits within two (2) hours, reactor power reductions shall be initiated at a rate not less than 10% per hour until APLHGR at all nodes is within the prescribed limits.

During power operation with one recirculation line isolated, the APLHGR for each fuel type as a function of average planar exposure shall not exceed 98% of limiting value shown in Figures 3.1.7a, 3.1.7b, and 3.1.7c.

## SURVEILLANCE REQUIREMENT

### 4.1.7 FUEL RODS

#### Applicability:

The Surveillance Requirements apply to the parameters which monitor the fuel rod operating conditions.


#### Objective:

The objective of the Surveillance Requirements is to specify the type and frequency of surveillance to be applied to the fuel rods.

#### Specification:

a. Average Planar Linear Heat Generation Rate (APLHGR)

The APLHGR for each type of fuel as a function of average planar exposure shall be determined daily during reactor operation at  $\geq 25\%$  rated thermal power.





**LIMITING CONDITION FOR OPERATION**

**b. Linear Heat Generation Rate (LHGR)**

During power operation, the Linear Heat Generation Rate (LHGR) of any rod in any fuel assembly at any axial location shall not exceed the maximum allowable LHGR as calculated by the following equation:

$$LHGR_{\max} \leq LHGR_d \left( 1 - \left( \frac{\Delta P}{P} \right)_{\max} \left( \frac{L}{LT} \right) \right)$$

$LHGR_d$  = Design LHGR =

13.4 kW/ft for 8x8 and 8x8R fuel

$\frac{\Delta P}{P}_{\max}$  = Maximum power spiking penalty =  
0.022 for 8x8 and 8x8R fuel

LT = Total core length - 12 ft for 8x8 fuel and  
12.1033 ft for 8x8R fuel


L = Axial position above bottom of core

If at any time during power operation it is determined by normal surveillance that the limiting value for LHGR is being exceeded at any location, action shall be initiated within 15 minutes to restore operation to within the prescribed limits. If the LHGR at all locations is not returned to within the prescribed limits within two (2) hours, reactor power reductions shall be initiated at a rate not less than 10% per hour until LHGR at all locations is within the prescribed limits.

**SURVEILLANCE REQUIREMENT**

**b. Linear Heat Generation Rate (LHGR)**

The LHGR as a function of core height shall be checked daily during reactor operation at  $\geq 25\%$  rated thermal power.



**LIMITING CONDITION FOR OPERATION**

**SURVEILLANCE REQUIREMENT**

**c. Minimum Critical Power Ratio (MCPR)**

During power operation MCPR shall be  $\geq 1.40$  for 8x8 fuel and  $\geq 1.37$  for 8x8R fuel at rated power and flow. If at any time during power operation it is determined by normal surveillance that these limits are no longer met, action shall be initiated within 15 minutes to restore operation to within the prescribed limits. If all the operating MCPRs are not returned to within the prescribed limits within two (2) hours, reactor power reductions shall be initiated at a rate not less than 10% per hour until MCPR is within the prescribed limits.

For core flows other than rated the MCPR limits shall be the limits identified above times  $K_f$  where  $K_f$  is as shown in Figure 3.1.7-1.

**d. Power Flow Relationship During Power Operation**

The power/flow relationship shall not exceed the limiting values shown in Figure 3.1.7.aa.

When operating the reactor with one recirculation loop isolated, core power shall be restricted to 90.5% full licensed power.

**c. Minimum Critical Power Ratio (MCPR)**

MCPR shall be determined daily during reactor power operation at  $>25\%$  rated thermal power.

**d. Power Flow Relationship**

Compliance with the power flow relationship in Section 3.1.7.d shall be determined daily during reactor operation.



## LIMITING CONDITION FOR OPERATION

## SURVEILLANCE REQUIREMENT

If at any time during power operation it is determined by normal surveillance that the limiting value for the power/flow relationship is being exceeded, action shall be initiated within 15 minutes to restore operation to within the prescribed limits. If the power/flow relationship is not returned to within the prescribed limits within two (2) hours, reactor power reductions shall be initiated at a rate not less than 10% per hour until the power/flow relationship is within the prescribed limits.

### e. Reporting Requirements

If any of the limiting values identified in Specification 3.1.7.a, b, c and d are exceeded, a Reportable Occurrence Report shall be submitted. If the corrective action is taken, as described, a thirty-day written report will meet the requirements of this Specification.



1950

1951

1952

1953

1954

1955

1956

1957

1958

1959

1960

1961

1962

1963

1964

1965

1966

1967

1968

1969

1970

1971

1972

1973

1974

1975

1976

1977

1978

1979

1980

1981

1982

1983

1984

1985

1986

1987

1988

1989

1990

1991

1992

1993

1994

1995

1996

1997

1998

1999

2000

2001

2002

2003

2004

2005

2006

2007

2008

2009

2010

2011

2012

2013

2014

2015

2016

2017

2018

2019

2020

2021

2022

2023

2024

2025




Figure 3.1.7a MAXIMUM ALLOWABLE AVERAGE PLANAR LHGR APPLICABLE TO 8DB250 and 8DB262 FUEL AS DESCRIBED IN REFERENCE 8.

Amendment No. 31



Vertical text or markings along the right edge of the page, possibly bleed-through from the reverse side.








FIGURE 3.1.7b MAXIMUM ALLOWABLE AVERAGE PLANAR LHGR APPLICABLE TO 8DB274L and 8DB274H FUEL  
As Described in Reference 8.



Nine Mile Point Unit 1

MAXIMUM AVERAGE PLANAR LHGR (KW/FT)


10  
9  
8  
7  
6



Amendment No. 31

AVERAGE PLANAR EXPOSURE (MWD/ST)

FIGURE 3.1.7c MAXIMUM ALLOWABLE AVERAGE PLANAR LHGR APPLICABLE TO 8DNB277 FUEL  
As Described in Reference 8.



LEFT INTENTIONALLY BLANK



2

4


1

LEFT INTENTIONALLY BLANK





LEFT INTENTIONALLY BLANK



REFERENCES FOR BASES 3.1.7 AND 4.1.7 FUEL RODS

---

- (1) "Fuel Densification Effects on General Electric Boiling Water Reactor Fuel," Supplements 6, 7 and 8, NEDM-10735, August 1973.
- (2) Supplement 1 to Technical Report on Densifications of General Electric Reactor Fuels, December 14, 1974 (USA Regulatory Staff).
- (3) Communication: V. A. Moore to I. S. Mitchell, "Modified GE Model for Fuel Densification," Docket 50-321, March 27, 1974.
- (4) "General Electric Boiling Water Reactor Generic Reload Application for 8 x 8 Fuel," NEDO-20360, Supplement 1 to Revision 1, December 1974.
- (5) "General Electric Company Analytical Model for Loss of Coolant Analysis in Accordance with 10CFR50 Appendix K," NEDO-20566.
- (6) General Electric Refill Reflood Calculation (Supplement to SAFE Code Description) transmitted to the USAEC by letter, G. L. Gyorey to Victor Stello Jr., dated December 20, 1974.
- (7) "Nine Mile Point Nuclear Power Station Unit 1, Load Line Limit Analysis," NEDO-24012.
- (8) Licensing Topical Report General Electric Boiling Water Reactor Generic Reload Fuel Application, NEDE-24011-P-A, August, 1978.



## BASES FOR 3.6.2 AND 4.6.2 PROTECTIVE INSTRUMENTATION

---

- b. The control rod block functions are provided to prevent excessive control rod withdrawal so that MCPR is maintained greater than 1.07. The trip logic for this function is 1 out of n; e.g., any trip on one of the eight APRM's, eight IRM's or four SRM's will result in a rod block. The minimum instrument channel requirements provide sufficient instrumentation to assure the single failure criteria is met. The minimum instrument channel requirements for the rod block may be reduced by one for a short period of time to allow for maintenance, testing, or calibration. This time period is only ~3% of the operating time in a month and does not significantly increase the risk of preventing an inadvertent control rod withdrawal.
- \* The APRM rod block trip is flow biased and prevents a significant reduction in MCPR especially during operation at reduced flow. The APRM provides gross core protection; i.e., limits the gross core power increase from withdrawal of control rods in the normal withdrawal sequence. The trips are set so that MCPR is maintained greater than 1.07.

The APRM rod block also provides local protection of the core; i.e., the prevention of critical heat flux in a local region of the core, for a single rod withdrawal error from a limiting control rod pattern. The trip point is flow biased. The worst case single control rod withdrawal error has been analyzed and the results show that with the specified trip settings rod withdrawal is blocked before the MCPR reaches 1.07, thus allowing adequate margin. Below ~60% power the worst case withdrawal of a single control rod results in a MCPR >1.07 without rod block action, thus below this level it is not required.

The IRM rod block function provides local as well as gross core protection. The scaling arrangement is such that trip setting is less than a factor of 10 above the indicated level. Analysis of the worst case accident results in rod block action before MCPR approaches 1.07.

A downscale indication on an APRM or IRM is an indication the instrument has failed or the instrument is not sensitive enough. In either case the instrument will not respond to changes in control rod motion and the control rod motion is prevented. The downscale trips are set at 5/125 of full scale for IRM and 3/125 of full scale for APRM.



100

100

100

100