



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220

NINE MILE POINT NUCLEAR STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 30  
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated January 11, 1977, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

7906250032

10



1 2 3

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-63 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 30, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas A. Appolito, Chief  
Operating Reactors Branch #3  
Division of Operating Reactors

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: March 26, 1979



. .

. .

.

.

.

.

ATTACHMENT TO LICENSE AMENDMENT NO. 30

FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220

Revise Appendix A by removing page 78 and replacing with revised page 78.  
Marginal lines indicate area of change.



. .

. .

.

. .

.

.

.

.

.

.

.

LIMITING CONDITION FOR OPERATION

- c. During hydrostatic testing the reactor vessel pressure and temperature shall satisfy the most limiting requirements of Figure 3.2.2.b.
- d. The reactor vessel head bolting studs shall not be under tension unless the temperature of the vessel head flange and the head are equal to or greater than 100F.

SURVEILLANCE REQUIREMENT

- c: Vessel material surveillance samples located within the core region to permit periodic monitoring of exposure and material properties shall be inspected on the following schedule:

First capsule - one fourth service life  
Second capsule - three fourth service life  
Third capsule - standby

In the event the surveillance specimens at one quarter of the vessels service life indicate a shift of reference temperature greater than predicted the schedule shall be revised as follows:

Second capsule - one half service life  
Third capsule - standby

