

NEDO-24185
79NED266
Class I
April 1979

NINE MILE POINT NUCLEAR POWER STATION UNIT 1
EXTENDED LOAD LINE LIMIT ANALYSIS
LICENSE AMENDMENT SUBMITTAL (CYCLE 6)

Prepared:

J. V. Woodford
J. V. Woodford, Sr. Engineer
Operating Licenses II

Approved:

R. O. Brugge
R. O. Brugge, Manager
Operating Licenses II

NUCLEAR ENERGY PROJECTS DIVISION • GENERAL ELECTRIC COMPANY
SAN JOSE, CALIFORNIA 95125

GENERAL  ELECTRIC

7906290600

IMPORTANT NOTICE REGARDING
CONTENTS OF THIS REPORT
PLEASE READ CAREFULLY

This report was prepared by General Electric solely for Niagara Mohawk Power Corporation (NMPC) for NMPC's use with the U.S. Nuclear Regulatory Commission (USNRC) for amending NMPC's operating license of the Nine Mile Point Nuclear Power Station Unit 1. The information contained in this report is believed by General Electric to be an accurate and true representation of the facts known, obtained, or provided to General Electric at the time this report was prepared.

The only undertakings of the General Electric Company respecting information in this document are contained in Niagara Mohawk Power Corporation Purchase Order No. 69545 dated 1/29/79 as amended by exceptions noted in General Electric memorandum dated 2/20/79 for analysis for the nuclear system for Nine Mile Point Nuclear Power Station, Unit 1, and nothing contained in this document shall be construed as changing said agreement. The use of this information except as defined by said agreement, or for any purpose other than that for which it is intended, is not authorized; and with respect to any such unauthorized use, neither General Electric Company nor any of the contributors to this document makes any representation or warranty (express or implied) as to the completeness, accuracy, or usefulness of the information contained in this document or that such use of such information may not infringe privately owned rights; nor do they assume any responsibility for liability or damage of any kind which may result from such use of such information.



1. INTRODUCTION

Previous analyses (References 1 and 2) provided the analytical bases for operation under a modified power/flow line designed to enable the direct ascension to full power within the design bases previously applied.

This submittal provides results of analyses which justify operation up to 100% of rated power at 91% of rated core flow. The analysis results are provided in the same sequence as the standard reload format to assure that all aspects of reactor operation which are affected are covered. Future reload submittals will incorporate the use of the extended load line in the analysis.

2. ANALYSIS RESULTS

- 2.1 Plant-Unique Items - Not Affected
- 2.2 Reload Fuel Bundles - Not Affected
- 2.3 Reference Core Loading Pattern - Not Affected
- 2.4 Calculated Core Effective Multiplication and Control System Worth -
No Voids, 20°C - Not Affected
- 2.5 Standby Liquid Control System Shutdown Capability - Not Affected
- 2.6 Reload-Unique Transient Analysis Inputs - Affected by Additional
Data as Shown



Transient Analysis Inputs

	<u>EOC</u>	<u>EOC-1000 MWd/t</u>	<u>EOC-2000 MWd/t</u>
Void Coefficient N/A,* (c/% Rg)	-6.85/-8.56	-7.58/-9.48	-8.67/-10.84
Void Fraction (%)	37.42	37.42	37.42
Doppler Coefficient N/A (c/% °F)	-0.233/-0.222	-0.228/-0.216	-0.222/-0.210
Avg Fuel Temperature (°F)	1204	1204	1204
Scram Worth N/A (\$)	-36.83/-29.47	-35.61/-28.49	-33.73/-26.99
Scram Reactivity	Figure 1a	Figure 1b	Figure 1c


*N = Nuclear Input Data
A = Used in Transient Analysis

2.7 Reload-Unique GETAB Transient Analysis Initial Condition Parameters - Affected by Additions as Shown

Unique GETAB Transient Analysis
Initial Condition Parameters

	100% Power/91% Flow					
	<u>EOC</u>	<u>8x8</u> <u>EOC-1000 MWd/t</u>	<u>EOC-2000 MWd/t</u>	<u>EOC</u>	<u>8x8R</u> <u>EOC-1000 MWd/t</u>	<u>EOC-2000 MWd/t</u>
Peaking Factors						
Local	1.22	1.22	1.22	1.20	1.20	1.20
Radial	1.676	1.704	1.704	1.822	1.850	1.850
Axial	1.4	1.4	1.4	1.4	1.4	1.4
R-Factor	1.102	1.102	1.102	1.051	1.051	1.051
Bundle Power (MWt)	5.707	5.802	5.802	6.201	6.294	6.294
Bundle Flow (10 ³ lb/hr)	93.34	92.67	92.67	89.53	88.96	88.96
Initial MCPR	1.22	1.20	1.20	1.22	1.20	1.20

2.8 Selected Margin Improvement Options - Not Affected



2000-01-01 00:00:00 2000-01-01 00:00:00 2000-01-01 00:00:00 2000-01-01 00:00:00 2000-01-01 00:00:00

2.9 Core-Wide Transient Analysis Results - Affected by Additions
as Shown

Core-Wide Transient Analysis Results

<u>Transient</u>	<u>Exposure</u>	<u>Power (%)</u>	<u>Core Flow (%)</u>	$\hat{\phi}$ <u>(% Ref)</u>	\hat{Q}/A <u>(% Ref)</u>	P_{Dome} <u>(psig)</u>	P_V <u>(psig)</u>	ΔCPR <u>8x8/8x8R</u>	<u>Plant Response</u>
Turbine Trip w/o Bypass	EOC	94.3	91	208.5	99.9	1193	1227	0.15	Figure 2a
Turbine Trip w/o Bypass	EOC-1000 MWd/t	98.0	91	168.4	98.7	1190	1224	0.06	Figure 2b
Turbine Trip w/o Bypass	EOC-2000 MWd/t	100	91	139.5	100.0	1179	1213	<0.01	Figure 2c

2.10 Local Rod Withdrawal Error (With Limiting Instrument Failure) Transient Summary - Affected by Additions as Shown

Local Rod Withdrawal Error (With Limiting Instrument Failure)
Transient Summary

<u>Rod Block Reading</u>	<u>Rod Position (Feet Withdrawn)</u>	<u>ΔCPR</u>		<u>LHGR</u>		<u>Limiting Rod Pattern</u>
		<u>8x8</u>	<u>8x8R</u>	<u>8x8</u>	<u>8x8R</u>	
104	8.0	0.30	0.25	13.77	15.69	Figure 3
105*	8.5	0.32	0.27	13.90	15.90	Figure 3
106	9.0	0.33	0.30	14.00	16.06	Figure 3
107	9.0	0.33	0.30	14.00	16.06	Figure 3
108	9.5	0.34	0.32	13.93	16.03	Figure 3
109	9.5	0.34	0.32	13.80	16.03	Figure 3


*Rod Block Setpoint

2.11 Operating MCPR Limit - Not Affected

2.12 Overpressurization Analysis Summary

Conservative analysis (EOC case) shows that operation of the plant in accordance with the extended load line limit does not violate the vessel overpressure protection criteria. Calculated peak pressures are at least 25 psi below the criteria of 1375 psig.

2.13 Stability Analysis Results - Not Affected



2.14 Loss-of-Coolant Accident Results - Potential Effects Explained

A discussion of low flow effects on LOCA analyses for all operating plants (Reference 3) has been presented to and was approved by the NRC (Reference 4). With the flow-dependent restrictions imposed by Reference 4, the LOCA analysis referenced in the plant/cycle specific reload submittal is applicable in the power flow domain discussed in this submittal.

2.15 Loading Error Results - Not Affected

2.16 Control Rod Drop Analysis Results - Not Affected



REFERENCES

1. "Nine Mile Point Nuclear Power Station Unit 1 Load Line Limit Analysis License Amendment Submittal", NEDO-24012, May 1977.
2. "Supplemental Reload Licensing Submittal for Nine Mile Point Nuclear Power Station Unit 1 Reload No. 7 Reanalysis Supplement", NEDO-24155-1, Supplement 1, December 1978.
3. Letter, R.L. Gridley to D.G. Eisenhut (NRC), "Review of Low Core Flow Effects on LOCA Analysis for Operating BWR's", May 8, 1978.
4. Letter, D.G. Eisenhut (NRC) to R.L. Gridley, enclosing "Safety Evaluation Report Revision of Previously Imposed MAPLHGR (ECCS-LOCA) Restrictions for BWR's at Less Than Rated Flow", May 19, 1978.



[The page contains extremely faint and illegible text, possibly bleed-through from the reverse side. The text is scattered across the page and does not form any recognizable words or sentences.]




Figure 1a. EOC Scram Reactivity



[Faint, illegible text or markings, possibly bleed-through from the reverse side of the page.]




Figure 1b. EOC-1000 MWd/t Scram Reactivity



[The text in this section is extremely faint and illegible. It appears to be a list or a series of entries, possibly organized in a table or grid format. The content is mostly lost to noise and low contrast.]




Figure 1c. EOC-2000 MWd/t Scram Reactivity










Figure 2a. Nine Mile Point-1 Turbine Trip Without Bypass, Trip Scram, EOC









Figure 2b. Nine Mile Point-1 Turbine Trip Without Bypass, Trip Scram, EOC-1000 MWd/t



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

[Faint, illegible text scattered across the page]








Figure 2c. Nine Mile Point-1 Turbine Trip Without Bypass, Trip Scram, EOC-2000 MWd/t



	02	06	10	14	18	22	26
51						00	
47					28		36
43				16		16	
39			00		00		00
35		16		36		38	
31			00		00		08
27		16		38		36	

- NOTES: 1. ROD PATTERN IS 1/4 CORE MIRROR SYMMETRIC. UPPER LEFT QUADRANT IS SHOWN ON MAP
2. NUMBERS INDICATE NOTCHES WITHDRAWN OUT OF 48. BLANK IS A WITHDRAWN ROD
3. ERROR ROD IS 18,31

Figure 3. Limiting Rod Pattern

ATTACHMENT C

Niagara Mohawk Power Corporation

License No. DPR-63

Docket No. 50-220

Amendment Classification

The proposed amendment to the operating license has been evaluated and determined to fall within the definition of Class III of 10 C.F.R. 170.22 thereby requiring a fee of four thousand dollars (\$4,000.00).

The proposed amendment for Nine Mile Point Unit 1 involves only a single safety issue. Therefore, it meets the requirements of Class III of 10 C.F.R. 170.22.

