

June 18, 1979

Office of Inspection and Enforcement  
Region I  
Attn: Mr. Boyce H. Grier, Director  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406


Dear Mr. Grier:

Re: Nine Mile Point Unit 2  
Docket No. 50-410

Your April 17, 1979 I. E. Bulletin 79-09 requested Niagara Mohawk to determine if General Electric type AK-2 circuit breakers are planned for use in safety-related systems at Nine Mile Point Unit 2. We do not plan to use General Electric type AK-2 circuit breakers in safety-related systems at Unit 2. The safety-related equipment which would utilize this type of circuit breaker has been purchased and it has been verified that the subject circuit breakers are not compatible with our equipment.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



Gerald K. Rhode  
Vice President  
System Project Management

Xc: U. S. Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
Division of Reactor Operations Inspection  
Washington, D. C. 20555

7908080024

11