

**NY NIAGARA
NM MOHAWK**

NMP-1136

NINE MILE POINT NUCLEAR STATION /P.O. BOX 32 LYCOMING, NEW YORK 13093 / TELEPHONE (315) 343-2110

July 9, 1979

Mr. Boyce H. Grier
Director
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA. 19406

RE: Docket No. 50-220
I.E. Bulletin 79-11

Dear Mr. Grier:

Your I.E. Bulletin 79-11, dated May 22, 1979, addresses faulty overcurrent trip device in circuit breakers for engineered safety systems.

Nine Mile Point Nuclear Station Unit #1 does not use any Westinghouse Type DB-50 or DB-75 circuit breakers in any safety system.

Very truly yours,

Thomas E. Lemoges

Thomas E. Lemoges -
General Superintendent -
Nuclear Generation
FOR R.R. Schneider
Vice President -
Electric Production

mtm

cc: Director, Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

002
CCF

7908070661

