

N V NIAGARA
N M MOHAWK

NIAGARA MOHAWK POWER CORPORATION/300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202/TELEPHONE (315) 474-1511

May 31, 1979

Office of Inspection and Enforcement
Region I
Attn: Mr. Boyce H. Grier, Director
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406


Dear Mr. Grier:

Re: Nine Mile Point Unit 2
Docket No. 50-410

Your March 30, 1979 I. E. Bulletin 79-04 indicated that incorrect weights for certain swing check valves manufactured by Velan Engineering Corporation may have been used in piping stress analysis. In response, no 1500 psi 3, 4, or 6-inch diameter Velan swing check valves are being installed or planned to be installed in Seismic Category I piping systems at Nine Mile Point Unit 2.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



Gerald K. Rhode
Vice President
System Project Management

Xc: U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D. C. 20555

7908080

497

